

Performance assessment of a small-scale adsorption chiller integrated to an already existing solar heating system



Sébastien Thomas^{1*}; Stefan Maas² ; Philippe André¹

¹University of Liège, Belgium. BEMS Building Energy Monitoring and Simulation

²University of Luxembourg. Faculté des Sciences, de la Technologie et de la Communication

*Corresponding author : sebastien.thomas@ulg.ac.be



Objective : To measure the thermal and electrical energy performance of a small scale air-conditioning system

Solar air-conditioning system components



A small-scale adsorption chiller was installed in April 2011 in a laboratory building. This building was previously equipped with a fully monitored heat and cold production and distribution system. A solar collector field (14m²) used for building heating and domestic hot water production exists. The heart of the system contains an adsorption chiller INVENSOR LTC09 (9kW_{cold}) nominal power, a dry cooling tower and a hydronic module including pumps.

Control strategy

The main assumption deals with the cooling load. A building with infinite cooling load is considered. In this way the total cold water produced is used to cool the building. This assumption allows to evaluate the chiller performance with a fixed cold water temperature (15-18°C).

Due to the small collector field compared to the adsorption nominal power, the system cycles during the day. Longest operating period : 3h30min

Solar loop is made of 14 m² flat plate collectors, a draining system and a 300 l hot water storage. Cold water is stored in a 500 l tank and distributed in the laboratory with the air handling unit, a cooling ceiling and cooling floors.



Monitoring


Thermal performance measurements :

temperatures → energy flows
massflows → COPs
Electrical performance
powers


Meteorological data measurements

temperature, humidity and solar radiation


Typical cycle results





Solar cooling @ University of Liège



— Qcollector
— Qcold water
— Qcooling water
— Qdrive heat
— T hot water supply
— T cold water produced
— T cooling tower return



Daily results



Results summary

	Units	Mean value for 51 days	Sunny and hot day 27th June 2011
Collected solar energy	[kWh/day]	22.1	45.8
Cold energy produced	[kWh/day]	8.2	21.3
Electricity consumed (fans, 4 pumps, ADS chiller)	[kWh/day]	3.4	6.6
Electricity cons. standby	[kWh/day]	0.61	0.56
Thermal COP	[-]	0.47	0.54
Electrical COP	[-]	2.38	3.21
Electrical COPADS only	[-]	4.71	3.62
Collector yield	[-]	0.3	0.44
Primary Energy ratio	[-]	0.95	1.29



Conclusion

Measurements of the solar cooling systems provide performance indicators. On a thermally point of view, a good COP_{therm} is achieved (around 0.5). Some enhancements will be done to increase this value.

After preliminary tests, a more energy efficient solar pump was installed during the tests. The total electricity consumption remains high and the complete system does not reach high COP_{elec} (5.1 maximum). A spraying kit will be installed ; it will certainly raise this performance indicator.