

Simulation based energy consumption calculation of an office building using solar-assisted air conditioning



S. Thomas*; P. André
 Environmental Sciences and Management Department
 Avenue de Longwy 185, 6700 Arlon, Belgium
 *Corresponding author : sebastien.thomas@ulg.ac.be



Objective : Evaluate **solar energy potential** in office building air-conditioning

At 3 locations

Stockholm - Paris - Lisbon

3 Heating/Cooling systems, 5 cases

Case	Heating		Cooling	
	Energy source	Equipment	Energy source	Equipment
1	Gas	Boiler	Electricity	Vapour compression system
2 .A .B	Gas	Boiler	Sun, Electricity grid as back-up	Vapour compression system, PV panels
3 .A .B	Gas, Sun	Boiler, solar thermal panels	Sun, Gas as back-up	Absorption chiller, solar thermal panels

Available space for solar pannels : building roof.
 Case 2.A ; 3.A : 3 floor building
 Case 2.B ; 3.B : 12 floor building

Case 1 Classical A-C

Key parameters
 Boiler efficiency = 88.2 to 89.2 %
 Chiller COP :
 3.5 at rating point
 4.5 (yearly mean value Lisbon)
 Hot water t° : 90°C to 45°C
 Cold water t° : 7°C
 Emission equipment :
 fan coil units (same for each case)
 Distribution equipment :
 2 different pipe networks (hot/cold) (same for each case)

Case 2.A 2.B PV field

Equipment added to case 1 :
 Polycrystalline silicon PV module market available
 610 m² net PV area on the roof
 Inclination angle
 36° Paris
 42° Stockholm
 34° Lisbon
 (optimised for yearly production)
 Inverter yield : 78%, optimal point tracking

Case 3.A 3.B Thermal field Absorption chiller

Hot water storage tank
 STO 3 - PAR 7 - LISB 11 m³
 Evacuated tube collectors
 427 m² net area on the roof
 Inclination angle
 STO, PAR 15° - LISB 25°
 Absorption chiller
 thermal COP rated : 0.695
 yearly mean value : 0.64-0.67

Simulation tool TRNSYS 16


Complete building modeling (type 56)
 Dynamic simulation for each case as well as for building load and appliances consumption.

For case 3, model of absorption chiller (type 107) has been updated.

Parameters definition based on real equipments.


Building layout

- Typical European office building (Case study IEA ECBCS 48)
- 1250m² / floor (81% is heated)
- 12 identical floors
- High internal loads
- North-South largely glazed
- U value = 0.80 W/(m².K)




Auxiliaries

72 kWh/(m² year) net energy
 180 kWh/(m² year) primary energy
 maximum 6% variation between locations



Results

Primary energy for heating and cooling (yearly basis)



Conclusions

Whatever the location, case 2 (PV panels) seems to be the most efficient case from a primary and net energy consumption point of view.

Auxiliaries consumption is a key field for energy savings.