

Projet REGAIN – Interreg IVB North West Europe Mise en place d'une méthodologie transnationale

État d'avancement n°1 du 19/05/09

La première partie de la mise en œuvre d'une méthodologie transnationale correspondait à l'établissement d'une méthodologie commune, pour la conception et la construction de bâtiments semi-industriels/semi-tertiaires environnementalement efficaces, et plus particulièrement efficaces du point de vue énergétique.

Chacun des partenaires du projet REGAIN imprime à son projet sa vision des objectifs du développement durable et de leur mise en œuvre dans son contexte propre. Ce contexte « local » est également exprimé sous la forme des valeurs cibles affectées aux critères d'évaluation de la qualité environnementale des projets, via l'outil d'évaluation commun « SB-Tool », proposé par l'équipe italienne et choisi par l'ensemble des partenaires du projet comme outil de référence.

Il existe actuellement une palette d'outils d'évaluation, parmi lesquels :

- VALIDEO : mis au point, en Belgique, par le Centre Scientifique et Technique de la Construction (CSTC) et le Bureau SECO, VALIDEO est en fin de phase de certification et pourra bientôt être appliqué, dans un premier temps, aux bâtiments tertiaires uniquement.




Figure 1 : Mode de cotation et critères d'évaluation de VALIDEO



Seize critères généraux d’évaluation ont été définis dans 4 domaines (Site et Construction, Gestion, Confort et Santé, Valeur sociale) : voir Figure 1 ci-dessus. Pour chaque critère, une cotation est établie, qui est de 0 point lorsque le prescrit légal correspondant est respecté, sans plus; ensuite de 1 à 5 points au fur et à mesure de l’accroissement de qualité du projet pour le critère concerné. La cote est négative (-1) si le projet ne rencontre pas le prescrit légal, par exemple un bâtiment existant qui ne respecte plus la législation ayant évolué. La somme des cotations obtenues conduit à un résultat global exprimé en nombre d’étoiles (1 à 5).

L’outil VALIDEO n’est encore applicable qu’aux seuls bâtiments tertiaires et demanderait une adaptation importante pour s’appliquer à un bâtiment mixte atelier-bureaux.

- BREAM (Building Research Establishment Environmental Assessment Method) : mis au point par le “CSTC anglais”, le Building Research Establishment, BREEAM comporte également plusieurs chapitres de critères couvrant les sujets de la qualité environnementale et affecte une cotation pour chacun de ces critères (Figure 2).




Figure 2 : Mode de cotation et critères d’évaluation de BREEAM

Pour être appliqué dans des contextes nationaux différents, BREEAM nécessiterait une adaptation particulière à chacun, comme cela est en cours par exemple pour les Pays-Bas qui souhaitent l’utiliser dans le cadre de la certification des bâtiments.

- LEED (Leadership in Energy and Environmental Design) : dans le contexte américain (USA), LEED est un label indépendant géré par l’US Green Building Council, qui poursuit l’objectif de transformer le secteur de la construction en l’amenant à mieux intégrer le bien-être de ses occupants, la performance environnementale et le rendement économique des bâtiments. D’expérience, il peut être établi que l’utilisation de LEED entraîne un surcoût de construction estimé à une moyenne d’environ 2 % du coût des travaux, mais engendre une amélioration de la productivité des travailleurs qui l’occupent : l’impact sur le coût salarial de cet accroissement de la productivité des usagers rentabilise très rapidement le surcoût de construction consenti. L’adaptation de LEED à un contexte européen serait plus importante encore que celle de BREEAM.

- HQE (Haute Qualité Environnementale) : français, cet outil d’évaluation regroupe les critères d’appréciation des bâtiments évalués en 14 cibles, elles-mêmes regroupées en 4 familles (éco-construction, éco-gestion, santé, confort) : voir Figure 3.




Figure 3 : Critères d’évaluation par HQE

Le label HQE ne comporte pas l’approche économique du projet qui reste pourtant un des trois piliers du développement durable (environnement, social et économie).

- MINERGIE : suisse, le label Minergie (tout comme le label PassivHausen Allemagne et en Autriche) est essentiellement axé sur l’énergie et n’approche les autres aspects de qualité environnementale que par le biais de son extension « Minergie-ECO ». Son adaptation aux projets REGAIN serait difficile.

L’équipe italienne partenaire du projet REGAIN a proposé un outil tout à fait complet et aisément adaptable à des contextes nationaux et régionaux : SB-Tool. Développé l’Université de Thessalonique dans le cadre d’un projet de recherche européen comprenant 25 pays participants, le « Sustainable Building – Tool » évalue les bâtiments suivant plus d’une centaine de critères regroupés en 7 familles, comprend également des aspects sociaux, économiques et culturels (voir Figure 4 ci-après) et permet d’affecter les poids souhaités à chacun des critères à l’intérieur de chaque famille et entre les familles de critères elles-mêmes.

Cette faculté d’adaptation de SB-Tool aux contextes locaux a favorisé le choix de SB-Tool par de nombreux organismes dans de nombreux pays dans le monde (Australie, Espagne, France, Japon, Chine, Corée, Taïwan, Norvège, Suède, Allemagne, Pays-Bas, Autriche, Finlande, Grèce, Canada, Etats-Unis, Grande Bretagne, Chili, Argentine...) et par les partenaires du projet REGAIN pour évaluer leurs projets de bâtiments.

Lors de la réunion plénière des partenaires du projet REGAIN qui s’est tenue à Glasgow, un certain nombre de ces critères d’appréciation ont été considérés comme ne s’appliquant pas aux projets de bâtiments mixtes et d’autres encore ne s’appliquent pas au contexte du site de Créalys sur lequel s’implantera le projet du BEP. Le poids relatif affecté à chaque critère et à chacune de leurs familles a été également décidé collégialement.

A Site Selection, Project Planning and Development

- A1 Site Selection
- A2 Project Planning
- A3 Urban Design and Site Development

B Energy and Resource Consumption

- B1 Total Life Cycle Non-Renewable Energy
- B2 Electrical peak demand for facility operations
- B3 Renewable Energy
- B4 Materials
- B5 Potable Water

C Environmental Loadings

- C1 Greenhouse Gas Emissions
- C2 Other Atmospheric Emissions
- C3 Solid Wastes
- C4 Rainwater, Stormwater and Wastewater
- C5 Impacts on Site
- C6 Other Local and Regional Impacts

D Indoor Environmental Quality

- D1 Indoor Air Quality
- D2 Ventilation
- D3 Air Temperature and Relative Humidity
- D4 Daylighting and Illumination
- D5 Noise and Acoustics

E Service Quality

- E1 Safety and Security During Operations
- E2 Functionality and efficiency
- E3 Controllability
- E4 Flexibility and Adaptability
- E5 Commissioning of facility systems
- E6 Maintenance of Operating Performance

F Social and Economic aspects

- F1 Social Aspects
- F2 Cost and Economics

G Cultural and Perceptual Aspects

- G1 Culture & Heritage
- G2 Perceptual

Figure 4 : Familles des critères d’évaluation par SB-Tool

L’adaptation au contexte belge, wallon et sur le site de Créalys est en cours de réalisation : l’Annexe comporte les critères retenus et les valeurs pivots de la cotation des critères particuliers, dont certaines restent encore à compléter.

L’équipe italienne a proposé récemment un étalonnage de l’énergie grise et des émissions de CO₂ consécutives à la production et à la mise en œuvre des matériaux de construction dans un projet de bâtiment mixte : cet étalonnage sera utilisé afin de déterminer ces deux paramètres du projet de Créalys.

La suite de la méthodologie comportera notamment :


- la continuation de l’adaptation des valeurs pivots des critères SB-Tool ;
- la relecture attentive du cahier des charges rédigé par l’équipe de projet, dans le souci d’obtenir la meilleure qualité environnementale possible pour le budget considéré ;
- l’élaboration de fiches techniques types qui permettront aux entreprises de proposer



et/ou de suggérer du matériel et/ou des matériaux particulièrement innovants ;

- la préparation d’une liste de personnes et organismes à tenir informés de l’avancement du projet et à inviter à des visites du futur chantier ;
- l’établissement d’un cahier de suivi retraçant le fil rouge du projet, depuis sa conception jusqu’à la réception définitive ;
- la préparation d’un mode d’évaluation du projet par les usagers eux-mêmes, en phase d’utilisation.

Ainsi fait à Liège, le 19/05/09,



Prof. J.-M. HAUGLUSTAINE.

Annexe : Liste des critères retenus par SB-Tool et adaptation, au contexte belge et au projet
BEP Créalys, des valeurs associées à l’échelle de cotation des critères.

Benchmarks A for designated occupancies in BigTown, Europe		Uses included	Small Industrial	
			Office	
			0	
New Construction	Design Phase		Generic	.
A Site Selection, Project Planning and Development				
A1 Site Selection				
A1.1 Pre-development ecological value or sensitivity of land.				
Intent	To encourage the selection of sites that have low ecological value or that are ecologically stable.		Applicable phases (Active if green)	
Indicator	Ecological value and / or sensitivity of land used for construction, as determined by a competent authority or by existing documentation.		P-Dsn.	Dsn.
Information sources	Reference x, y and z.			
Applicable project type	Any occupancy except renovation projects			
Assessment method	Review of site analysis report by an ecologist.			
Applicable Standards	a			
	b			
	c			
	d			
Information Submittals	e			
	f			
Total project	Total project			Score
Negative	The site currently supports a wide range of flora and fauna.			-1
Acceptable practice	The site currently supports a range of flora and fauna consistent with other sites in the area.			0
Good Practice	The site currently supports a range of flora and fauna that is less diverse than other sites in the area.			3
Best Practice	The site currently supports a very limited range of flora and fauna.			5
A1.2 Pre-development agricultural value of land.				rejected in Glasgow
Intent	To discourage the use of land with high agricultural value.		Applicable phases (Active if green)	
Indicator	Agricultural value of land used for construction, as determined by a competent authority or by existing documentation.		P-Dsn.	Dsn.
Information sources	Reference x, y and z.			
Applicable project type	Any occupancy except renovation projects.			
Assessment method	Review of site analysis report by an agronomist.			
Applicable Standards	a			
	b			
	c			
	d			
Information Submittals	e			
	f			
Total project	Total project			Score
Negative	Land used for the project is Class A (best grade) agricultural land.			-1
Acceptable practice	Land used for the project is Class B agricultural land.			0
Good Practice	Land used for the project is Class C (lowest grade) agricultural land.			3
Best Practice	Land used for the project has no agricultural value.			5

Benchmarks A for designated occupancies in BigTown, Europe		Uses included	Small Industrial	
			Office	
			0	
New Construction	Design Phase	Generic		
A1.3 Vulnerability of land to flooding.			rejected in Glasgow	
Intent	To discourage the selection of land for building where there is a substantial risk that the site may be flooded.		Applicable phases (Active if green)	
Indicator	Height above 100-year flood plain as defined in official documentation or assessment by competent authorities.	P-Dsn.	Dsn	Ops.
Information sources	Reference x, y and z.			
Applicable project type	Any occupancy except renovation projects			
Assessment method	Review of site analysis report.			
Applicable Standards	a			
	b			
	c			
	d			
Information Submittals	e			
	f			
Total project	Total project	m	Score	
Negative		1.0	-1	
Acceptable practice		1.3	0	
Good Practice	The height of the minimum elevation of the site above the elevation of the 100-year flood plain is :	2.0	3	
Best Practice		2.5	5	
A1.4 Potential for development to contaminate nearby bodies of water.			rejected in Glasgow	
Intent	To discourage the selection of land for building where the risk of polluting an adjacent water body is high.		Applicable phases (Active if green)	
Indicator	Distance of the building from water body or wetland as defined in official documentation or assessment by competent authorities.	P-Dsn.	Dsn	Ops.
Information sources	Reference x, y and z.			
Applicable project type	Any occupancy except renovation projects			
Assessment method	Review of site analysis report.			
Applicable Standards	a			
	b			
	c			
	d			
Information Submittals	e			
	f			
Total project	Total project	m	Score	
Negative		15	-1	
Acceptable practice		25	0	
Good Practice	The distance of the nearest body of water, including wetlands from the closest part of the site, is equal to or less than:	55	3	
Best Practice		75	5	

Benchmarks A for designated occupancies in BigTown, Europe			Uses included	Small Industrial			
				Office			
				0			
New Construction	Design Phase	Generic					
A1.5 Pre-development contamination status of land.				JMH proposes to reject it for the context of Crealys			
A1.5	Intent	To encourage the use of previously contaminated land for building.	Applicable phases (Active if green)				
	Indicator	Official documentation or assessment by competent authorities.	P-Dsn.	Dsn	Ops.		
	Information sources	Brownfield lands should be preferentially developed, since this will reduce pressures to use more valuable lands for development.					
	Applicable project type	Any occupancy except renovation projects					
	Assessment method	Review of site analysis report by a geophysical specialist.					
	Applicable Standards	a					
		b					
		c					
		d					
	Information Submittals	e					
		f					
	Total project	Total project			Score		
	Negative	The site is documented as having no sub-surface contamination.			-1		
	Acceptable practice	The site is documented as having no sub-surface contamination.			0		
	Good Practice	The site is documented as having moderate sub-surface contamination.			3		
	Best Practice	The site is documented as having major sub-surface contamination.			5		
A1.6 Proximity of site to public transportation.							
A1.6	Intent	To encourage the selection of sites that are within a short distance of a public transport stop.	Applicable phases (Active if green)				
	Indicator	Distance in m. to public transport stop from a main building entry or exit door.	P-Dsn.	Dsn	Ops.		
	Information sources	Reference x, y and z.					
	Applicable project type	Any occupancy, where public transport is available in the area.					
	Assessment method	Review of site plan and existing public transit routes.					
	Applicable Standards	a					
		b					
		c					
		d					
	Information Submittals	e					
		f					
	Total project	Total project	m	Score	Values proposed by JMH	instead of	Source
	Negative		700	-1	700	580	Survey
	Acceptable practice		300	0	300	500	Survey
	Good Practice	The distance of the project from a public transport stop is equal to or less than:	200	3	200	260	Survey
	Best Practice		100	5	100	100	Survey

Benchmarks A for designated occupancies in BigTown, Europe				Uses included	Small Industrial				
					Office				
					0				
New Construction	Design Phase			Generic		.			
A1.7 Distance between site and centres of employment or residential occupancies.									
Intent	To encourage the selection of sites that are within a reasonable distance of centers of employment.			Applicable phases (Active if green)					
Indicator	If Residential, distance to the nearest center of employment with at least 3 different firms or organizations hiring a minimum of 10 persons; if non-residential, distance to nearest major area of housing.			P-Dsn.	Dsn	Ops.			
Information sources	Reference x, y and z.								
Applicable project type	All occupancies except for Enclosed Parking or Open Space.								
Assessment method	Review of site plan by an outside planner.								
Applicable Standards	a								
	b								
	c								
	d								
Information Submittals	e								
	f								
Occupancy 1	Small Industrial			on	m	Score	Values proposed by JMH	instead of	Source
Negative					10 000	-1	10 000	5 800	Survey
Acceptable practice					6 000	0	6 000	5 000	Survey
Good Practice	The distance to nearest major area of affordable housing is equal to or less than:				2 000	3	2 000	2 600	Survey
Best Practice					1 000	5	1 000	1 000	Survey
Occupancy 2	Office			on	m	Score	Values proposed by JMH	instead of	Source
Negative					700	-1	700	0	Survey
Acceptable practice					300	0	300		Survey
Good Practice	The distance to nearest major area of affordable housing is equal to or less than:				200	3	200	0	Survey
Best Practice					100	5	100		Survey

Benchmarks B for designated occupancies in BigTown, Europe		Uses included	Small Industrial		
			Office		
			0		
New Construction	Design Phase	Generic	.		
B Energy and Resource Consumption					
B1 Total Life Cycle Non-Renewable Energy					
B1.1 Annualized non-renewable primary energy embodied in construction materials.					
Intent	To minimize the embodied primary energy used in the building, annualized over the estimated lifespan of the building.		Applicable phases (Active if green)		
Indicator	Estimate of embodied primary energy used for structure, envelope (excl. glazing), and major interior components, as determined by a program designed to estimate embodied energy and emissions through Life Cycle Analysis; also, estimate of lifespan.		Dsn	Ops.	
Information sources	Note that minimization of embodied energy may not always be optimal. For example, the greater embodied energy associated with high thermal mass will, in most cases, reduce operating energy, and the total net lifecycle energy could then be reduced.				
Applicable project type	All occupancies		Assumed lifespan in years	50	
Assessment method	Use an embodied energy estimating system, based on LCA (Life Cycle Assessment). Alternatively, use the crude estimating method provided in this system.				
Applicable Standards	a				
	b				
	c				
	d				
Information Submittals	e				
	f				
Occupancy 1	Small Industrial	GJ/m2	MJ/m2 per yr.	Score	Data to be received from Italian team
Negative		8.6	172	-1	
Acceptable practice	The predicted embodied energy for materials used in the structure and building envelope, as determined an acceptable LCA-based estimating method :	8.0	160	0	
Good Practice		6.2	124	3	
Best Practice		5.0	100	5	
Occupancy 2	Office	GJ/m2	MJ/m2 per yr.	Score	Data to be received from Italian team
Negative		12.6	252	-1	
Acceptable practice	The predicted embodied energy for materials used in the structure and building envelope, as determined an acceptable LCA-based estimating method :	12.0	240	0	
Good Practice		10.2	204	3	
Best Practice		9.0	180	5	

Benchmarks B for designated occupancies in BigTown, Europe				Uses included	Small Industrial
				Office	
				0	
New Construction	Design Phase			Generic	.
B1.2 Annual non-renewable primary energy used for facility heating					
Intent	To minimize the amount of non-renewable energy (not including on-site renewable energy) used annually for building operations, commensurate with functional needs.			Applicable phases (Active if green)	
	Indicator	MJ of delivered energy per m2 of net area, including fuel and electrical use, as predicted by means of an acceptable method or tool.		Dsn	Ops.
Information sources	See IEA.org for data and case studies.				
Applicable project type	Any occupancy except for Open Space				M
Assessment method	During early design stages a screening tool may be used, but in later stages an hour-by-hour simulation program should be used. Benchmarks for Ops should be derived from operational data for the relevant occupancy types, after a period of occupancy of at least one year. Note that benchmarks should be set using Delivered energy data, since this is what is commonly available. SBTool applies a conversion factor to these values to convert them to primary energy for the Results.				
Applicable Standards	a				
	b				
	c				
	d				
Information Submittals	e				
	f				
Occupancy 1	Small Industrial	Elec. MJ/m2 per yr	Total MJ/m2 per yr	Score	Values proposed by JMH instead of Source
Negative		540	1460	-1	1 460
Acceptable practice	MJ of delivered non-renewable energy per m2 of net area used for operations, as predicted by means of an acceptable method or tool.	500	1300	0	1 300
Good Practice		380	820	3	820
Best Practice		300	500	5	144 MJ/m2 500 IBGE 40 kWh/m2 = 144 MJ/m2
Occupancy 2	Office	Elec. MJ/m2 per yr	MJ/m2 per yr.	Score	Values proposed by JMH instead of Source
Negative		320	375	-1	375
Acceptable practice	MJ of delivered non-renewable energy per m2 of net area used for operations, as predicted by means of an acceptable method or tool.	300	350	0	350
Good Practice		240	275	3	275
Best Practice		200	225	5	54 MJ/m2 225 IBGE 15 kWh/m2 = 54 MJ/m2
B1.3 Annual non-renewable primary energy used for facility cooling					
Intent	To minimize the amount of non-renewable energy (not including on-site renewable energy) used annually for building operations, commensurate with functional needs.			Applicable phases (Active if green)	
	Indicator	MJ of delivered energy per m2 of net area, including fuel and electrical use, as predicted by means of an acceptable method or tool.		Dsn	Ops.
Information sources	See IEA.org for data and case studies.				
Applicable project type	Any occupancy except for Open Space				
Assessment method	During early design stages a screening tool may be used, but in later stages an hour-by-hour simulation program should be used. Benchmarks for Ops should be derived from operational data for the relevant occupancy types, after a period of occupancy of at least one year. Note that benchmarks should be set using Delivered energy data, since this is what is commonly available. SBTool applies a conversion factor to these values to convert them to primary energy for the Results.				
Applicable Standards	a				
	b	Revise text			
	c				
	d				
Information Submittals	e				
	f				
Occupancy 1	Small Industrial	Elec. MJ/m2 per yr	Total MJ/m2 per yr	Score	Values proposed by JMH instead of Source
Negative		540	1460	-1	1 460
Acceptable practice	MJ of delivered non-renewable energy per m2 of net area used for operations, as predicted by means of an acceptable method or tool.	500	1300	0	1 300
Good Practice		380	820	3	820
Best Practice		300	500	5	152 MJ:m2 500 IBGE 45 kWh/m2 = 152 MJ/m2
Occupancy 2	Office	Elec. MJ/m2 per yr	MJ/m2 per yr.	Score	Values proposed by JMH instead of Source
Negative		320	375	-1	375
Acceptable practice	MJ of delivered non-renewable energy per m2 of net area used for operations, as predicted by means of an acceptable method or tool.	300	350	0	350
Good Practice		240	275	3	275
Best Practice		200	225	5	152 MJ:m2 225 IBGE 45 kWh/m2 = 152 MJ/m2

Benchmarks B for designated occupancies in BigTown, Europe				Uses included	Small Industrial			
				Office				
				0				
New Construction	Design Phase			Generic	.			
B1.4 Annual non-renewable primary energy used for lighting and equipment								
Intent	To minimize the amount of non-renewable energy (not including on-site renewable energy) used annually for building operations, commensurate with functional needs.			Applicable phases (Active if green)				
	Indicator	MJ of delivered energy per m2 of net area, including fuel and electrical use, as predicted by means of an acceptable method or tool.				Dsn	Ops.	
Information sources		See IEA.org for data and case studies.			●	●	●	
Applicable project type	Any occupancy except for Open Space					M		
Assessment method	During early design stages a screening tool may be used, but in later stages an hour-by-hour simulation program should be used. Benchmarks for Ops should be derived from operational data for the relevant occupancy types, after a period of occupancy of at least one year. Note that benchmarks should be set using Delivered energy data, since this is what is commonly available. SBTool applies a conversion factor to these values to convert them to primary energy for the Results.							
Applicable Standards	a							
	b	Revise text						
	c							
	d							
Information Submittals	e							
	f							
Occupancy 1	Small Industrial		Elec. MJ/m2 per yr	Total MJ/m2 per yr	Score	Values proposed by JMH	instead of	Source
Negative			540	1460	-1		1 460	
Acceptable practice	MJ of delivered non-renewable energy per m2 of net area used for operations, as predicted by means of an acceptable method or tool.		500	1300	0		1 300	
Good Practice			380	820	3		820	
Best Practice			300	500	5		500	IBGE 2 W/m2*1600h/an*3.6/1000=11.5 MJ/m2
Occupancy 2	Office		Elec. MJ/m2 per yr	MJ/m2 per yr.	Score	Values proposed by JMH	instead of	Source
Negative			320	375	-1		375	
Acceptable practice	MJ of delivered non-renewable energy per m2 of net area used for operations, as predicted by means of an acceptable method or tool.		300	350	0		350	
Good Practice			240	275	3		275	
Best Practice			200	225	5		225	IBGE 2 W/m2*1600h/an*3.6/1000=11.5 MJ/m2
B2 Electrical peak demand for facility operations				●	●			
Intent	To minimize the peak monthly electrical demand for building operations, especially where the grid is near peak capacity.			Applicable phases (Active if green)				
	Indicator	Average of peak monthly electrical demand for one year, W/m2, as predicted by means of an acceptable method or tool.				Dsn	Ops.	
Information sources		References x, y and z						
Applicable project type	Any occupancy except open space							
Assessment method	Review of contract documentation and sample equipment specifications by an outside electrical engineer.							
Applicable Standards	a							
	b							
	c							
	d							
Information Submittals	e							
	f							
Occupancy 1	Small Industrial	on	W/m2	Score	Values proposed by JMH	instead of	Source	
Negative			6	-1	6	6	o.k. with proposal	
Acceptable practice	The peak monthly electrical demand for the occupancy, as predicted by means of an acceptable method or tool.		5	0	5	5	o.k. with proposal	
Good Practice			3	3	3	3	o.k. with proposal	
Best Practice			2	5	2	2	o.k. with proposal	
Occupancy 2	Office	on	W/m2	Score	Values proposed by JMH	instead of	Source	
Negative			0	-1		0	BEP : ?	
Acceptable practice	The peak monthly electrical demand for the occupancy, as predicted by means of an acceptable method or tool.			0			BEP : ?	
Good Practice			0	3		0	BEP : ?	
Best Practice				5			BEP : ?	

Benchmarks B for designated occupancies in BigTown, Europe				Uses included	Small Industrial	
				Office		
				0		
New Construction	Design Phase			Generic		
B3 Renewable Energy				●	●	
B3.1 Use of off-site energy that is generated from renewable sources.						
Intent	To encourage the use of sources that generate power by renewable energy means, e.g. 'green power'.			Applicable phases (Active if green)		
Indicator	Percent of annual purchased electricity consumption for the Total Building that is planned to be obtained from sources that generate power by means of renewable energy.			Dsn	Ops.	
Information sources	NABERS (Australian system) defines Acceptable Practice as 20% and Best Practice as 100%, whereas HK-BEAM equivalents are 4% and 20% and BREEAM specifies a threshold of 10%.			Available from grid, per Emission worksheet	0.0%	
Applicable project type	Any occupancy where renewable sources are available.					
Assessment method	Review of contract documentation and sample equipment specifications by an outside electrical engineer.					
Applicable Standards	a					
	b					
	c					
	d					
Information Submittals	e					
	f					
Total project	Total project			Percent	Score	Values proposed by JMH instead of Source
Negative				0%	-1	0% 0% o.k. with proposal
Acceptable practice	The percent of annual purchased electricity consumption planned to be obtained from sources that generate power by means of renewable energy :			0%	0	0% 0% o.k. with proposal
Good Practice				30%	3	30% 30% o.k. with proposal
Best Practice				50%	5	50% 50% o.k. with proposal
B3.2 Provision of on-site renewable energy systems.						
Intent	To encourage the use of on-site renewable energy systems.			Applicable phases (Active if green)		
Indicator	The amount of energy intended to be contributed by renewable energy systems, in MJ/m2 per year, not including daylighting or Ground Source Heat Pumps (GSHP).			Dsn	Ops.	
Information sources	We suggest a higher level for Residential and Schools than for Office, because of possibility of using renewable sources for pre-heating Hot Water. E-Benchmark suggests a minimum of 10% and LEED ranges from 5% to 20%.			●	●	
Applicable project type	Any occupancy except Enclosed Parking and Open Space.					
Assessment method	Review of contract documentation and sample equipment specifications by an outside electrical engineer with renewables expertise.					
Applicable Standards	a					
	b					
	c					
	d					
Information Submittals	e					
	f					
Occupancy 1	Total project	M	MJ/m2 per yr.	Score	Values proposed by JMH	instead of Source
Negative				40	-1	40 40 o.k. with proposal
Acceptable practice	The predicted annual contribution of on-site renewable energy planned for operations, as per drawings and specifications :			50	0	50 50 o.k. with proposal
Good Practice				80	3	80 80 o.k. with proposal
Best Practice				100	5	100 100 o.k. with proposal

Benchmarks B for designated occupancies in BigTown, Europe			Uses included	Small Industrial	
				Office	
				0	
New Construction	Design Phase	Generic			
B4 Materials			●	●	
B4.1 Re-use of suitable existing structure(s).					
Intent	To encourage the re-use of any sound structures that exist on the site, as part of the new project.		Applicable phases (Active if green)		
Indicator	The development of an inventory and the percent, by area, of an existing structure that is re-used or recycled, where the structures are in usable condition.		Dsn	C&C.	Ops.
Information sources	0				
Applicable project type	Any occupancy, where an existing structure in usable condition is located on the site.				
#REF!	If there is an existing structure on the site, the basis of assessment should be a report that provides a structural, functional and economic assessment of the existing structure, carried out by a team of qualified professionals.				
Applicable Standards	a				
	b				
	c				
	d				
Information Submittals	e				
	f				
Total project	Total project	Percent by area	Score	Not applicable in the context of Cralys	
Negative		13%	-1		
Acceptable practice	The percentage (by area) of existing sound structures that is planned to be re-used as part of the project :	25%	0		
Good Practice		61%	3		
Best Practice		85%	5		
B4.2 Use of recycled materials from off-site sources.					
Intent	To encourage the use of recycled materials from off-site sources as part of the new facility, where they are suitable.		Applicable phases (Active if green)		
Indicator	The percentage, by cost, of the materials, products, and furnishings in the project are recycled from off-site sources.		Dsn	C&C.	Ops.
Information sources	LEED ranges from 25% to 50%.				
Applicable project type	Total building.				
#REF!	Review of contract documentation by an outside materials specialist.				
Applicable Standards	a				
	b				
	c				
	d				
Information Submittals	e				
	f				
Total project	Total Project	% by cost	Score	Data to be received from Italian team	
Negative		7%	-1		
Acceptable practice	The percentage (by cost) of the materials, products, and furnishings in the project that are made from materials that recycled from off-site post-consumer sources :	10%	0		
Good Practice		19%	3		
Best Practice		25%	5		

Benchmarks B for designated occupancies in BigTown, Europe			Uses included	Small Industrial	
				Office	
				0	
New Construction	Design Phase	Generic			
B4.3 Use of bio-based products obtained from sustainable sources.					
Intent	To encourage the use of bio-based products that are certified by a recognized certification agency as coming from renewable sources, or the equivalent.		Applicable phases (Active if green)		
Indicator	The percentage, by cost, of bio-based products used in the building, including wood and agricultural products, that are certified by a recognized certification agency.		Dsn	C&C.	Ops.
Information sources	0				
Applicable project type	Total building, all sizes.				
Assessment method	Review of contract documentation by an outside materials specialist.				
Applicable Standards	a				
	b				
	c				
	d				
Information Submittals	e				
	f				
Total project	Total Project	Percent by cost	Score	Data to be received from Italian team	
Negative		9%	-1		
Acceptable practice	The percentage (by cost) of the wood-based products in the building certified by a recognized certification agency as coming from renewable sources :	10%	0		
Good Practice		13%	3		
Best Practice		15%	5		
B4.4 Use of cement supplementing materials in concrete.					
Intent	To encourage the use of cement supplementing materials in concrete, such as flyash, steel slag or rice ash, in order to reduce GHG emissions from the use of cement.		Applicable phases (Active if green)		
Indicator	The percentage, by volume, of cement substitute used in concrete.		Dsn	C&C.	Ops.
Information sources	Note that up to 50% of CSM has been used, but curing time increases with volume used. Typical industry utilisation ranges from 15% to 25%.				
Applicable project type	0				
Assessment method	Review of contract documentation by an outside concrete specialist.				
Applicable Standards	a				
	b				
	c				
	d				
Information Submittals	e				
	f				
Total project	Total Project	% by vol.	Score	Values proposed by JMH	instead of Source
Negative		2%	-1	0%	2%
Acceptable practice	The percentage, by volume, of an acceptable cement supplementing material used in concrete :	10%	0	0%	10%
Good Practice		34%	3	10%	34%
Best Practice		50%	5	25%	50%

Benchmarks B for designated occupancies in BigTown, Europe				Uses included	Small Industrial		
					Office		
					0		
New Construction	Design Phase			Generic			
B4.5 Use of materials that are locally produced.							
	Intent	To encourage the procurement of high-weight materials such as aggregate, sand, concrete, masonry, steel and glass, from sources within the greater urban region.			Applicable phases (Active if green)		
	Indicator	The percentage, by weight, of the aggregate, sand, concrete, masonry, steel and glass used in the project produced within the greater urban region, if local sources of acceptable quality are available.			Dsn	C&C. Ops.	
	Information sources	LEED specifies specific distances, but we consider that this is not applicable to all areas.					
	Applicable project type	Total building, all sizes.					
	Assessment method	Review of contract documentation by an outside materials specialist.					
	Applicable Standards	a					
		b					
		c					
		d					
	Information Submittals	e					
		f					
	Total project	Total Project			% by weight	Score	Values proposed by JMH instead of Source
	Negative				42%	-1	42%
	Acceptable practice	The percentage, by weight, of the aggregate, sand, concrete, masonry, steel and glass used in the project produced within the greater urban region :			50%	0	50% No law constraint
	Good Practice				74%	3	74%
Best Practice				90%	5	90%	
B4.6 Design for disassembly, re-use or recycling.							
	Intent	To encourage a building design that will facilitate the easy dis-assembly of components so that they can be re-used or recycled at the end of the service life of the components.			Applicable phases (Active if green)		
	Indicator	Measures taken to facilitate future disassembly and re-use or recycling.			Dsn	C&C. Ops.	
	Information sources	0					
	Applicable project type	Total building					
	Assessment method	Review of contract documentation by an outside deconstruction specialist.					
	Applicable Standards	a					
		b					
		c					
		d					
	Information Submittals	e					
		f					
	Total project	Total Project			Score		
	Negative	No measures have been taken to facilitate future disassembly, re-use or recycling.			-1		
	Acceptable practice	Limited measures have been taken to facilitate future disassembly, re-use or recycling, such as the use of modular interior partitions and other interior components.			0		
	Good Practice	Measures have been taken to facilitate future disassembly, re-use or recycling, such as the use of modular interior components and the use of bolted structural or building envelope components.			3		
Best Practice	Extensive measures have been taken to facilitate future disassembly, re-use or recycling, such as the use of modular interior components, the use of bolted structural or building envelope components, and the non-use of composite or bonded materials.			5			

Benchmarks B for designated occupancies in BigTown, Europe				Uses included	Small Industrial				
					Office				
					0				
New Construction	Design Phase			Generic		.			
B5 Potable Water				●	●				
B5.1 Use of potable water for site irrigation.									
Intent	To discourage the use of potable water for irrigation; and to ensure that any potable water used for irrigation purposes during dry seasons is minimal.			Applicable phases (Active if green)					
	Indicator	The development of a credible irrigation management plan for areas landscaped with non native species (excluding stored rainwater or greywater used for this purpose).		Dsn	C&C.	Ops.			
Information sources	0								
Applicable project type	Total project								
Assessment method	Review pf landscaping plans by an outside landscape architect.								
Applicable Standards	a								
	b								
	c								
	d								
Information Submittals	e								
	f								
Total project	Total Project			M ³ / m ²	Score	Values proposed by JMH	instead of	Source	
Negative				4.8	-1	5%	4.8	o.k. with proposal	
Acceptable practice	The predicted net annual potable water volume used for irrigation of areas landscaped with non-native species (excluding stored rainwater or greywater used for this purpose) :			4.0	0	4%	4.0	o.k. with proposal	
Good Practice				1.6	3	2%	1.6	o.k. with proposal	
Best Practice				0.0	5	0%	0.0	o.k. with proposal	
B5.2 Use of potable water for building and occupancy needs.									
Intent	To minimize the amount of potable water imported to the site and used for occupancy needs, excluding building system uses or irrigation of exterior areas.			Applicable phases (Active if green)					
	Indicator	Prediction of total potable water use, in L per person per day, based on a credible water management plan for occupancy fixtures and use. Note that the benchmarks are expressed as L / m2 per year in order to allow uses such as indoor parking to be compared to other uses such as office or residential.		Dsn	C&C.	Ops.			
Information sources	See File C for fixtures and water consumption data for the specific project.			●					
Applicable project type	By separate occupancies, excluding irrigation water for outdoor areas.								
Assessment method	Review of contract documentation by a specialist in water use.								
Applicable Standards	a								
	b								
	c								
	d								
Information Submittals	e								
	f								
Occupancy 1	Small Industrial			on	L / m2 per year	Score	Values proposed by JMH	instead of	Source
Negative					1600	-1		1 600	BEP : ?
Acceptable practice	Based on a credible water management plan, the volume of potable water predicted to be used for occupancy needs :				1500	0		1 500	BEP : ?
Good Practice					1200	3		1 200	BEP : ?
Best Practice					1000	5		1 000	BEP : ?
Occupancy 2	Office			on	L / m2 per year	Score	Values proposed by JMH	instead of	Source
Negative					215	-1		215	BEP : ?
Acceptable practice	Based on a credible water management plan, the volume of potable water predicted to be used for occupancy needs :				200	0		200	BEP : ?
Good Practice					155	3		155	BEP : ?
Best Practice					125	5		125	BEP : ?

Benchmarks C for designated occupancies in BigTown, Europe			Uses included	Small Industrial	
				Office	
				0	
New Construction	Design Phase		Generic		.
C Environmental Loadings					<div></div>
C1 Greenhouse Gas Emissions				<div></div>	<div></div>
C1.1 Annualized GHG emissions embodied in construction materials.					
Intent	To minimize the amount of CO2-equivalent emissions from primary non-renewable energy used in the extraction, fabrication and transportation of materials and components in the building.		Applicable phases (Active if green)		
	Indicator	CO2-equivalent emissions per Kg. per m2 of gross area, as determined by calculations based on design documents and fuel emission values plus process-related emissions related to the region of production, and annualized according to the predicted lifespan of the building.	Dsn		Ops.
Information sources		Benchmarks for GJ/m2 are the same as those selected for Benchmark B1.1. Values in BREEAM range from about 1000 to 300 kgCO2/m2 for Residential, and 100 to 500 kgCO2/m2f or offices (not annualized).	Assumed lifespan in years, from Basic worksheet	50	
Applicable project type	All occupancies	kg eCO2 per embodied GJ	55		
Assessment method	We recommend that this analysis be carried out only with new projects, since there are likely to be insurmountable difficulties in obtaining emission data for materials that are located in an existing building.				
Applicable Standards	a				
	b				
	c				
	d				
Information Submittals	e				
	f				
Occupancy 1	Small Industrial	GJ/m2	kg/m2 * year	Score	Data to be received from Italian team
Negative		8.6	9.5	-1	
Acceptable practice	The annualized amount of CO2-equivalent emissions from primary non-renewable energy used in materials and components for structure and building envelope, based on design documents :	8.0	8.8	0	
Good Practice		6.2	6.8	3	
Best Practice		5.0	5.5	5	
Occupancy 2	Office	GJ/m2	kg/m2 * year	Score	Data to be received from Italian team
Negative		12.6	13.9	-1	
Acceptable practice	The annualized amount of CO2-equivalent emissions from primary non-renewable energy used in materials and components for structure and building envelope, based on design documents :	12.0	13.2	0	
Good Practice		10.2	11.2	3	
Best Practice		9.0	9.9	5	

Benchmarks C for designated occupancies in BigTown, Europe				Uses included	Small Industrial				
					Office				
					0				
New Construction	Design Phase			Generic	.				
C1.2 Annual GHG emissions from all energy used for facility heating.									
Intent	To minimize the amount of CO2-equivalent emissions from all energy used for annual building operations.			Applicable phases (Active if green)					
	Indicator	Annual CO2-equivalent emissions per Kg. per m2 of net area, as determined by an hour-by-hour simulation program and calculations based on regional fuel emission values.			Dsn		Ops.		
Information sources		Values in the UK BREEAM system range from 167 to 30 kgCO2/m2 for Residential, 250 to 20 kgCO2/m2 for Office and about 48 to 17 kgCO2/m2 for Schools.							
	Emissions for Residential taken from average Canadian building stock values for 1999 (NRCan data).			Est. kg CO2 per GJ, Small Industrial	55.0				
	Emissions for Commercial taken from average Canadian building stock values for 1999 (NRCan data).			Est. kg CO2 per GJ, Office	55.0				
	0			Est. kg CO2 per GJ, 0	55.0				
	Applicable project type			All occupancies except open space					
	Assessment method			Values below are based on B1.2 in BmkB					
Applicable Standards	The use of an hour-by-hour simulation tool, as required for B1.2, will produce annual energy consumption results. These data are combined by SBTool with emission data (see Emissions worksheet) to produce estimates of operating emissions.								
	a								
	b								
	c								
Information Submittals	d								
	e								
	f								
Occupancy 1	Small Industrial			M	kg/m2 per yr.	Score	Values proposed by JMH	instead of	Source
Negative					80	-1		80	
Acceptable practice	Based on the results of an hour-by-hour simulation program and regional fuel emission values, the amount of CO2-equivalent emissions from primary non-renewable energy used for annual operations of the occupancy is predicted to be :				72	0		72	
Good Practice					45	3		45	
Best Practice					28	5		28	
Occupancy 2	Office			M	kg/m2 per yr.	Score	Values proposed by JMH	instead of	Source
Negative					21	-1		21	
Acceptable practice	Based on the results of an hour-by-hour simulation program and regional fuel emission values, the amount of CO2-equivalent emissions from primary non-renewable energy used for annual operations of the occupancy is predicted to be :				19	0		19	
Good Practice					15	3		15	
Best Practice					12	5		12	

Benchmarks C for designated occupancies in BigTown, Europe				Uses included	Small Industrial				
					Office				
					0				
New Construction	Design Phase			Generic	.				
C1.3 Annual GHG emissions from all energy used for facility cooling.									
Intent	To minimize the amount of CO2-equivalent emissions from all energy used for annual building operations.			Applicable phases (Active if green)					
	Indicator	Annual CO2-equivalent emissions per Kg. per m2 of net area, as determined by an hour-by-hour simulation program and calculations based on regional fuel emission values.			Dsn		Ops.		
Information sources		Values in the UK BREEAM system range from 167 to 30 kgCO2/m2 for Residential, 250 to 20 kgCO2/m2 for Office and about 48 to 17 kgCO2/m2 for Schools.							
	Emissions for Residential taken from average Canadian building stock values for 1999 (NRCan data).			Est. kg CO2 per GJ, Small Industrial	55.0				
	Emissions for Commercial taken from average Canadian building stock values for 1999 (NRCan data).			Est. kg CO2 per GJ, kg/m2 per yr.	55.0				
	0			Est. kg CO2 per GJ, 0	55.0				
	Applicable project type			All occupancies except open space					
Assessment method	The use of an hour-by-hour simulation tool, as required for B1.2, will produce annual energy consumption results. These data are combined by SBTool with emission data (see Emissions worksheet) to produce estimates of operating emissions.			Values below are based on B1.2 in BmkB					
Applicable Standards	a								
	b								
	c								
	d								
Information Submittals	e								
	f								
Occupancy 1	Small Industrial			M	kg/m2 per yr.	Score	Values proposed by JMH	instead of	Source
Negative					80	-1		80	
Acceptable practice	Based on the results of an hour-by-hour simulation program and regional fuel emission values, the amount of CO2-equivalent emissions from primary non-renewable energy used for annual operations of the occupancy is predicted to be :				72	0		72	
Good Practice					45	3		45	
Best Practice					28	5		28	
Occupancy 2	Office			M	kg/m2 per yr.	Score	Values proposed by JMH	instead of	Source
Negative					21	-1		21	
Acceptable practice	Based on the results of an hour-by-hour simulation program and regional fuel emission values, the amount of CO2-equivalent emissions from primary non-renewable energy used for annual operations of the occupancy is predicted to be :				19	0		19	
Good Practice					15	3		15	
Best Practice					12	5		12	

Benchmarks C for designated occupancies in BigTown, Europe				Uses included	Small Industrial				
					Office				
					0				
New Construction	Design Phase			Generic	.				
C1.4 Annual GHG emissions from all energy used for lighting and equipment.									
Intention	To minimize the amount of CO2-equivalent emissions from all energy used for annual building operations.			Applicable phases (Active if green)					
	Indicator	Annual CO2-equivalent emissions per Kg. per m2 of net area, as determined by an hour-by-hour simulation program and calculations based on regional fuel emission values.			Dsn		Ops.		
Information sources		Values in the UK BREEAM system range from 167 to 30 kgCO2/m2 for Residential, 250 to 20 kgCO2/m2 for Office and about 48 to 17 kgCO2/m2 for Schools.							
	Emissions for Residential taken from average Canadian building stock values for 1999 (NRCan data).			Est. kg CO2 per GJ, Small Industrial	55.0				
	Emissions for Commercial taken from average Canadian building stock values for 1999 (NRCan data).			Est. kg CO2 per GJ, kg/m2 per yr.	55.0				
	0			Est. kg CO2 per GJ, 20.625	55.0				
Applicable project type	All occupancies except open space			Values below are based on B1.2 in BmkB					
Assessment method	The use of an hour-by-hour simulation tool, as required for B1.2, will produce annual energy consumption results. These data are combined by SBTool with emission data (see Emissions worksheet) to produce estimates of operating emissions.								
Applicable Standards	a	Text to be revised							
	b								
	c								
	d								
Information Submittals	e								
	f								
Occupancy 1	Small Industrial			M	kg/m2 per yr.	Score	Values proposed by JMH	instead of	Source
Negative					80	-1		80	
Acceptable practice	Based on the results of an hour-by-hour simulation program and regional fuel emission values, the amount of CO2-equivalent emissions from primary non-renewable energy used for annual operations of the occupancy is predicted to be :				72	0		72	
Good Practice					45	3		45	
Best Practice					28	5		28	
Occupancy 2	Office			M	kg/m2 per yr.	Score	Values proposed by JMH	instead of	Source
Negative					21	-1		21	
Acceptable practice	Based on the results of an hour-by-hour simulation program and regional fuel emission values, the amount of CO2-equivalent emissions from primary non-renewable energy used for annual operations of the occupancy is predicted to be :				19	0		19	
Good Practice					15	3		15	
Best Practice					12	5		12	

Benchmarks C for designated occupancies in BigTown, Europe				Uses included	Small Industrial	
					Office	
					0	
New Construction	Design Phase			Generic		
C2 Other Atmospheric Emissions						
C2.1 Emissions of acidifying emissions during facility operations.						
Intent	To minimize the production of atmospheric emissions from building operations that may result in acidification.			Applicable phases (Active if green)		SO2 (not emitted anymore) replaced by NOx
Indicator	SO2 Equiv. per year in kg. per unit net area			Dsn	Ops.	
Information sources	References x, y and z				M	
Applicable project type	Total project					
#REF	Review of contract documents and equipment specifications.					
Applicable Standards	a					
	b					
	c					
	d					
Information Submittals	e					
	f					
Total project	Total Project			Kg. / m2 per yr.	Score	Values proposed by JMH
Negative				0.45	-1	instead of
Acceptable practice	The predicted emission of SO2 equivalent per year in kg. per unit area net, based on the results of an acceptable hour-by-hour simulation program and taking into account the characteristics of available fuels :			0.40	0	Source
Good Practice				0.25	3	
Best Practice				0.15	5	
C2.2 Emissions leading to photo-oxidants during facility operations.						
Intent	To minimize the production of atmospheric emissions from building operations that may result in photo-oxidants.			Applicable phases (Active if green)		
Indicator	Ethene equiv. per year in gm per net unit area			Dsn	Ops.	
Information sources	References x, y and z					
Applicable project type	Total project					
Assessment method	Review of contract documents and equipment specifications.					
Applicable Standards	a					
	b					
	c					
	d					
Information Submittals	e					
	f					
Total project	Total Project			gm./m2 per yr.	Score	Values proposed by JMH
Negative				0.278	-1	instead of
Acceptable practice	The predicted emission of Ethene equivalent per year in gm. per net unit area, based on the results of an acceptable hour-by-hour simulation program, and taking into account the characteristics of available fuels :			0.250	0	Source
Good Practice				0.166	3	
Best Practice				0.110	5	

Benchmarks C for designated occupancies in BigTown, Europe				Uses included	Small Industrial				
					Office				
					0				
New Construction	Design Phase			Generic					
C3 Solid Wastes									
C3.1 Solid waste resulting from the construction and demolition process.									
Intent	To minimize the amount of waste off the site by encouraging the development and implementation of a construction waste management program, with sorting, re-use and recycling measures.			Applicable phases (Active if green)					
Indicator	The development of a credible construction waste management plan and the percentage, by weight, of construction waste to be re-used (on or off the site) or re-cycled, as predicted in the plan.			Dsn	C&C.	Ops.			
Information sources	It is assumed that a construction waste management plan is developed, and construction waste is sorted, with specific amounts recorded.								
Applicable project type	Total Project								
Assessment method	Review of construction management plan by an outside party with construction and solid waste management expertise.								
Applicable Standards	a								
	b								
	c								
	d								
Information Submittals	e								
	f								
Total project	Total Project			Percent	Score	Values proposed by JMH	instead of	Source	
Negative				-7%	-1		-7%		
Acceptable practice	The percentage, by weight, of construction waste to be re-used (on or off the site) or re-cycled, as predicted in the construction waste management plan :			10%	0		10%		
Good Practice				61%	3		61%		
Best Practice				95%	5		95%		
C3.2 Solid waste resulting from facility operations.									
Intent	To encourage the provision of facilities for storage of waste on each floor or each major work area, and space for the central sorting and storage of waste, with access to a truck loading area.			Applicable phases (Active if green)					
Indicator	Facilities provided in the design for the storage and sorting of solid wastes in both dispersed and central locations.			Dsn		Ops.			
Information sources	We specify storage areas per dwelling and per work group, and assume that the central storage area will be sized to suit.								
Applicable project type	Separate criteria for residential and non-residential; NA for parking or open space								
Assessment method	Review of construction documents by an outside party with solid waste management expertise.								
Applicable Standards	a								
	b								
	c								
	d								
Information Submittals	e								
	f								
Occupancy 1	Small Industrial			on	percent	Score	Values proposed by JMH	instead of	Source
Negative					70%	-1		70%	
Acceptable practice	A central sorting and storage area is located close to a truck loading area, and storage has been provided sufficient for all wastes that may accumulate over a period of one week. It is estimated that the percentage of total waste that can be sorted and				75%	0		75%	
Good Practice					89%	3		89%	
Best Practice					98%	5		98%	
Occupancy 2	Office			on	percent	Score	Values proposed by JMH	instead of	Source
Negative					70%	-1		70%	
Acceptable practice	A central sorting and storage area is located close to a truck loading area, and storage has been provided sufficient for all wastes that may accumulate over a period of one week. It is estimated that the percentage of total waste that can be sorted and				75%	0		75%	
Good Practice					90%	3		90%	
Best Practice					100%	5		100%	

Benchmarks C for designated occupancies in BigTown, Europe		Uses included	Small Industrial	
			Office	
			0	
New Construction	Design Phase	Generic	.	

Benchmarks C for designated occupancies in BigTown, Europe				Uses included		
				Small Industrial		
				Office		
				0		
New Construction	Design Phase			Generic	.	
C4 Rainwater, Stormwater and Wastewater				●	●	
C4.1 Liquid effluents from facility operations sent off the site.						
Intent	To minimize the volume of waste water, including effluent, sent off the site to be treated.			Applicable phases (Active if green)		
Indicator	The volume of liquid waste per person per day that is sent off the site for treatment.			Dsn	Ops.	
Information sources	The default (0) volume is assumed to be 95% of the potable water consumption with no on-site treatment, as per BmkA 5.2 (see cells at right)			1425	190	
Applicable project type	By separate occupancies.					
Assessment method	Review of contract documents.					
Applicable Standards	a					
	b					
	c					
	d					
Information Submittals	e					
	f					
Occupancy 1	Small Industrial	on	L / m2 * yr.	Score	Values proposed by JMH	
Negative				1520	-1	instead of
Acceptable practice				1425	0	Source
Good Practice	The predicted volume of liquid waste per m2 per year to be sent off the site for treatment			1140	3	
Best Practice				950	5	
Occupancy 2	Office	on	L / m2 * yr.	Score	Values proposed by JMH	
Negative				204	-1	instead of
Acceptable practice				190	0	Source
Good Practice	The predicted volume of liquid waste per m2 per year to be sent off the site for treatment			147	3	
Best Practice				119	5	
C4.2 Retention of rainwater for later re-use.						
Intent	To encourage the retention of rainwater on the site for later re-use.			Applicable phases (Active if green)		
Indicator	The percent of annual rainwater falling on the site that is planned to be retained on the site for future use on the site or in the building in holding ponds or tanks.			Dsn	Ops.	
Information sources	References x, y and z					
Applicable project type	Total project					
Assessment method	Review of contract documents and landscaping plans by a person with experience in this field.					
Applicable Standards	a					
	b					
	c					
	d					
Information Submittals	e					
	f					
Total project	Total Project		Percent	Score	Values proposed by JMH	
Negative				0%	-1	instead of
Acceptable practice				0%	0	Source
Good Practice	The percent of annual rainwater falling on the site that is predicted to be retained on the site for future use on the site or in the building in holding ponds or tanks.			45%	3	
Best Practice				75%	5	

Benchmarks C for designated occupancies in BigTown, Europe			Uses included	Small Industrial		
			Office			
			0			
New Construction	Design Phase		Generic		.	
N.A. N.A.						
	N.A.	N.A.	Applicable phases (Active if green)			
	N.A.	N.A.	Dsn	C&C.	Ops.	
	N.A.	N.A.				
	N.A.	N.A.				
	N.A.	N.A.				
	N.A.	N.A.				
	N.A.	N.A.				
	N.A.	N.A.				
	N.A.	N.A.				
	N.A.	N.A.				
	N.A.	N.A.			Score	
	N.A.	N.A.			-1	
	N.A.	N.A.			0	
	N.A.	N.A.			3	
	N.A.	N.A.			5	
	N.A. N.A.					
		N.A.	N.A.	Applicable phases (Active if green)		
		N.A.	N.A.	Dsn	C&C.	Ops.
N.A.		N.A.				
N.A.		N.A.				
N.A.		N.A.				
N.A.		N.A.				
N.A.		N.A.				
N.A.		N.A.				
N.A.		N.A.				
N.A.		N.A.				
N.A.		N.A.			Score	
N.A.		N.A.			-1	
N.A.		N.A.			0	
N.A.		N.A.			3	
N.A.		N.A.			5	

Benchmarks C for designated occupancies in BigTown, Europe		Uses included	Small Industrial	
			Office	
			0	
New Construction	Design Phase	Generic		
N.A. N.A.				
	N.A. N.A.	Applicable phases (Active if green)		
	N.A. N.A.	Dsn		Ops.
	N.A. N.A.	●		
	N.A. N.A.			
	N.A. N.A.			
	N.A. N.A.			
	N.A. N.A.			
	N.A. N.A.			
	N.A. N.A.			
	N.A. N.A.			
	N.A. N.A.			
	N.A. N.A.	Score		
	N.A. N.A.	-1		
	N.A. N.A.	0		
	N.A. N.A.	3		
N.A. N.A.	5			
C6 Other Local and Regional Impacts		●	●	Not applicable (decided in Glasgow)
C6.1 Cumulative thermal changes to lake water or sub-surface aquifers.				
	Intent	To ensure that building operations involving ground-source or ground-water heat pumps do not change the average annual temperature of sub-surface aquifers, nor affect the water quality of such aquifers.		
	Indicator	Predictions of changes in the average annual temperature of sub-surface aquifers, determined by simulation studies.		
	Information sources	References x, y and z		
	Applicable project type	For Total Project if a water-source or ground-source heat pumps (GSHP) is being used.		
	#REF!	Review of mechanical drawings, specifications and equipment by geophysical engineer.		
	Applicable Standards	a		
		b		
		c		
		d		
	Information Submittals	e		
		f		
	Total project	Total Project	Deg. C	Score
	Negative		1.8	-1
	Acceptable practice	Studies predict that operations of ground-source or ground-water heat pumps may change the average annual temperature of sub-surface aquifers by :	1.5	0
	Good Practice		0.6	3
Best Practice		0.0	5	

Benchmarks C for designated occupancies in BigTown, Europe		Uses included	Small Industrial	
			Office	
			0	
New Construction	Design Phase	Generic		
C6.2 Heat Island Effect - landscaping and paved areas.			Not applicable to Crealys context	
Intent	To ensure that open areas of the site are either landscaped, or are paved with reflective materials, to minimize infrared re-radiation to the atmosphere that would increase the urban heat island effect.		Applicable phases (Active if green)	
Indicator	Reflectance and area of paved and landscaped areas, as indicated by drawings and specifications.	Dsn		Ops.
Information sources	References x, y and z			
Applicable project type	Total Project			
Assessment method	Review of landscaping plans and design team analysis.			
Applicable Standards	a			
	b			
	c			
	d			
Information Submittals	e			
	f			
Total project	Total Project	Percent	Score	
Negative		40%	-1	
Acceptable practice	Drawings and specifications indicate that the area of landscaped open area plus paved areas with a surface reflectance of 60% or greater, as a percentage of total open area (site area minus building footprint) is :	50%	0	
Good Practice		80%	3	
Best Practice		100%	5	
C6.3 Heat Island Effect - roofing.			Not applicable to Crealys context	
Intent	To encourage the use of roofing systems with high reflectance or a landscaped or green roof, or a combination of these, so that reflected infrared radiation to the atmosphere is minimized.		Applicable phases (Active if green)	
Indicator	Reflectance and area of roofing material; or the use of a green roof, as indicated by drawings and specifications.	Dsn		Ops.
Information sources	References x, y and z			
Applicable project type	Total Project			
Assessment method	Review of roofing specifications.			
Applicable Standards	a			
	b			
	c			
	d			
Information Submittals	e			
	f			
Total project	Total Project	Percent	Score	
Negative		0%	-1	
Acceptable practice	According to drawings and specifications, the percentage of total roof area provided with a Green roof or a roofing system with a surface reflectance of 60%, or a combination of these, is :	0%	0	
Good Practice		60%	3	
Best Practice		100%	5	

Benchmarks C for designated occupancies in BigTown, Europe			Uses included	Small Industrial	
				Office	
				0	
New Construction	Design Phase		Generic	.	
C6.4 Atmospheric light pollution.				Not applicable to Crealys context	
Intent	To minimize the spillage of light into the atmosphere from ground-level sources.		Applicable phases (Active if green)		
Indicator	Percentage of total exterior light output that lies outside a vertical 120 degree cone, as indicated by drawings and specifications.		Dsn		Ops.
Information sources	0		●		
Applicable project type	Total Project				
Assessment method	Review of building and site illumination plans and design team analysis.				
Applicable Standards	a				
	b				
	c				
	d				
Information Submittals	e				
	f				
Total project	Total Project			Percent	Score
Negative				90%	-1
Acceptable practice	The percentage of total exterior light output that lies outside a vertical 120 degree cone, as indicated by drawings and specifications is :			75%	0
Good Practice				30%	3
Best Practice				0%	5

Benchmarks D for designated occupancies in BigTown, Europe		Uses included	Small Industrial
			Office
			0
New Construction	Design Phase	Generic	.

D Indoor Environmental Quality

D1 Indoor Air Quality

D1.1 Pollutant migration between occupancies.

Intent	Ensure that areas that contain equipment or activities generating chemical pollutants, are separately ventilated and isolated from other occupied spaces. Examples include copier rooms, waste storage areas and janitorial rooms.		Applicable phases (active if green)	
Indicator	Measures taken to isolate areas or rooms where pollutants may be generated, as indicated by drawings and specifications.		Dsn	Ops.
Information sources	0		●	
Applicable project type	Separate by occupancy type.			
#REF	Review of contract documents and mechanical system by an outside mechanical engineer.			
Applicable Standards	a			
	b			
	c			
	d			
Information Submittals	e			
	f			
Occupancy 1	Small Industrial	on	Score	
Negative	Drawings and specifications indicate that some rooms and spaces in this occupancy that contain equipment or activities generating chemical pollutants are not separately ventilated.			-1
Acceptable practice	Drawings and specifications indicate that all rooms and spaces in this occupancy that contain equipment or activities generating chemical pollutants, are separately ventilated.			0
Good Practice	Drawings and specifications indicate that all rooms and spaces in this occupancy that contain equipment or activities generating chemical pollutants, are separately ventilated and there is little possibility of migration to or from other occupied spaces.			3
Best Practice	Drawings and specifications indicate that all rooms and spaces in this occupancy that contain equipment or activities generating chemical pollutants, are separately ventilated and there is NO possibility of migration to or from other occupied spaces.			5
Occupancy 2	Office	on	Score	
Negative	Drawings and specifications indicate that some rooms and spaces in this occupancy that contain equipment or activities generating chemical pollutants are not separately ventilated.			-1
Acceptable practice	Drawings and specifications indicate that all rooms and spaces in this occupancy that contain equipment or activities generating chemical pollutants, are separately ventilated.			0
Good Practice	Drawings and specifications indicate that all rooms and spaces in this occupancy that contain equipment or activities generating chemical pollutants, are separately ventilated and there is little possibility of migration to or from other occupied spaces.			3
Best Practice	Drawings and specifications indicate that all rooms and spaces in this occupancy that contain equipment or activities generating chemical pollutants, are separately ventilated and there is NO possibility of migration to or from other occupied spaces.			5

D1.2 CO2 concentrations in indoor air.

	Intent	To ensure that carbon dioxide concentrations stay below acceptable levels in typical primary occupancy areas.		Applicable phases (active if green)			
	Indicator	Designs for HVAC systems that conform to ASHRAE, CIBSE or other acceptable protocol.		Dsn		Ops.	
	Information sources	Reference x, y and z					
	Applicable project type	Non-residential Occupancies, except for Open Space.					
	Assessment method	Review of contract documents and mechanical system by an outside mechanical engineer.					
	Applicable Standards	a					
		b					
		c					
		d					
	Information Submittals	e					
f							
Occupancy 1	Small Industrial	on	ppm	Score	Values proposed by JMH	instead of	Source: EN 13 779
Negative			1160	-1	1 000	1 000	1 200
Acceptable practice	Designs for HVAC systems, carried out in accordance with ASHRAE, CIBSE or other acceptable standards, predict concentrations of CO2 during operating conditions equal to or less than :		1050	0	800	800	800
Good Practice			720	3	700	700	500
Best Practice			500	5	600	600	350
Occupancy 2	Office	on	ppm	Score	Values proposed by JMH	instead of	Source: EN 13 779
Negative			640	-1	1 000	1 000	1 200
Acceptable practice	Designs for HVAC systems, carried out in accordance with ASHRAE, CIBSE or other acceptable standards, predict concentrations of CO2 during operating conditions equal to or less than :		600	0	800	800	800
Good Practice			480	3	500	700	500
Best Practice			400	5	350	600	350

Benchmarks D for designated occupancies in BigTown, Europe		Uses included	Small Industrial	
		Office		
		0		
New Construction	Design Phase	Generic		
D1.3 IAQ monitoring during project operations.				
Intent	To ensure long-term indoor air quality in non-residential occupancies by installing a permanent carbon dioxide monitoring system to provide objective data on indoor air quality, with monitoring points located in typical primary occupancy areas.		Applicable phases (active if green)	
Indicator	Measures anticipated to ensure adequate monitoring of IAQ quality.	Dsn		Ops.
Information sources	Reference A, B and C.			
Applicable project type	By separate occupancies except outdoor space.			
Assessment method	Review of contract documents and mechanical system by an outside mechanical engineer.			
Applicable Standards	a			
	b			
	c			
	d			
Information Submittals	e			
	f			
Occupancy 1	Small Industrial	on	Score	
Negative	No specific measures are anticipated to ensure adequate and on-going monitoring of IAQ quality in public areas.		-1	
Acceptable practice	Annual monitoring is anticipated to assess IAQ quality in public areas.		0	
Good Practice	Quarterly monitoring is anticipated to assess IAQ quality in public areas.		3	
Best Practice	Daily monitoring is anticipated to assess IAQ quality in public areas.		5	
Occupancy 2	Office	on	Score	
Negative	No specific measures are anticipated to ensure adequate and on-going monitoring of IAQ quality in public areas.		-1	
Acceptable practice	Annual monitoring is anticipated to assess IAQ quality in public areas.		0	
Good Practice	Quarterly monitoring is anticipated to assess IAQ quality in public areas.		3	
Best Practice	Daily monitoring is anticipated to assess IAQ quality in public areas.		5	
D2 Ventilation				
D2.1 Effectiveness of ventilation in naturally ventilated occupancies.				
Intent	To ensure that the number, placement and type of windows or other openings in a naturally-ventilated building are capable of providing a high level of air quality and ventilation.		Applicable phases (active if green)	
Indicator	Area and location of windows that provide natural ventilation.	Dsn		Ops.
Information sources	Cross-ventilation is defined as spaces where operable windows are located on at least two separate walls.			
Applicable project type	By separate occupancies for buildings under a defined height limit.	Height limit, floors	16	
Assessment method	Review of contract documents and mechanical system by an outside mechanical engineer with specific knowledge of natural ventilation issues.			
Applicable Standards	a			
	b			
	c			
	d			
Information Submittals	e			
	f			
Occupancy 1	Small Industrial	M	Score	
Negative	The aggregate area of openings from primary occupancy areas to the exterior is less than 5% of the aggregate primary floor area, and less than 50% of all primary spaces have cross-ventilation.		-1	
Acceptable practice	The aggregate area of openings from primary occupancy areas to the exterior is at least 5% of the aggregate primary floor area, and more than 50% of all primary spaces have cross-ventilation.		0	
Good Practice	The aggregate area of openings from primary occupancy areas to the exterior is at least 5% of the aggregate primary floor area, and at more than 75% of all primary spaces have cross-ventilation.		3	
Best Practice	The aggregate area of openings from primary occupancy areas to the exterior is at least 10% of the aggregate primary floor area, and more than 90% of all primary spaces have cross-ventilation.		5	
Occupancy 2	Office	M	Score	
Negative	The aggregate area of openings from primary occupancy areas to the exterior is less than 5% of the aggregate primary floor area, and less than 50% of all primary spaces have cross-ventilation.		-1	
Acceptable practice	The aggregate area of openings from primary occupancy areas to the exterior is at least 5% of the aggregate primary floor area, and more than 50% of all primary spaces have cross-ventilation.		0	
Good Practice	The aggregate area of openings from primary occupancy areas to the exterior is at least 5% of the aggregate primary floor area, and at more than 75% of all primary spaces have cross-ventilation.		3	
Best Practice	The aggregate area of openings from primary occupancy areas to the exterior is at least 10% of the aggregate primary floor area, and more than 90% of all primary spaces have cross-ventilation.		5	

Benchmarks D for designated occupancies in BigTown, Europe			Uses included
			Small Industrial
			Office
			0
New Construction	Design Phase	Generic	.

D2.2 Air quality and ventilation in mechanically ventilated occupancies.				
Intent	To ensure that mechanical ventilation and cooling systems are designed in a manner that will ensure a satisfactory level of air quality and ventilation.			Applicable phases (active if green)
Indicator	Conformance of the design to the requirements of a recognized relevant standard, such as ASHRAE or CIBSE.	Dsn		Ops.
Information sources	Reference x, y and z			
Applicable project type	Any occupancy except Outdoor Area			
Assessment method	Review of contract documents and mechanical system by an outside mechanical engineer.			
Applicable Standards	a			
	b			
	c			
	d			
Information Submittals	e			
	f			
Occupancy 1	Small Industrial	M		Score
Negative	Mechanical ventilation in some primary occupancy areas does not fully satisfy the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.			-1
Acceptable practice	Mechanical ventilation in some primary occupancy areas meets the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.			0
Good Practice	Mechanical ventilation in more than 50% of primary occupancy areas exceeds the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.			3
Best Practice	Mechanical ventilation in 100% of primary occupancy areas exceeds the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.			5
Occupancy 2	Office	M		Score
Negative	Mechanical ventilation in some primary occupancy areas does not fully satisfy the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.			-1
Acceptable practice	Mechanical ventilation in some primary occupancy areas meets the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.			0
Good Practice	Mechanical ventilation in more than 50% of primary occupancy areas exceeds the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.			3
Best Practice	Mechanical ventilation in 100% of primary occupancy areas exceeds the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.			5

D2.3 Air movement in mechanically ventilated occupancies.				
Intent	To ensure that air movement in mechanically ventilated occupancies is sufficient to satisfy requirements for human comfort.			#REF!
Indicator	Predicted air speed in m/s, as indicated by an analysis of proposed HVAC system characteristics or by post-occupancy monitoring.	Dsn		Ops.
Information sources	Reference x, y and z			
Applicable project type	Total project			
Assessment method	Review of contract documents and mechanical system by an outside mechanical engineer.			
Applicable Standards	a			
	b			
	c			
	d			
Information Submittals	e			
	f			
Occupancy 1	Small Industrial	on	m/s	Score
Negative				0.0 -1
Acceptable practice	An analysis of proposed HVAC system characteristics indicates that air speed at working level during typical operating conditions is likely to be :			0.0 0
Good Practice				0.0 3
Best Practice				0.0 5
Occupancy 2	Office	on	m/s	Score
Negative				1.2 -1
Acceptable practice	An analysis of proposed HVAC system characteristics indicates that air speed at working level during typical operating conditions is likely to be :			1.5 0
Good Practice				2.4 3
Best Practice				3.0 5

Values proposed by JMH	instead of	Source
	0.0	
	0.0	
	0.0	
	0.0	
	1.2	
	1.5	
	2.4	
	3.0	

Benchmarks D for designated occupancies in BigTown, Europe		Uses included	Small Industrial
			Office
			0
New Construction	Design Phase	Generic	

Benchmarks D for designated occupancies in BigTown, Europe		Uses included	Small Industrial
			Office
			0
New Construction	Design Phase	Generic	.

D2.3 Air movement in mechanically ventilated occupancies.

Intent	To ensure that mechanical ventilation and cooling systems are designed in a manner that will ensure a satisfactory level of air quality and ventilation.		Applicable phases (active if green)	
Indicator	Conformance of the design to the requirements of a recognized relevant standard, such as ASHRAE or CIBSE.		Dsn	Ops.
Information sources	Reference x, y and z			
Applicable project type	Any occupancy except Outdoor Area			
#REF!	Review of contract documents and mechanical system by an outside mechanical engineer.			
Applicable Standards	a			
	b	text to be revised		
	c			
	d			
Information Submittals	e			
	f			
Occupancy 1	Small Industrial		M	Score
Negative	Mechanical ventilation in some primary occupancy areas does not fully satisfy the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.			-1
Acceptable practice	Mechanical ventilation in some primary occupancy areas meets the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.			0
Good Practice	Mechanical ventilation in more than 50% of primary occupancy areas exceeds the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.			3
Best Practice	Mechanical ventilation in 100% of primary occupancy areas exceeds the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.			5
Occupancy 2	Office		M	Score
Negative	Mechanical ventilation in some primary occupancy areas does not fully satisfy the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.			-1
Acceptable practice	Mechanical ventilation in some primary occupancy areas meets the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.			0
Good Practice	Mechanical ventilation in more than 50% of primary occupancy areas exceeds the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.			3
Best Practice	Mechanical ventilation in 100% of primary occupancy areas exceeds the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.			5

D2.4 Effectiveness of ventilation in mechanically ventilated occupancies.

Intent	Ensure, through the use of appropriate simulation programs, that the ventilation system in mechanically-ventilated non-residential occupancies will bring ventilation air to where it is needed, i.e. to seating areas or workers or visitors.		Applicable phases (active if green)				
	Indicator	Percent of ventilation air reaching work surfaces, as indicated by an analysis of proposed HVAC system and room characteristics.	Dsn		Ops.		
Information sources	Reference x, y and z						
Applicable project type	Non-residential Occupancies.						
Assessment method	Review of contract documents and mechanical system by an outside mechanical engineer.						
Applicable Standards	a						
	b						
	c						
	d						
Information Submittals	e						
	f						
Occupancy 1	Small Industrial	on	Eac	Score	Values proposed by JMH	instead of	Source
Negative			80%	-1	80%	80%	o.k. with proposal
Acceptable practice	An analysis of proposed HVAC system and room characteristics in mechanically ventilated areas of the occupancy indicates that the air change effectiveness (Eac), as determined by ASHRAE 129		80%	0	80%	80%	o.k. with proposal
Good Practice	-1997 or equivalent CIBSE or other standard, of :		89%	3	89%	89%	o.k. with proposal
Best Practice			95%	5	95%	95%	o.k. with proposal
Occupancy 2	Office	on	Eac	Score	Values proposed by JMH	instead of	Source
Negative			80%	-1	80%	80%	o.k. with proposal
Acceptable practice	An analysis of proposed HVAC system and room characteristics in mechanically ventilated areas of the occupancy indicates that the air change effectiveness (Eac), as determined by ASHRAE 129		80%	0	80%	80%	o.k. with proposal
Good Practice	-1997 or equivalent CIBSE or other standard, of :		89%	3	89%	89%	o.k. with proposal
Best Practice			95%	5	95%	95%	o.k. with proposal

Benchmarks D for designated occupancies in BigTown, Europe				Uses included	Small Industrial	
					Office	
					0	
New Construction	Design Phase			Generic		
D3 Air Temperature and Relative Humidity						
D3.1 Air temperature and relative humidity in mechanically heated occupancies.						
Intent	To ensure acceptable temperature and humidity control within established ranges per climate zone, and to provide on-going monitoring of thermal comfort performance and the effectiveness of humidification and/or dehumidification system.			Applicable phases (active if green)		
	Indicator	Compliance of mechanical ventilation systems with recognized design standards such as ASHRAE or CIBSE.		Dsn		Ops.
		Information sources				
	Reference x, y and z					
	Applicable project type					
	All mechanically ventilated occupancies.					
	#REF!					
	Review of contract documents and mechanical system by an outside mechanical engineer.					
	Applicable Standards	a				
		b				
		c				
d						
Information Submittals	e					
	f					
Occupancy 1	Small Industrial			ON	Score	
Negative	The mechanical system design does not comply with ASHRAE 55-1992, or other similar standard such as CIBSE, or the variation from setpoints exceeds 5 deg. C:			-1	≥ 19°C	< 5°C
Acceptable practice	The mechanical system design complies with ASHRAE 55-1992, or complies with other similar standard such as CIBSE. Temperature variation from setpoints does not exceed 3 deg. C.			0	≥ 21°C	< 3°C
Good Practice	The mechanical system design complies with ASHRAE 55-1992, or complies with other similar standard such as CIBSE. Temperature variation from setpoints does not exceed 2 deg. C.			3	≥ 23°C	< 2°C
Best Practice	The mechanical system design complies with ASHRAE 55-1992, or complies with other similar standard such as CIBSE. A permanent monitoring system provides feedback on temperature and humidity conditions. Temperature variation from setpoints does not exceed 1 deg. C.			5	≤ 25°C	< 1°C
D3.2 Air temperature and relative humidity in mechanically cooled occupancies.						
Intent	To ensure acceptable temperature within established ranges per climate zone in naturally ventilated occupancies.			Applicable phases (active if green)		
	Indicator	Predicted ability of natural ventilation systems to maintain temperatures within an acceptable range, as indicated by drawings and specifications.		Dsn		Ops.
		Information sources				
	ASHRAE 55-1992, Addenda 1995 or equivalent CIBSE or other recognized standard.					
	Applicable project type					
	Total project					
	Assessment method					
	Review of contract documents and mechanical system by an outside mechanical engineer with specific knowledge of natural ventilation issues.					
	Applicable Standards	a				
		b				
		c				
d						
Information Submittals	e					
	f					
Total project	Total Project			Score		
Negative	According to recognized predictive techniques, the temperature in primary occupancy areas can NOT be kept, for more than 90% of occupied hours, within a swing range (+ or -) of 6 deg. C.			-1	≤ 28°C	90% in range of 6°C
Acceptable practice	According to recognized predictive techniques, the temperature in primary occupancy areas can be kept, for more than 90% of occupied hours, within a swing range (+ or -) of 4 deg. C.			0	≤ 24°C	90% in range of 4°C
Good Practice	According to recognized predictive techniques, the temperature in primary occupancy areas can be kept, for more than 90% of occupied hours, within a swing range (+ or -) of 3 deg. C.			3	≤ 22°C	90% in range of 3°C
Best Practice	According to recognized predictive techniques, the temperature in primary occupancy areas can be kept, for more than 90% of occupied hours, within a swing range (+ or -) of 2 deg. C.			5	≤ 20°C	90% in range of 2°C

Benchmarks D for designated occupancies in BigTown, Europe				Uses included	Small Industrial			
				Office				
				0				
New Construction	Design Phase			Generic				
D3.3 Time lag and decrement factor								
	Intent	To ensure acceptable temperature within established ranges per climate zone in naturally ventilated occupancies.			Applicable phases (active if green)			
	Indicator	Predicted ability of natural ventilation systems to maintain temperatures within an acceptable range, as indicated by drawings and specifications.			Dsn	Ops.		
	Information sources	ASHRAE 55-1992, Addenda 1995 or equivalent CIBSE or other recognized standard.						
	Applicable project type	Total project						
	Assessment method	Review of contract documents and mechanical system by an outside mechanical engineer with specific knowledge of natural ventilation issues.						
	Applicable Standards	a						
		b						
		c						
		d						
	Information Submittals	e						
		f						
Total project	Total Project				Score	Values proposed by JMH	instead of	Source
Negative	According to recognized predictive techniques, the temperature in primary occupancy areas can NOT be kept, for more than 90% of occupied hours, within a swing range (+ or -) of 6 deg. C.				-1	6°C	90% in range of 6°C	o.k. with proposal and confirmed other values
Acceptable practice	According to recognized predictive techniques, the temperature in primary occupancy areas can be kept, for more than 90% of occupied hours, within a swing range (+ or -) of 4 deg. C.				0	4°C	90% in range of 4°C	RGPT : 20 to 24°C
Good Practice	According to recognized predictive techniques, the temperature in primary occupancy areas can be kept, for more than 90% of occupied hours, within a swing range (+ or -) of 3 deg. C.				3	3°C	90% in range of 3°C	intermediate value between neighbor ones
Best Practice	According to recognized predictive techniques, the temperature in primary occupancy areas can be kept, for more than 90% of occupied hours, within a swing range (+ or -) of 2 deg. C.				5	2°C	90% in range of 2°C	NEN 13 779
D3.4 Air temperature in naturally ventilated occupancies.								
	Intent	To ensure acceptable temperature within established ranges per climate zone in naturally ventilated occupancies.			Applicable phases (active if green)			
	Indicator	Predicted ability of natural ventilation systems to maintain temperatures within an acceptable range, as indicated by drawings and specifications.			Dsn	Ops.		
	Information sources	ASHRAE 55-1992, Addenda 1995 or equivalent CIBSE or other recognized standard.						
	Applicable project type	Total project						
	Assessment method	Review of contract documents and mechanical system by an outside mechanical engineer with specific knowledge of natural ventilation issues.						
	Applicable Standards	a						
		b						
		c						
		d						
	Information Submittals	e						
		f						
Total project	Total Project				Score	Values proposed by JMH	instead of	Source
Negative	According to recognized predictive techniques, the temperature in primary occupancy areas can NOT be kept, for more than 90% of occupied hours, within a swing range (+ or -) of 6 deg. C.				-1	6°C	90% in range of 6°C	o.k. with proposal and confirmed other values
Acceptable practice	According to recognized predictive techniques, the temperature in primary occupancy areas can be kept, for more than 90% of occupied hours, within a swing range (+ or -) of 4 deg. C.				0	4°C	90% in range of 4°C	RGPT : 20 to 24°C
Good Practice	According to recognized predictive techniques, the temperature in primary occupancy areas can be kept, for more than 90% of occupied hours, within a swing range (+ or -) of 3 deg. C.				3	3°C	90% in range of 3°C	intermediate value between neighbor ones
Best Practice	According to recognized predictive techniques, the temperature in primary occupancy areas can be kept, for more than 90% of occupied hours, within a swing range (+ or -) of 2 deg. C.				5	2°C	90% in range of 2°C	NEN 13 779






Benchmarks D for designated occupancies in BigTown, Europe				Uses included	Small Industrial			
				Office				
				0				
New Construction	Design Phase			Generic				
D4 Daylighting and Illumination								
D4.1 Daylighting in primary occupancy areas.								
	Intent	To ensure an adequate level of daylighting in all primary occupied spaces.		Applicable phases (active if green)				
	Indicator	The predicted Daylight Factor in a typical occupancy area located on the ground floor of the building, as indicated by drawings and specifications.		Dsn		Ops.		
	Information sources	x						
	Applicable project type	By separate occupancies						
	Assessment method	Review of contract documents by an illumination specialist.						
	Applicable Standards	a						
		b						
		c						
		d						
	Information Submittals	e						
		f						
	Occupancy 1	Small Industrial	M	DF	Score	Values proposed by JMH	instead of	Source: littérature
	Negative				1.8%	-1	1.0%	circulation areas
	Acceptable practice	The predicted Daylight Factor in a typical workspace located on the ground floor of the occupancy, as indicated by drawings and specifications.			2.0%	0	2.0%	standard workshop
	Good Practice				2.6%	3	3.0%	(intermediate value)
Best Practice				3.0%	5	5.0%	for precise tasks	
Occupancy 2	Office	on	DF	Score	Values proposed by JMH	instead of		
Negative				0.0%	-1	1.0%	circulation areas	
Acceptable practice	The predicted Daylight Factor in a typical workspace located on the ground floor of the occupancy, as indicated by drawings and specifications.				0	2.0%	standard office	
Good Practice				0.0%	3	3.0%	(intermediate value)	
Best Practice					5	5.0%	drawing office	
D4.2 Glare in non-residential occupancies.								
	Intent	To ensure that glare conditions are minimized in main occupancy areas during periods of maximum exterior brightness, through the use of exterior or interior shading.		#REF!				
	Indicator	The predicted maximum ratio of contrast in illuminance between windows and adjacent wall areas in a typical occupancy area, as indicated by design characteristics.		Dsn		Ops.		
	Information sources	Glare shall be measured by the contrast between window areas and adjacent wall areas, as seen from the interior.						
	Applicable project type	Non-residential occupancies						
	Assessment method	Review of contract documents by an illumination specialist.						
	Applicable Standards	a						
		b						
		c						
		d						
	Information Submittals	e						
		f						
	Occupancy 1	Small Industrial	on	Ratio	Score	Values proposed by JMH	instead of	Source
	Negative				59	-1	40	59
	Acceptable practice	The predicted maximum ratio of contrast in illuminance between windows and adjacent wall areas in a typical occupancy area, as indicated by design characteristics is :			50	0	20	50
	Good Practice				23	3	10	23
Best Practice				5	5	3	5	
Occupancy 2	Office	on	Ratio	Score	Values proposed by JMH	instead of	Source	
Negative				59	-1	40	59	
Acceptable practice	The predicted maximum ratio of contrast in illuminance between windows and adjacent wall areas in a typical occupancy area, as indicated by design characteristics is :			50	0	20	50	
Good Practice				23	3	10	23	
Best Practice				5	5	3	5	

Benchmarks D for designated occupancies in BigTown, Europe				Uses included	Small Industrial	
					Office	
					0	
New Construction	Design Phase			Generic		
D4.3 Illumination levels and quality of lighting.						
	Intent	To ensure that lighting systems provide adequate illumination and quality levels in public and work areas; and that there is a capability to support the provision of suitable task lighting in work areas.			Applicable phases (active if green)	
	Indicator	Appropriateness of illumination levels and lighting quality to planned tasks, in Lux, as indicated by design characteristics.			Dsn	Ops.
	Information sources	Acceptable values range from 30 to 500 Lux for normal tasks, and up to 10,000 Lux for demanding tasks.			●	●
	Applicable project type	Non-residential Occupancies, all sizes.				
	Assessment method	Review of contract documents, especially lighting plans and specs, by an illumination specialist.				
	Applicable Standards	a				
		b				
		c				
		d				
	Information Submittals	e				
		f				
	Occupancy 2	Office			on	Score
	Negative	The design indicates that illumination levels and quality of lighting will not be appropriate to planned tasks in the occupancy, and no provision is made for task lighting.			-1	
	Acceptable practice	The design indicates that ambient illumination systems will provide illumination levels appropriate to tasks in the occupancy, and provision is made for task lighting.			0	
	Good Practice	The design indicates that ambient illumination systems will provide illumination levels appropriate to tasks in the occupancy, dimmable ballasts are provided, and provision is made for task lighting in each 15 m2 work zone.			3	
	Best Practice	The design indicates that ambient illumination systems will provide illumination levels appropriate to tasks in the occupancy, dimmable ballasts are provided, and provision is made for task lighting in each 10 m2 work zone.			5	
D5 Noise and Acoustics				●	●	
D5.1 Noise attenuation through the exterior envelope.						
	Intent	Ensure that noise attenuation through the wall facing the noisiest site boundary is adequate to provide interior noise levels that will not interfere with normal tasks.			Applicable phases (active if green)	
	Indicator	The predicted noise attenuation performance of the exterior wall most exposed to potential sources of noise, as indicated by design characteristics.			Dsn	Ops.
	Information sources	http://greenbuildings.santa-monica.org/envelope/envventilation.html				
	Applicable project type	Total Project				
	Assessment method	Review of design team analysis by a noise specialist.				
	Applicable Standards	a				
		b				
		c				
		d				
	Information Submittals	e				
		f				
	Total project	Total Project			STC	Score
	Negative				29.7	-1
	Acceptable practice	Design documents indicate that windows in the exterior wall of the Design exposed to the most significant sources of external noise will have a Sound Transmission Class, or equivalent, of :			27.5	0
	Good Practice				34.1	3
	Best Practice				38.5	5
				Values proposed by JMH	instead of	
				26.0	29.7	
				29.0	standard value of STC	
				34.0	acoustic glass	
				41.0	2 glasses + 10 cm space between them	





Benchmarks D for designated occupancies in BigTown, Europe				Uses included	Small Industrial			
				Office				
				0				
New Construction	Design Phase			Generic				
D5.2 Transmission of facility equipment noise to primary occupancies.								
Intent	To ensure that HVAC systems and equipment rooms are designed to minimize noise transmission to primary occupancies.			Applicable phases (Active if green)				
Indicator	Noise Reduction Criteria ratings of mechanical equipment and equipment rooms, as indicated by design characteristics.			Dsn		Ops.		
Information sources	Reference x, y and z."							
Applicable project type	Total project							
Assessment method	Review of contract documents and mechanical system by an outside mechanical engineer.							
Applicable Standards	a							
	b							
	c							
	d							
Information Submittals	e							
	f							
Total project	Total Project			NRC	Score	Values proposed by JMH	instead of	Source: Belgian acoustic standard
Negative				37.0	-1	37.0	37.0	
Acceptable practice	Design documents indicate that HVAC systems and equipment rooms are designed for a Noise Reduction Criteria (NRC) of :			35.0	0	29.0	35.0	normal acoustic comfort
Good Practice				29.0	3	34.0	29.0	intermediate value
Best Practice				25.0	5	41.0	25.0	superior acoustic comfort
D5.3 Noise attenuation between primary occupancy areas.								
Intent	To ensure that measures have been taken to reduce noise impacts between all tenancies and occupancy types.			Applicable phases (active if green)				
Indicator	Minimum Sound Transmission Class of partitions between primary occupancy areas, as indicated by design characteristics.			Dsn		Ops.		
Information sources	Reference x, y and z."							
Applicable project type	Total project							
Assessment method	Review of design team analysis.							
Applicable Standards	a							
	b							
	c							
	d							
Information Submittals	e							
	f							
Total project	Total Project			STC	Score	Values proposed by JMH	instead of	Source: Belgian acoustic standard
Negative				23.0	-1	50.0	23.0	
Acceptable practice	Design documents indicate that the Minimum Sound Transmission Class of partitions between			25.0	0	54.0	25.0	standard: normal comfort
Good Practice	primary occupancy areas will be :			31.0	3	59.0	31.0	
Best Practice				35.0	5	62.0	35.0	standard: superior comfort

Benchmarks D for designated occupancies in BigTown, Europe				Uses included	Small Industrial
				Office	
				0	
New Construction	Design Phase	Generic			
D5.4 Acoustic performance within primary occupancy areas.					
Intent	To ensure that primary occupancies are designed to ensure a satisfactory level of acoustic performance.			Applicable phases (active if green)	
Indicator	Predicted reverberation time in seconds, as indicated by design characteristics.	Dsn		Ops.	
Information sources	Although acoustics is a complex science, only reverberation time is dealt with here.				
Applicable project type	Non-residential occupancies, all sizes				
Assessment method	Where needed, review of design team analysis by an acoustic specialist.				
Applicable Standards	a				
	b				
	c				
	d				
Information Submittals	e				
	f				
Occupancy 1	Small Industrial	on		Score	
Negative	Design documents indicate that reverberation time in primary occupancy areas will be more than 3.5 seconds or less than 0.5 second.			-1	
Acceptable practice	Design documents indicate that reverberation time in primary occupancy areas will be between 3.5 seconds and 0.5 second.			0	
Good Practice	Design documents indicate that reverberation time in primary occupancy areas will be between 3 seconds and 1 second.			3	
Best Practice	Design documents indicate that reverberation time in primary occupancy areas will be between 2.5 seconds and 1.5 second.			5	
Occupancy 2	Office	on		Score	
Negative	Design documents indicate that reverberation time in primary occupancy areas will be more than 3.5 seconds or less than 0.5 second.			-1	
Acceptable practice	Design documents indicate that reverberation time in primary occupancy areas will be between 3.5 seconds and 0.5 second.			0	
Good Practice	Design documents indicate that reverberation time in primary occupancy areas will be between 3 seconds and 1 second.			3	
Best Practice	Design documents indicate that reverberation time in primary occupancy areas will be between 2.5 seconds and 1.5 second.			5	
D6 Control of electromagnetic emissions					"magnetic" instead of "electromagnetic"
Intent	To ensure that electro-magnetic emissions are kept to a level that does not harm human health.			Applicable phases (Active if green)	
Indicator		Dsn		Ops.	
Information sources	The report shown below states that there is no certain standard for EMF.				
	Environmental Health Perspectives				
Applicable project type	Total Building, all sizes.				
Assessment method	0				
Applicable Standards	a				
	b				
	c				
	d				
Information Submittals	e				
	f				
Total project	Total Project			Score	
Negative	XXXa.			-1	
Acceptable practice	XXXs			0	
Good Practice	XXXd.			3	
Best Practice	XXXg.			5	

Benchmarks E for designated occupancies in BigTown, Europe		Uses included	Small Industrial
			Office
			0
New Construction	Design Phase	Generic	.
E Service Quality			●

Benchmarks E for designated occupancies in BigTown, Europe			Uses included	Small Industrial		
				Office		
				0		
New Construction	Design Phase		Generic		.	
E1	Automation of building systems to maximize operational efficiency					
	#REF!	To encourage the commissioning of building systems with critical functions.	Applicable phases (Active if green)			
	#REF!	The development of a commissioning plan and the range of systems to be commissioned.	Dsn	C&C.	Ops.	
	#REF!	It is strongly recommended that the architects and engineers should be involved in the commissioning process, to ensure that the design intent is respected. Costs are estimated as ranging from 0.5% to 1.5%, with specialized facilities much higher.				
	Applicable project type	Total building where total net area is more than threshold area.	Threshold area, m2		10 000	
	Not applicable to Crealys context					
	#REF!	Review of commissioning management plan.				
	Applicable Standards	a				
		b				
		c				
		d				
	Information Submittals	e				
		f				
	#REF!	Total project			Score	
	Negative	No commissioning plan has been developed and no commissioning activities are planned.			-1	
	Acceptable practice	A commissioning plan has been developed and some building systems with critical functions are to be commissioned, including life safety systems, central HVAC systems and electrical systems.			0	
	Good Practice	A commissioning plan has been developed and all building systems with critical functions are to be fully commissioned, including life safety systems, central HVAC systems, lighting, building control and electrical systems.			3	
	Best Practice	A commissioning plan has been developed and all building systems with critical functions are to be fully commissioned, including life safety systems, central HVAC systems, lighting, building control, electrical systems and the building envelope.			5	

Benchmarks E for designated occupancies in BigTown, Europe			Uses included	Small Industrial		
				Office		
				0		
New Construction	Design Phase		Generic		.	
E2 Ability to modify facility technical systems.						
	#REF!	To encourage the commissioning of building systems with critical functions.	Applicable phases (Active if green)			
	#REF!	The development of a commissioning plan and the range of systems to be commissioned.	Dsn	C&C.	Ops.	
	#REF!	It is strongly recommended that the architects and engineers should be involved in the commissioning process, to ensure that the design intent is respected. Costs are estimated as ranging from 0.5% to 1.5%, with specialized facilities much higher.				
	Applicable project type	Total building where total net area is more than threshold area.	Threshold area, m2		0	
	#REF!	Review of commissioning management plan.				
	Applicable Standards	a	<div>Revise text</div>			
		b				
		c				
		d				
	Information Submittals	e				
		f				
	#REF!	Total project	Score			
	Negative	No commissioning plan has been developed and no commissioning activities are planned.				-1
	Acceptable practice	A commissioning plan has been developed and some building systems with critical functions are to be commissioned, including life safety systems, central HVAC systems and electrical systems.				0
	Good Practice	A commissioning plan has been developed and all building systems with critical functions are to be fully commissioned, including life safety systems, central HVAC systems, lighting, building control and electrical systems.				3
	Best Practice	A commissioning plan has been developed and all building systems with critical functions are to be fully commissioned, including life safety systems, central HVAC systems, lighting, building control, electrical systems and the building envelope.				5

Benchmarks E for designated occupancies in BigTown, Europe			Uses included	Small Industrial	
				Office	
				0	
New Construction	Design Phase		Generic		.
E3 Commissioning of facility systems					
Intent	To encourage the commissioning of building systems with critical functions.		Applicable phases (Active if green)		
Indicator	The development of a commissioning plan and the range of systems to be commissioned.		Dsn	C&C.	Ops.
Information sources	It is strongly recommended that the architects and engineers should be involved in the commissioning process, to ensure that the design intent is respected. Costs are estimated as ranging from 0.5% to 1.5%, with specialized facilities much higher.				
Applicable project type	Total building where total net area is more than threshold area.		Threshold area, m2		10 000
#REF!	Review of commissioning management plan.				
Applicable Standards	a				
	b				
	c				
	d				
Information Submittals	e				
	f				
#REF!	Total project				Score
Negative	No commissioning plan has been developed and no commissioning activities are planned.				-1
Acceptable practice	A commissioning plan has been developed and some building systems with critical functions are to be commissioned, including life safety systems, central HVAC systems and electrical systems.				0
Good Practice	A commissioning plan has been developed and all building systems with critical functions are to be fully commissioned, including life safety systems, central HVAC systems, lighting, building control and electrical systems.				3
Best Practice	A commissioning plan has been developed and all building systems with critical functions are to be fully commissioned, including life safety systems, central HVAC systems, lighting, building control, electrical systems and the building envelope.				5

Not applicable to Crealys context

Benchmarks E for designated occupancies in BigTown, Europe		Uses included	Small Industrial	
			Office	
			0	
New Construction	Design Phase	Generic	.	
E4 Maintenance of Operating Performance			●	●
E4.1 Maintenance of building envelope performance.			●	●
Intent	To ensure that detailed design minimizes the risk of moisture accumulating in the building envelope, where it is likely to shorten the lifespan of building elements, especially if constructed of wood in areas where temperatures can fall to below 0 deg.C.	Applicable phases (Active if green)		
Indicator	In areas where applicable, the existence of a report that describes and details the measures taken to ensure long-term integrity of the building envelope.	Dsn		Ops.
Information sources	0			
Applicable project type	Any occupancy type where winter design temperatures fall below 0 deg. C.			
Assessment method	Review of contract documents and engineering analysis of performance during winter conditions.			
Applicable Standards	a			
	b			
	c			
	d			
Information Submittals	e			
	f			
#REF!	Total Project			Score
Negative	Envelope detailing and construction does not follow industry good practice.			-1
Acceptable practice	Envelope detailing and construction follows industry good practice.			0
Good Practice	Envelope detailing and construction follows best practices, and at least one air-depressurization test is carried out.			3
Best Practice	Envelope detailing and construction follows best practices, and air-depressurization tests are carried out before and after interior finishes are applied.			5

Benchmarks E for designated occupancies in BigTown, Europe			Uses included	Small Industrial	
				Office	
				0	
New Construction	Design Phase		Generic		.
E4.2 Development and implementation of a maintenance management plan.					
	Intent	To ensure the availability and implementation of a plan for the long-term maintenance and efficient operation of the facility.	Applicable phases (Active if green)		
	Indicator	The availability of a comprehensive and long-term plan at the end of Design phase, and evidence of its implementation during Operations phase.	Dsn		Ops.
	Information sources	0			
	Applicable project type	Total project, where gross area exceeds threshold area.	Threshold area, m2	10 000	Not applicable to Crealys context
	#REF!	Review of operations and maintenance management plan.			
	Applicable Standards	a			
		b			
		c			
		d			
	Information Submittals	e			
		f			
	#REF!	Total Project			Score
	Negative	No explicit plan exists for future maintenance and efficient operation of the facility.			-1
	Acceptable practice	An explicit plan exists for future maintenance and efficient operation of the facility, but it is not comprehensive and is not long term.			0
	Good Practice	An explicit plan exists for future maintenance and efficient operation of the facility, covering main technical systems, and providing performance targets, system maintenance and replacement guidance over at least a 10-year period.			3
	Best Practice	An explicit plan exists for future maintenance and efficient operation of the facility, covering all technical systems, and providing performance targets, system maintenance and replacement guidance over a 25-year period.			5

Benchmarks E for designated occupancies in BigTown, Europe		Uses included	Small Industrial		
			Office		
			0		
New Construction	Design Phase	Generic			
E4.3 On-going monitoring and verification of performance.					
Intent	To ensure the ongoing optimization of building energy and water consumption performance over time.		Applicable phases (Active if green)		
Indicator	The provision of energy sub-metering systems and water consumption monitoring systems, according to design documentation.		Dsn		Ops.
Information sources	0				
Applicable project type	0				
Assessment method	Review of contract documentation, with special emphasis on the capability of the computerized building management system to manage the gathering and analysis of data from many dispersed locations.				
Applicable Standards	a				
	b				
	c				
	d				
Information Submittals	e				
	f				
#REF!	Total Project				Score
Negative	According to design documentation, no sub-metering of energy use will be provided for major occupancies.				-1
Acceptable practice	According to design documentation, an energy submetering system is provided for a few major occupancies.				0
Good Practice	According to design documentation, an energy and water submetering system will be provided for the occupancy, occasional air quality tests will be carried out, and a reporting system will be provided.				3
Best Practice	According to design documentation an energy and water submetering system linked to a building management system will be provided for the occupancy, regular air quality tests will be carried out, and a reporting system will be provided.				5

Benchmarks E for designated occupancies in BigTown, Europe		Uses included	Small Industrial		
			Office		
			0		
New Construction	Design Phase	Generic		.	
E4.4 Retention of as-built drawings and documentation.					
Intent	Ensure that as-built architectural, mechanical and electrical drawings, and equipment manuals are available to operating staff and owners, so that they will be able to operate the building efficiently.	Applicable phases (Active if green)			
Indicator	The scope and quality of design documentation retained for use by building operators, according to design documentation.	Dsn		Ops.	
Information sources	0				
Applicable project type	0				
Applicable Standards	a				
	b				
	c				
	d				
Information Submittals	e				
	f				
#REF!	Total Project	Score			
Negative	Operations and maintenance manuals have not been provided, or are deficient. Plans for operation do not provide for recording, reporting and documentation protocol for maintenance, or it will be inconsistent with the size and complexity of the building.	-1			
Acceptable practice	A full set of systems manuals and complete as-built drawings will be been provided. There will be a partial recording, reporting and documentation protocol for maintenance, but somewhat inconsistent with the size and complexity of the building.	0			
Good Practice	A full set of operations and maintenance documentation, including a full set of systems manuals, complete as-built drawings and an operations and maintenance guide will be provided.	3			
Best Practice	A full set of operations and maintenance documentation, including a full set of systems manuals, complete as-built drawings and an operations and maintenance guide will be provided in both hard-copy and electronic forms.	5			

Benchmarks E for designated occupancies in BigTown, Europe		Uses included	Small Industrial		
			Office		
			0		
New Construction	Design Phase	Generic		.	
E4.5 Provision and maintenance of a building log.					
Intent	Assess whether operating events, such as significant events, occupancy density, operating schedule, energy and water consumption, renovations and equipment changes, etc., are all recorded in a building log for future analysis and reference.	Applicable phases (Active if green)			
Indicator	The maintenance of a building log, of varying degrees of comprehensiveness.	Dsn		Ops.	
Information sources	0				
Applicable project type	0				
Applicable Standards	a				
	b				
	c				
	d				
Information Submittals	e				
	f				
#REF!	Total Project	Score			
Negative	A building log is not maintained, or it is only sporadically maintained.	-1			
Acceptable practice	A building log is continuously maintained, but only a few key parameters are covered, such as energy and water consumption.	0			
Good Practice	A building log is continuously maintained, and contents include all key operating parameters, as well as most relevant supporting data.	3			
Best Practice	A building log is continuously maintained, and contents include all key operating parameters, as well as most relevant supporting data. The log is maintained in a software form that collects operating data from the BMS system.	5			

Benchmarks E for designated occupancies in BigTown, Europe		Uses included	Small Industrial		
			Office		
			0		
New Construction	Design Phase	Generic		.	
E4.6 Skills and knowledge of operating staff.					
Indicator	To increase the probability that tenants and occupants will operate building systems under their control in an efficient manner. This probability will be increased if incentives are built into sales or lease agreements.		Applicable phases (Active if green)		
	The presence of sales agreements or leases that will incent owners or tenants to operate the facilities efficiently.		Dsn	Ops.	
	Information sources 0				
	Applicable project type All occupancies				
	Assessment method Review of proposed lease agreements to ascertain incentives and disincentives for efficient day-to-day management.				
	a				
	Applicable Standards b				
	c				
	d				
	Information Submittals e				
	f				
	#REF!	Total Project			Score
	Negative	Sales agreements or leases will contain no information relating to efficient building operations and heating, cooling and power costs are paid by the building owner.			-1
	Acceptable practice	Planned leases will require tenants to pay directly for heating, cooling and electric power usage.			0
Good Practice	Planned leases will require tenants to pay directly for heating, cooling and electric power usage and information is provided about performance requirements and recommended practices.			3	
Best Practice	Planned leases will require tenants to pay directly for heating, cooling and electric power usage, information is provided about performance requirements and recommended practices and performance incentives are provided.			5	

Benchmarks F for designated occupancies in BigTown, Europe		Uses included	Small Industrial	
			Office	
			0	
New Construction	Design Phase		Generic	.
F Social and Economic aspects				●
F1 Social Aspects			●	●
F1.1 Minimization of construction accidents.				
Intent	To minimize accidents causing injury or death to construction workers.		Applicable phases (Active if green)	
Indicator	Target rate for accidents on the jobsite requiring hospitalization per 100,000 hours worked.	Dsn		Ops.
Information sources	0			
Applicable project type	0			
Assessment method	Review of construction management plans by specialist in construction safety.			
Applicable Standards	a			
	b			
	c			
	d			
Information Submittals	e			
	f			
Total project	Total Project		Rate	Score
Negative			0.60	-1
Acceptable practice	Target rate for accidents on the jobsite requiring hospitalization per 100,000 hours worked is :		0.50	0
Good Practice			0.20	3
Best Practice			0.00	5

rejected in Glasgow, because considered as mandatory

Benchmarks F for designated occupancies in BigTown, Europe				Uses included	Small Industrial	
					Office	
					0	
New Construction	Design Phase			Generic		.
F1.2 Access for physically handicapped persons.						
	Intent	To assess the relative ease of access and use of facilities for persons with physical handicaps.			Applicable phases (Active if green)	
	Indicator	The scope and quality of design measures planned to facilitate access and use of building facilities by handicapped persons.			Dsn	Ops.
	Information sources	0				
	Applicable project type	By separate occupancies				
	Assessment method	Review of construction documents by a specialist in universal access design.				
	Applicable Standards	a				
		b				
		c				
		d				
	Information Submittals	e				
		f				
Occupancy 1	Small Industrial				On	Score
Negative	Design documentation indicates that not all key facilities in the occupancy, including entry points, washrooms and vertical circulation systems, are accessible to wheelchair users and visually impaired persons.					-1
Acceptable practice	Design documentation indicates that all key facilities in the occupancy, including entry points, washrooms and vertical circulation systems, are accessible to wheelchair users and visually impaired persons.					0
Good Practice	Design documentation indicates that all key facilities in the occupancy, including entry points, washrooms, vertical circulation systems and support facilities, are accessible to wheelchair users and visually impaired persons.					3
Best Practice	Same as Good Practice.					5
Occupancy 2	Office				on	Score
Negative	Design documentation indicates that not all key facilities in the occupancy, including entry points, washrooms and vertical circulation systems, are accessible to wheelchair users and visually impaired persons.					-1
Acceptable practice	Design documentation indicates that all key facilities in the occupancy, including entry points, washrooms and vertical circulation systems, are accessible to wheelchair users and visually impaired persons.					0
Good Practice	Design documentation indicates that all key facilities in the occupancy, including entry points, washrooms, vertical circulation systems and support facilities, are accessible to wheelchair users and visually impaired persons.					3
Best Practice	Same as Good Practice.					5

Benchmarks F for designated occupancies in BigTown, Europe					Uses included	Small Industrial				
						Office				
						0				
New Construction		Design Phase			Generic		.			
F1.3 Access to views from work areas.										
	Intent	To assess the extent to which the distance from a workstation to the exterior and the interior organization of the space does not limit visual access to exterior views.			Applicable phases (Active if green)					
	Indicator	Distance of the most remote workstation in a typical primary occupancy from exterior windows; and the extent to which interior organization provides exterior views.			Dsn			Ops.		
	Information sources	0								
	Applicable project type	For non-residential occupancies, all sizes.								
	#REF!	Review of analysis prepared by the design team.								
	Applicable Standards	a								
		b								
		c								
		d								
	Information Submittals	e								
		f								
	Occupancy 1	Small Industrial			on	m.	Score	Values proposed by JMH	instead of	Source
	Negative					11	-1		11	
	Acceptable practice	The maximum distance from the most remote work location in a typical primary occupancy to exterior windows is :				10	0		10	
	Good Practice					6	3		6	
	Best Practice					4	5		4	
	Occupancy 2	Office			On	m.	Score	Values proposed by JMH	instead of	Source
	Negative					11	-1		11	
	Acceptable practice	The maximum distance from the most remote work location in a typical primary occupancy to exterior windows is :				10	0		10	
	Good Practice					6	3		6	
	Best Practice					4	5		4	
F1.4 Social utility of primary building function								rejected in Glasgow		
	Intent	To assess the extent to which the primary occupancy function of the project satisfies basic societal needs.			Applicable phases (Active if green)					
	Indicator	The degree of social relevance of the primary occupancy.			Dsn			Ops.		
	Information sources	0								
	Applicable project type	All occupancies								
	Assessment method	Review of planned primary occupancy type by expert panel that includes a sociologist and an economist.								
	Applicable Standards	a								
		b								
		c								
		d								
	Information Submittals	e								
		f								
	Total project	Total Project					Score			
	Negative	The planned primary occupancy serves a function that will work against regional social values or stability.					-1			
	Acceptable practice	The planned primary occupancy serves a function that is not likely to have either a negative or positive impact on regional social values or stability.					0			
	Good Practice	The planned primary occupancy serves a function that is likely to have a positive impact on regional social values or stability.					3			
	Best Practice	The planned primary occupancy serves a function that is likely to have a very positive impact on regional social values or stability.					5			

Benchmarks F for designated occupancies in BigTown, Europe				Uses included	Small Industrial		
					Office		
					0		
New Construction	Design Phase			Generic		.	
F2 Cost and Economics				<div></div>		<div></div>	
F2.1 Minimization of life-cycle cost.							
Intent	To assess the level of total Life Cycle Cost of the project			Applicable phases (Active if green)			
	Indicator	Predicted Life Cycle Cost over a 25-year period, with calculations carried out in accordance with recognized procedures.		Dsn		Ops.	
Information sources	0						
Applicable project type	0						
Assessment method	Review of LCC analysis by a qualified cost consultant.						
Applicable Standards	a						
	b						
	c						
	d						
Information Submittals	e						
	f						
Occupancy 1	Small Industrial	on	EUR per m2	Score	Values proposed by JMH	instead of	Source
Negative			9 880	-1		9 880	
Acceptable practice	The maximum distance from the most remote work location in a typical primary occupancy to exterior windows is :		9 500	0		9 500	
Good Practice			8 360	3		8 360	
Best Practice			7 600	5		7 600	
Occupancy 2	Office	on	EUR per m2	Score	Values proposed by JMH	instead of	Source
Negative			12 840	-1		12 840	
Acceptable practice	The maximum distance from the most remote work location in a typical primary occupancy to exterior windows is :		12 000	0		12 000	
Good Practice			9 480	3		9 480	
Best Practice			7 800	5		7 800	
F2.2 Minimization of construction cost.							
Intent	To assess the difference between the capital cost of the Design with that of a reference building designed according to standards of Acceptable Practice.			Applicable phases (Active if green)			
	Indicator	Predicted construction cost per unit area, according to design documentation.		Dsn		Ops.	
Information sources	0						
Applicable project type	For individual occupancies, all sizes						
Assessment method	Review of cost analysis by a qualified cost consultant.						
Applicable Standards	a						
	b						
	c						
	d						
Information Submittals	e						
	f						
Occupancy 1	Small Industrial	on	EUR/m2	Score	Values proposed by JMH	instead of	Source
Negative			2 100	-1		2 100	BEP : ?
Acceptable practice	The maximum distance from the most remote work location in a typical primary occupancy to exterior windows is :		2 000	0		2 000	BEP : ?
Good Practice			1 700	3		1 700	BEP : ?
Best Practice			1 500	5		1 500	BEP : ?
Occupancy 2	Office	on	EUR per m2	Score	Values proposed by JMH	instead of	Source
Negative			1 120	-1		1 120	BEP : ?
Acceptable practice	The maximum distance from the most remote work location in a typical primary occupancy to exterior windows is :		1 100	0		1 100	BEP : ?
Good Practice			1 040	3		1 040	BEP : ?
Best Practice			1 000	5		1 000	BEP : ?

Benchmarks F for designated occupancies in BigTown, Europe		Uses included	Small Industrial
			Office
			0
New Construction	Design Phase	Generic	.

Benchmarks F for designated occupancies in BigTown, Europe				Uses included	Small Industrial			
					Office			
					0			
New Construction	Design Phase			Generic	.			
F2.3 Minimization of operating and maintenance cost.								
	Intent	To assess the difference between the operating cost of the Design with that of a reference building designed according to standards of Acceptable Practice.			Applicable phases (Active if green)			
	Indicator	Operating cost per unit area for energy, water & maintenance, according to design documentation.			Dsn	Ops.		
	Information sources	The operating cost of a high-performance building should be substantially less than Acceptable Practice, primarily because of reduced energy, water and equipment maintenance costs.						
	Applicable project type	For individual occupancies, all sizes						
	Assessment method	Review of operating cost projections by a cost consultant and a person knowledgeable in building operations.						
	Applicable Standards	a						
		b						
		c						
		d						
	Information Submittals	e						
		f						
	Occupancy 1	Small Industrial	on	EUR per m2	Score	Values proposed by JMH	instead of Source	
	Negative				17	-1	17	BEP : ?
	Acceptable practice	The maximum distance from the most remote work location in a typical primary occupancy to exterior windows is :			15	0	15	BEP : ?
	Good Practice				11	3	11	BEP : ?
Best Practice				8	5	8	BEP : ?	
Occupancy 2	Office	on	EUR per m2	Score	Values proposed by JMH	instead of Source		
Negative				6	-1	6	BEP : ?	
Acceptable practice	The maximum distance from the most remote work location in a typical primary occupancy to exterior windows is :			5	0	5	BEP : ?	
Good Practice				3	3	3	BEP : ?	
Best Practice				2	5	2	BEP : ?	
F2.5 Support of Local Economy.								
	Intent	To encourage the purchase of a significant level of construction goods and services within the economic region.			Applicable phases (Active if green)			
	Indicator	Prediction of the percentage of construction expenditures for goods and services going to firms with permanent offices in the urban region.			Dsn	Ops.		
	Information sources	0						
	Applicable project type	For Total Project, all sizes.						
	#REF!	Review of expenditure program and sample analysis of material billing to verify costs.						
	Applicable Standards	a						
		b						
		c						
		d						
	Information Submittals	e						
		f						
	Total project	Total Project		Percent	Score	Values proposed by JMH	instead of Source	
	Negative				44%	-1	44%	BEP : ?
	Acceptable practice	The maximum distance from the most remote work location in a typical primary occupancy to exterior windows is :			50%	0	50%	BEP : ?
	Good Practice				68%	3	68%	BEP : ?
Best Practice				80%	5	80%	BEP : ?	

based on cost, construction , labour %

Benchmarks B for designated occupancies in BigTown, Europe			Uses included	Small Industrial	
				Office	
				0	
New Construction	Design Phase		Generic	.	
B Energy and Resource Consumption				<div></div>	
B1 Total Life Cycle Non-Renewable Energy				<div></div>	<div></div>
B1.1 Annualized non-renewable primary energy embodied in construction materials.					
Intent	To minimize the embodied primary energy used in the building, annualized over the estimated lifespan of the building.		Applicable phases (Active if green)		
	Indicator	Estimate of embodied primary energy used for structure, envelope (excl. glazing), and major interior components, as determined by a program designed to estimate embodied energy and emissions through Life Cycle Analysis; also, estimate of lifespan.		Dsn	Ops.
Information sources		Note that minimization of embodied energy may not always be optimal. For example, the greater embodied energy associated with high thermal mass will, in most cases, reduce operating energy, and the total net lifecycle energy could then be reduced.		<div></div>	<div></div>
	Applicable project type	All occupancies	Assumed lifespan in years	50	
Assessment method		Use an embodied energy estimating system, based on LCA (Life Cycle Assessment). Alternatively, use the crude estimating method provided in this system.			
	Applicable Standards	a			
b					
c					
d					
Information Submittals	e				
	f				
Occupancy 1	Small Industrial	GJ/m2	MJ/m2 per yr.	Score	Data to be received from Italian team
Negative		8.6	172	-1	
Acceptable practice	The predicted embodied energy for materials used in the structure and building envelope as determined an acceptable LCA-based estimating method :	8.0	160	0	
Good Practice		6.2	124	3	
Best Practice		5.0	100	5	
Occupancy 2	Office	GJ/m2	MJ/m2 per yr.	Score	Data to be received from Italian team
Negative		12.6	252	-1	
Acceptable practice	The predicted embodied energy for materials used in the structure and building envelope as determined an acceptable LCA-based estimating method :	12.0	240	0	
Good Practice		10.2	204	3	
Best Practice		9.0	180	5	

Data to be received from Italian team

Data to be received from Italian team

Benchmarks B for designated occupancies in BigTown, Europe				Uses included	Small Industrial	
					Office	
					0	
New Construction	Design Phase			Generic	.	
B1.2 Annual non-renewable primary energy used for facility heating						
Intent	To minimize the amount of non-renewable energy (not including on-site renewable energy) used annually for building operations, commensurate with functional needs.			Applicable phases (Active if green)		
	Indicator	MJ of delivered energy per m2 of net area, including fuel and electrical use, as predicted by means of an acceptable method or tool.				Dsn
Information sources		See IEA.org for data and case studies.			●	●
Applicable project type	Any occupancy except for Open Space					M
Assessment method	During early design stages a screening tool may be used, but in later stages an hour-by-hour simulation program should be used. Benchmarks for Ops should be derived from operational data for the relevant occupancy types, after a period of occupancy of at least one year. Note that benchmarks should be set using Delivered energy data, since this is what is commonly available. SBTool applies a conversion factor to these values to convert them to primary energy for the Results.					
	Applicable Standards	a				
b						
c						
d						
Information Submittals	e					
	f					
Occupancy 1	Small Industrial		Elec. MJ/m2 per yr	Total MJ/m2 per yr	Score	Values proposed by JMH instead of Source
Negative			540	1460	-1	1 460
Acceptable practice	MJ of delivered non-renewable energy per m2 of net area used for operations, as predicted by means of an acceptable method or tool.		500	1300	0	1 300
Good Practice			380	820	3	820
Best Practice			300	500	5	144 MJ/m2 500 IBGE 40 kWh/m2 = 144 MJ/m2
Occupancy 2	Office		Elec. MJ/m2 per yr	MJ/m2 per yr.	Score	Values proposed by JMH instead of Source
Negative			320	375	-1	375
Acceptable practice	MJ of delivered non-renewable energy per m2 of net area used for operations, as predicted by means of an acceptable method or tool.		300	350	0	350
Good Practice			240	275	3	275
Best Practice			200	225	5	54 MJ/m2 225 IBGE 15 kWh/m2 = 54 MJ/m2
B1.3 Annual non-renewable primary energy used for facility cooling						
Intent	To minimize the amount of non-renewable energy (not including on-site renewable energy) used annually for building operations, commensurate with functional needs.			Applicable phases (Active if green)		
	Indicator	MJ of delivered energy per m2 of net area, including fuel and electrical use, as predicted by means of an acceptable method or tool.				Dsn
Information sources		See IEA.org for data and case studies.			●	●
Applicable project type	Any occupancy except for Open Space					
Assessment method	During early design stages a screening tool may be used, but in later stages an hour-by-hour simulation program should be used. Benchmarks for Ops should be derived from operational data for the relevant occupancy types, after a period of occupancy of at least one year. Note that benchmarks should be set using Delivered energy data, since this is what is commonly available. SBTool applies a conversion factor to these values to convert them to primary energy for the Results.					
	Applicable Standards	a				
b						
c						
d						
Information Submittals	e					
	f					
Occupancy 1	Small Industrial		Elec. MJ/m2 per yr	Total MJ/m2 per yr	Score	Values proposed by JMH instead of Source
Negative			540	1460	-1	1 460
Acceptable practice	MJ of delivered non-renewable energy per m2 of net area used for operations, as predicted by means of an acceptable method or tool.		500	1300	0	1 300
Good Practice			380	820	3	820
Best Practice			300	500	5	152 MJ:m2 500 IBGE 45 kWh/m2 = 152 MJ/m2
Occupancy 2	Office		Elec. MJ/m2 per yr	MJ/m2 per yr.	Score	Values proposed by JMH instead of Source
Negative			320	375	-1	375
Acceptable practice	MJ of delivered non-renewable energy per m2 of net area used for operations, as predicted by means of an acceptable method or tool.		300	350	0	350
Good Practice			240	275	3	275
Best Practice			200	225	5	152 MJ:m2 225 IBGE 45 kWh/m2 = 152 MJ/m2

Benchmarks B for designated occupancies in BigTown, Europe				Uses included	Small Industrial				
					Office				
					0				
New Construction	Design Phase			Generic	.				
B1.4 Annual non-renewable primary energy used for lighting and equipment									
Intent	To minimize the amount of non-renewable energy (not including on-site renewable energy) used annually for building operations, commensurate with functional needs.			Applicable phases (Active if green)					
	Indicator	MJ of delivered energy per m2 of net area, including fuel and electrical use, as predicted by means of an acceptable method or tool.				Dsn	Ops.		
Information sources		See IEA.org for data and case studies.			●	●	●		
Applicable project type	Any occupancy except for Open Space					M			
Assessment method	During early design stages a screening tool may be used, but in later stages an hour-by-hour simulation program should be used. Benchmarks for Ops should be derived from operational data for the relevant occupancy types, after a period of occupancy of at least one year. Note that benchmarks should be set using Delivered energy data, since this is what is commonly available. SBTool applies a conversion factor to these values to convert them to primary energy for the Results.								
Applicable Standards	a								
	b								
	c								
	d								
Information Submittals	e								
	f								
Occupancy 1	Small Industrial			Elec. MJ/m2 per yr	Total MJ/m2 per yr	Score	Values proposed by JMH	instead of	Source
Negative				540	1460	-1		1 460	
Acceptable practice	MJ of delivered non-renewable energy per m2 of net area used for operations, as predicted by means of an acceptable method or tool.			500	1300	0		1 300	
Good Practice				380	820	3		820	
Best Practice				300	500	5		500	IBGE 2 W/m2*1600h/an*3.6/1000=11.5 MJ/m2
Occupancy 2	Office			Elec. MJ/m2 per yr	MJ/m2 per yr.	Score	Values proposed by JMH	instead of	Source
Negative				320	375	-1		375	
Acceptable practice	MJ of delivered non-renewable energy per m2 of net area used for operations, as predicted by means of an acceptable method or tool.			300	350	0		350	
Good Practice				240	275	3		275	
Best Practice				200	225	5		225	IBGE 2 W/m2*1600h/an*3.6/1000=11.5 MJ/m2
B2 Electrical peak demand for facility operations				●	●				
Intent	To minimize the peak monthly electrical demand for building operations, especially where the grid is near peak capacity.			Applicable phases (Active if green)					
	Indicator	Average of peak monthly electrical demand for one year, W/m2, as predicted by means of an acceptable method or tool.				Dsn	Ops.		
Information sources		References x, y and z							
Applicable project type	Any occupancy except open space								
Assessment method	Review of contract documentation and sample equipment specifications by an outside electrical engineer.								
Applicable Standards	a								
	b								
	c								
	d								
Information Submittals	e								
	f								
Occupancy 1	Small Industrial			on	W/m2	Score	Values proposed by JMH	instead of	Source
Negative					6	-1	6	6	o.k. with proposal
Acceptable practice	The peak monthly electrical demand for the occupancy, as predicted by means of an acceptable method or tool.				5	0	5	5	o.k. with proposal
Good Practice					3	3	3	3	o.k. with proposal
Best Practice					2	5	2	2	o.k. with proposal
Occupancy 2	Office			on	W/m2	Score	Values proposed by JMH	instead of	Source
Negative					0	-1		0	BEP : ?
Acceptable practice	The peak monthly electrical demand for the occupancy, as predicted by means of an acceptable method or tool.					0			BEP : ?
Good Practice					0	3		0	BEP : ?
Best Practice						5			BEP : ?

Benchmarks B for designated occupancies in BigTown, Europe				Uses included	Small Industrial		
					Office		
					0		
New Construction	Design Phase			Generic			
B3 Renewable Energy				<div></div>	<div></div>		
B3.1 Use of off-site energy that is generated from renewable sources.							
	Intent	To encourage the use of sources that generate power by renewable energy means, e.g. 'green power'.			Applicable phases (Active if green)		
	Indicator	Percent of annual purchased electricity consumption for the Total Building that is planned to be obtained from sources that generate power by means of renewable energy.				DsnOps.	
	Information sources	NABERS (Australian system) defines Acceptable Practice as 20% and Best Practice as 100%, whereas HK-BEAM equivalents are 4% and 20% and BREEAM specifies a threshold of 10%.			Available from grid, per Emission worksheet0.0%		
	Applicable project type	Any occupancy where renewable sources are available.					
	Assessment method	Review of contract documentation and sample equipment specifications by an outside electrical engineer.					
	Applicable Standards	a					
		b					
		c					
		d					
	Information Submittals	e					
		f					
	Total project	Total project			Percent	Score	Values proposed by JMHinstead ofSource
	Negative				0%	-1	0%0%o.k. with proposal
	Acceptable practice	The percent of annual purchased electricity consumption planned to be obtained from sources that generate power by means of renewable energy :			0%	0	0%0%o.k. with proposal
	Good Practice				30%	3	30%30%o.k. with proposal
	Best Practice				50%	5	50%50%o.k. with proposal
B3.2 Provision of on-site renewable energy systems.							
	Intent	To encourage the use of on-site renewable energy systems.			Applicable phases (Active if green)		
	Indicator	The amount of energy intended to be contributed by renewable energy systems, in MJ/m2 per year, not including daylighting or Ground Source Heat Pumps (GSHP).				DsnOps.	
	Information sources	We suggest a higher level for Residential and Schools than for Office, because of possibility of using renewable sources for pre-heating Hot Water. E-Benchmark suggests a minimum of 10% and LEED ranges from 5% to 20%.					
	Applicable project type	Any occupancy except Enclosed Parking and Open Space.					
	Assessment method	Review of contract documentation and sample equipment specifications by an outside electrical engineer with renewables expertise.					
	Applicable Standards	a					
		b					
		c					
		d					
	Information Submittals	e					
		f					
	Occupancy 1	Total project			M	MJ/m2 per yr.	ScoreValues proposed by JMHinstead ofSource
	Negative					40	-14040o.k. with proposal
	Acceptable practice	The predicted annual contribution of on-site renewable energy planned for operations, as per drawings and specifications :				50	05050o.k. with proposal
	Good Practice					80	38080o.k. with proposal
	Best Practice					100	5100100o.k. with proposal

Benchmarks B for designated occupancies in BigTown, Europe			Uses included	Small Industrial			
				Office			
				0			
New Construction	Design Phase		Generic		.		
B4 Materials			<div></div>	<div></div>			
B4.1 Re-use of suitable existing structure(s).							
	Intent	To encourage the re-use of any sound structures that exist on the site, as part of the new project.		Applicable phases (Active if green)			
	Indicator	The development of an inventory and the percent, by area, of an existing structure that is re-used or recycled, where the structures are in usable condition.		Dsn	C&C.	Ops.	
	Information sources	0					
	Applicable project type	Any occupancy, where an existing structure in usable condition is located on the site.					
	#REF!	If there is an existing structure on the site, the basis of assessment should be a report that provides a structural, functional and economic assessment of the existing structure, carried out by a team of qualified professionals.					
	Applicable Standards	a					
		b					
		c					
		d					
	Information Submittals	e					
		f					
	Total project	Total project			Percent by area	Score	Not applicable in the context of Cralys
	Negative				13%	-1	
	Acceptable practice	The percentage (by area) of existing sound structures that is planned to be re-used as part of the project :			25%	0	
	Good Practice				61%	3	
	Best Practice				85%	5	
B4.2 Use of recycled materials from off-site sources.							
	Intent	To encourage the use of recycled materials from off-site sources as part of the new facility, where they are suitable.		Applicable phases (Active if green)			
	Indicator	The percentage, by cost, of the materials, products, and furnishings in the project are recycled from off-site sources.		Dsn	C&C.	Ops.	
	Information sources	LEED ranges from 25% to 50%.					
	Applicable project type	Total building.					
	#REF!	Review of contract documentation by an outside materials specialist.					
	Applicable Standards	a					
		b					
		c					
		d					
	Information Submittals	e					
		f					
	Total project	Total Project			% by cost	Score	Data to be received from Italian team
	Negative				7%	-1	
	Acceptable practice	The percentage (by cost) of the materials, products, and furnishings in the project that are made from materials that recycled from off-site post-consumer sources :			10%	0	
	Good Practice				19%	3	
	Best Practice				25%	5	

Benchmarks B for designated occupancies in BigTown, Europe				Uses included	Small Industrial				
					Office				
					0				
New Construction	Design Phase			Generic	.				
B4.3 Use of bio-based products obtained from sustainable sources.									
	Intent	To encourage the use of bio-based products that are certified by a recognized certification agency as coming from renewable sources, or the equivalent.			Applicable phases (Active if green)				
	Indicator	The percentage, by cost, of bio-based products used in the building, including wood and agricultural products, that are certified by a recognized certification agency.			Dsn	C&C.	Ops.		
	Information sources	0							
	Applicable project type	Total building, all sizes.							
	Assessment method	Review of contract documentation by an outside materials specialist.							
	Applicable Standards	a							
		b							
		c							
		d							
	Information Submittals	e							
		f							
	Total project	Total Project			Percent by cost	Score	Data to be received from Italian team		
	Negative				9%	-1			
	Acceptable practice	The percentage (by cost) of the wood-based products in the building certified by a recognized certification agency as coming from renewable sources :			10%	0			
	Good Practice				13%	3			
	Best Practice				15%	5			
B4.4 Use of cement supplementing materials in concrete.									
	Intent	To encourage the use of cement supplementing materials in concrete, such as flyash, steel slag or rice ash, in order to reduce GHG emissions from the use of cement.			Applicable phases (Active if green)				
	Indicator	The percentage, by volume, of cement substitute used in concrete.			Dsn	C&C.	Ops.		
	Information sources	Note that up to 50% of CSM has been used, but curing time increases with volume used. Typical industry utilisation ranges from 15% to 25%.							
	Applicable project type	0							
	Assessment method	Review of contract documentation by an outside concrete specialist.							
	Applicable Standards	a							
		b							
		c							
		d							
	Information Submittals	e							
		f							
	Total project	Total Project			% by vol.	Score	Values proposed by JMH	instead of	Source
	Negative				2%	-1	0%	2%	
	Acceptable practice	The percentage, by volume, of an acceptable cement supplementing material used in concrete :			10%	0	0%	10%	No law constraint
	Good Practice				34%	3	10%	34%	
	Best Practice				50%	5	25%	50%	

Benchmarks B for designated occupancies in BigTown, Europe				Uses included	Small Industrial				
					Office				
					0				
New Construction	Design Phase			Generic	.				
B4.5 Use of materials that are locally produced.									
	Intent	To encourage the procurement of high-weight materials such as aggregate, sand, concrete, masonry, steel and glass, from sources within the greater urban region.			Applicable phases (Active if green)				
	Indicator	The percentage, by weight, of the aggregate, sand, concrete, masonry, steel and glass used in the project produced within the greater urban region, if local sources of acceptable quality are available.			Dsn	C&C.	Ops.		
	Information sources	LEED specifies specific distances, but we consider that this is not applicable to all areas.							
	Applicable project type	Total building, all sizes.							
	Assessment method	Review of contract documentation by an outside materials specialist.							
	Applicable Standards	a							
		b							
		c							
		d							
	Information Submittals	e							
		f							
	Total project	Total Project			% by weight	Score	Values proposed by JMH	instead of	Source
	Negative				42%	-1		42%	
	Acceptable practice	The percentage, by weight, of the aggregate, sand, concrete, masonry, steel and glass used in the project produced within the greater urban region :			50%	0		50%	No law constraint
	Good Practice				74%	3		74%	
	Best Practice				90%	5		90%	
B4.6 Design for disassembly, re-use or recycling.									
	Intent	To encourage a building design that will facilitate the easy dis-assembly of components so that they can be re-used or recycled at the end of the service life of the components.			Applicable phases (Active if green)				
	Indicator	Measures taken to facilitate future disassembly and re-use or recycling.			Dsn	C&C.	Ops.		
	Information sources	0							
	Applicable project type	Total building							
	Assessment method	Review of contract documentation by an outside deconstruction specialist.							
	Applicable Standards	a							
		b							
		c							
		d							
	Information Submittals	e							
		f							
	Total project	Total Project				Score			
	Negative	No measures have been taken to facilitate future disassembly, re-use or recycling.				-1			
	Acceptable practice	Limited measures have been taken to facilitate future disassembly, re-use or recycling, such as the use of modular interior partitions and other interior components.				0			
	Good Practice	Measures have been taken to facilitate future disassembly, re-use or recycling, such as the use of modular interior components and the use of bolted structural or building envelope components.				3			
	Best Practice	Extensive measures have been taken to facilitate future disassembly, re-use or recycling, such as the use of modular interior components, the use of bolted structural or building envelope components, and the non-use of composite or bonded materials.				5			

Benchmarks B for designated occupancies in BigTown, Europe				Uses included	Small Industrial				
					Office				
					0				
New Construction	Design Phase			Generic	.				
B5 Potable Water				<div></div>	<div></div>				
B5.1 Use of potable water for site irrigation.									
Intent	To discourage the use of potable water for irrigation; and to ensure that any potable water used for irrigation purposes during dry seasons is minimal.			Applicable phases (Active if green)					
	Indicator	The development of a credible irrigation management plan for areas landscaped with non-native species (excluding stored rainwater or greywater used for this purpose).		Dsn	C&C.	Ops.			
Information sources	0								
Applicable project type	Total project								
Assessment method	Review pf landscaping plans by an outside landscape architect.								
Applicable Standards	a								
	b								
	c								
	d								
Information Submittals	e								
	f								
Total project	Total Project			M ³ / m ²	Score	Values proposed by JMH	instead of	Source	
Negative				4.8	-1	5%	4.8	o.k. with proposal	
Acceptable practice	The predicted net annual potable water volume used for irrigation of areas landscaped with non-native species (excluding stored rainwater or greywater used for this purpose) :			4.0	0	4%	4.0	o.k. with proposal	
Good Practice				1.6	3	2%	1.6	o.k. with proposal	
Best Practice				0.0	5	0%	0.0	o.k. with proposal	
B5.2 Use of potable water for building and occupancy needs.									
Intent	To minimize the amount of potable water imported to the site and used for occupancy needs, excluding building system uses or irrigation of exterior areas.			Applicable phases (Active if green)					
	Indicator	Prediction of total potable water use, in L per person per day, based on a credible water management plan for occupancy fixtures and use. Note that the benchmarks are expressed as L / m2 per year in order to allow uses such as indoor parking to be compared to other uses such as office or residential.		Dsn	C&C.	Ops.			
Information sources	See File C for fixtures and water consumption data for the specific project.			<div></div>					
Applicable project type	By separate occupancies, excluding irrigation water for outdoor areas.								
Assessment method	Review of contract documentation by a specialist in water use.								
Applicable Standards	a								
	b								
	c								
	d								
Information Submittals	e								
	f								
Occupancy 1	Small Industrial			on	L / m2 per year	Score	Values proposed by JMH	instead of	Source
Negative					1600	-1		1 600	BEP : ?
Acceptable practice	Based on a credible water management plan, the volume of potable water predicted to be used for occupancy needs :				1500	0		1 500	BEP : ?
Good Practice					1200	3		1 200	BEP : ?
Best Practice					1000	5		1 000	BEP : ?
Occupancy 2	Office			on	L / m2 per year	Score	Values proposed by JMH	instead of	Source
Negative					215	-1		215	BEP : ?
Acceptable practice	Based on a credible water management plan, the volume of potable water predicted to be used for occupancy needs :				200	0		200	BEP : ?
Good Practice					155	3		155	BEP : ?
Best Practice					125	5		125	BEP : ?

Benchmarks C for designated occupancies in BigTown, Europe				Uses included	Small Industrial	
					Office	
					0	
New Construction	Design Phase			Generic	.	
C Environmental Loadings					<div></div>	
C1 Greenhouse Gas Emissions					<div></div>	<div></div>
C1.1 Annualized GHG emissions embodied in construction materials.						
Intent	To minimize the amount of CO2-equivalent emissions from primary non-renewable energy used in the extraction, fabrication and transportation of materials and components in the building.			Applicable phases (Active if green)		
	Indicator	CO2-equivalent emissions per Kg. per m2 of gross area, as determined by calculations based on design documents and fuel emission values plus process-related emissions related to the region of production, and annualized according to the predicted lifespan of the building.			Dsn	
Information sources		Benchmarks for GJ/m2 are the same as those selected for Benchmark B1.1. Values in BREEAM range from about 1000 to 300 kgCO2/m2 for Residential, and 100 to 500 kgCO2/m2f or offices (not annualized).			Assumed lifespan in years, from Basic worksheet	
	Applicable project type	All occupancies			kg eCO2 per embodied GJ	
Assessment method	We recommend that this analysis be carried out only with new projects, since there are likely to be insurmountable difficulties in obtaining emission data for materials that are located in an existing building.					
	Applicable Standards	a				
b						
c						
d						
Information Submittals	e					
	f					
Occupancy 1	Small Industrial			GJ/m2	kg/m2 * year	Score
Negative				8.6	9.5	-1
Acceptable practice	The annualized amount of CO2-equivalent emissions from primary non-renewable energy used in materials and components for structure and building envelope, based on design documents :			8.0	8.8	0
Good Practice				6.2	6.8	3
Best Practice				5.0	5.5	5
Occupancy 2	Office			GJ/m2	kg/m2 * year	Score
Negative				12.6	13.9	-1
Acceptable practice	The annualized amount of CO2-equivalent emissions from primary non-renewable energy used in materials and components for structure and building envelope, based on design documents :			12.0	13.2	0
Good Practice				10.2	11.2	3
Best Practice				9.0	9.9	5

Lifespan = 35 years (Glasgow meeting)

Data to be received from Italian team

Data to be received from Italian team

Benchmarks C for designated occupancies in BigTown, Europe				Uses included	Small Industrial				
					Office				
					0				
New Construction	Design Phase			Generic					
C1.2 Annual GHG emissions from all energy used for facility heating.									
Intent	To minimize the amount of CO2-equivalent emissions from all energy used for annual building operations.			Applicable phases (Active if green)					
	Indicator	Annual CO2-equivalent emissions per Kg. per m2 of net area, as determined by an hour-by-hour simulation program and calculations based on regional fuel emission values.			Dsn		Ops.		
Information sources		Values in the UK BREEAM system range from 167 to 30 kgCO2/m2 for Residential, 250 to 20 kgCO2/m2 for Office and about 48 to 17 kgCO2/m2 for Schools.							
	Emissions for Residential taken from average Canadian building stock values for 1999 (NRCan data).			Est. kg CO2 per GJ, Small Industrial	55.0				
	Emissions for Commercial taken from average Canadian building stock values for 1999 (NRCan data).			Est. kg CO2 per GJ, Office	55.0				
	0			Est. kg CO2 per GJ, 0	55.0				
	Applicable project type			All occupancies except open space					
Assessment method	The use of an hour-by-hour simulation tool, as required for B1.2, will produce annual energy consumption results. These data are combined by SBTool with emission data (see Emissions worksheet) to produce estimates of operating emissions.			Values below are based on B1.2 in BmkB					
	a								
Applicable Standards	b								
	c								
	d								
Information Submittals	e								
	f								
Occupancy 1	Small Industrial			M	kg/m2 per yr.	Score	Values proposed by JMH	instead of	Source
Negative					80	-1		80	
Acceptable practice	Based on the results of an hour-by-hour simulation program and regional fuel emission values, the amount of CO2-equivalent emissions from primary non-renewable energy used for annual operations of the occupancy is predicted to be :				72	0		72	
Good Practice					45	3		45	
Best Practice					28	5		28	
Occupancy 2	Office			M	kg/m2 per yr.	Score	Values proposed by JMH	instead of	Source
Negative					21	-1		21	
Acceptable practice	Based on the results of an hour-by-hour simulation program and regional fuel emission values, the amount of CO2-equivalent emissions from primary non-renewable energy used for annual operations of the occupancy is predicted to be :				19	0		19	
Good Practice					15	3		15	
Best Practice					12	5		12	

Benchmarks C for designated occupancies in BigTown, Europe				Uses included	Small Industrial				
					Office				
					0				
New Construction	Design Phase			Generic	.				
C1.3 Annual GHG emissions from all energy used for facility cooling.									
Intent	To minimize the amount of CO2-equivalent emissions from all energy used for annual building operations.			Applicable phases (Active if green)					
	Indicator	Annual CO2-equivalent emissions per Kg. per m2 of net area, as determined by an hour-by-hour simulation program and calculations based on regional fuel emission values.			Dsn		Ops.		
Information sources		Values in the UK BREEAM system range from 167 to 30 kgCO2/m2 for Residential, 250 to 20 kgCO2/m2 for Office and about 48 to 17 kgCO2/m2 for Schools.							
	Emissions for Residential taken from average Canadian building stock values for 1999 (NRCan data).			Est. kg CO2 per GJ, Small Industrial	55.0				
	Emissions for Commercial taken from average Canadian building stock values for 1999 (NRCan data).			Est. kg CO2 per GJ, kg/m2 per yr.	55.0				
	0			Est. kg CO2 per GJ, 0	55.0				
Applicable project type	All occupancies except open space			Values below are based on B1.2 in BmkB					
Assessment method	The use of an hour-by-hour simulation tool, as required for B1.2, will produce annual energy consumption results. These data are combined by SBTool with emission data (see Emissions worksheet) to produce estimates of operating emissions.								
Applicable Standards	a	Text to be revised							
	b								
	c								
	d								
Information Submittals	e								
	f								
Occupancy 1	Small Industrial			M	kg/m2 per yr.	Score	Values proposed by JMH	instead of	Source
Negative					80	-1		80	
Acceptable practice	Based on the results of an hour-by-hour simulation program and regional fuel emission values, the amount of CO2-equivalent emissions from primary non-renewable energy used for annual operations of the occupancy is predicted to be :				72	0		72	
Good Practice					45	3		45	
Best Practice					28	5		28	
Occupancy 2	Office			M	kg/m2 per yr.	Score	Values proposed by JMH	instead of	Source
Negative					21	-1		21	
Acceptable practice	Based on the results of an hour-by-hour simulation program and regional fuel emission values, the amount of CO2-equivalent emissions from primary non-renewable energy used for annual operations of the occupancy is predicted to be :				19	0		19	
Good Practice					15	3		15	
Best Practice					12	5		12	

Benchmarks C for designated occupancies in BigTown, Europe				Uses included	Small Industrial				
					Office				
					0				
New Construction	Design Phase			Generic		.			
C1.4 Annual GHG emissions from all energy used for lighting and equipment.									
Intent	To minimize the amount of CO2-equivalent emissions from all energy used for annual building operations.			Applicable phases (Active if green)					
	Indicator	Annual CO2-equivalent emissions per Kg. per m2 of net area, as determined by an hour-by-hour simulation program and calculations based on regional fuel emission values.			Dsn		Ops.		
Information sources		Values in the UK BREEAM system range from 167 to 30 kgCO2/m2 for Residential, 250 to 20 kgCO2/m2 for Office and about 48 to 17 kgCO2/m2 for Schools.							
	Emissions for Residential taken from average Canadian building stock values for 1999 (NRCan data).			Est. kg CO2 per GJ, Small Industrial	55.0				
	Emissions for Commercial taken from average Canadian building stock values for 1999 (NRCan data).			Est. kg CO2 per GJ, kg/m2 per yr.	55.0				
	0			Est. kg CO2 per GJ, 20.625	55.0				
	All occupancies except open space			Values below are based on B1.2 in BmkB					
Applicable project type									
Assessment method	The use of an hour-by-hour simulation tool, as required for B1.2, will produce annual energy consumption results. These data are combined by SBTool with emission data (see Emissions worksheet) to produce estimates of operating emissions.								
Applicable Standards	a	Text to be revised							
	b								
	c								
	d								
Information Submittals	e								
	f								
Occupancy 1	Small Industrial			M	kg/m2 per yr.	Score	Values proposed by JMH	instead of	Source
Negative					80	-1		80	
Acceptable practice	Based on the results of an hour-by-hour simulation program and regional fuel emission values, the amount of CO2-equivalent emissions from primary non-renewable energy used for annual operations of the occupancy is predicted to be :				72	0		72	
Good Practice					45	3		45	
Best Practice					28	5		28	
Occupancy 2	Office			M	kg/m2 per yr.	Score	Values proposed by JMH	instead of	Source
Negative					21	-1		21	
Acceptable practice	Based on the results of an hour-by-hour simulation program and regional fuel emission values, the amount of CO2-equivalent emissions from primary non-renewable energy used for annual operations of the occupancy is predicted to be :				19	0		19	
Good Practice					15	3		15	
Best Practice					12	5		12	

Benchmarks C for designated occupancies in BigTown, Europe				Uses included	Small Industrial	
					Office	
					0	
New Construction	Design Phase			Generic		
C2 Other Atmospheric Emissions						
C2.1 Emissions of acidifying emissions during facility operations.						
Intent	To minimize the production of atmospheric emissions from building operations that may result in acidification.			Applicable phases (Active if green)		SO2 (not emitted anymore) replaced by NOx
Indicator	SO2 Equiv. per year in kg. per unit net area			Dsn	Ops.	
Information sources	References x, y and z				M	
Applicable project type	Total project					
#REF	Review of contract documents and equipment specifications.					
Applicable Standards	a					
	b					
	c					
	d					
Information Submittals	e					
	f					
Total project	Total Project			Kg. / m2 per yr.	Score	Values proposed by JMH
Negative				0.45	-1	instead of
Acceptable practice	The predicted emission of SO2 equivalent per year in kg. per unit area net, based on the results of an acceptable hour-by-hour simulation program and taking into account the characteristics of available fuels :			0.40	0	Source
Good Practice				0.25	3	
Best Practice				0.15	5	
C2.2 Emissions leading to photo-oxidants during facility operations.						
Intent	To minimize the production of atmospheric emissions from building operations that may result in photo-oxidants.			Applicable phases (Active if green)		
Indicator	Ethene equiv. per year in gm per net unit area			Dsn	Ops.	
Information sources	References x, y and z					
Applicable project type	Total project					
Assessment method	Review of contract documents and equipment specifications.					
Applicable Standards	a					
	b					
	c					
	d					
Information Submittals	e					
	f					
Total project	Total Project			gm./m2 per yr.	Score	Values proposed by JMH
Negative				0.278	-1	instead of
Acceptable practice	The predicted emission of Ethene equivalent per year in gm. per net unit area, based on the results of an acceptable hour-by-hour simulation program, and taking into account the characteristics of available fuels :			0.250	0	Source
Good Practice				0.166	3	
Best Practice				0.110	5	

Benchmarks C for designated occupancies in BigTown, Europe				Uses included	Small Industrial	
					Office	
					0	
New Construction	Design Phase			Generic	.	
C3 Solid Wastes				<div></div>	<div></div>	
C3.1 Solid waste resulting from the construction and demolition process.						
Intent	To minimize the amount of waste off the site by encouraging the development and implementation of a construction waste management program, with sorting, re-use and recycling measures.			Applicable phases (Active if green)		
Indicator	The development of a credible construction waste management plan and the percentage, by weight, of construction waste to be re-used (on or off the site) or re-cycled, as predicted in the plan.			Dsn	C&C.	Ops.
Information sources	It is assumed that a construction waste management plan is developed, and construction waste is sorted, with specific amounts recorded.					
Applicable project type	Total Project					
Assessment method	Review of construction management plan by an outside party with construction and solid waste management expertise.					
Applicable Standards	a					
	b					
	c					
	d					
Information Submittals	e					
	f					
Total project	Total Project			Percent	Score	Values proposed by JMH
Negative				-7%	-1	instead of
Acceptable practice	The percentage, by weight, of construction waste to be re-used (on or off the site) or re-cycled, as predicted in the construction waste management plan :			10%	0	7%
Good Practice				61%	3	10%
Best Practice				95%	5	61%
C3.2 Solid waste resulting from facility operations.						
Intent	To encourage the provision of facilities for storage of waste on each floor or each major work area, and space for the central sorting and storage of waste, with access to a truck loading area.			Applicable phases (Active if green)		
Indicator	Facilities provided in the design for the storage and sorting of solid wastes in both dispersed and central locations.			Dsn		Ops.
Information sources	We specify storage areas per dwelling and per work group, and assume that the central storage area will be sized to suit.					
Applicable project type	Separate criteria for residential and non-residential; NA for parking or open space					
Assessment method	Review of construction documents by an outside party with solid waste management expertise.					
Applicable Standards	a					
	b					
	c					
	d					
Information Submittals	e					
	f					
Occupancy 1	Small Industrial	on	percent	Score	Values proposed by JMH	instead of
Negative				70%	-1	70%
Acceptable practice	A central sorting and storage area is located close to a truck loading area, and storage has been provided sufficient for all wastes that may accumulate over a period of one week. It is estimated			75%	0	75%
Good Practice	that the percentage of total waste that can be sorted and			89%	3	89%
Best Practice				98%	5	98%
Occupancy 2	Office	on	percent	Score	Values proposed by JMH	instead of
Negative				70%	-1	70%
Acceptable practice	A central sorting and storage area is located close to a truck loading area, and storage has been provided sufficient for all wastes that may accumulate over a period of one week. It is estimated			75%	0	75%
Good Practice	that the percentage of total waste that can be sorted and			90%	3	90%
Best Practice				100%	5	100%

Benchmarks C for designated occupancies in BigTown, Europe		Uses included	Small Industrial	
			Office	
			0	
New Construction	Design Phase	Generic	.	

Benchmarks C for designated occupancies in BigTown, Europe				Uses included	Small Industrial				
					Office				
					0				
New Construction	Design Phase			Generic		.			
C4 Rainwater, Stormwater and Wastewater				<div></div>		<div></div>			
C4.1 Liquid effluents from facility operations sent off the site.									
Intent	To minimize the volume of waste water, including effluent, sent off the site to be treated.			Applicable phases (Active if green)					
	Indicator	The volume of liquid waste per person per day that is sent off the site for treatment.		Dsn		Ops.			
Information sources	The default (0) volume is assumed to be 95% of the potable water consumption with no on-site treatment, as per BmkA 5.2 (see cells at right)			1425	190	0			
Applicable project type	By separate occupancies.								
Assessment method	Review of contract documents.								
Applicable Standards	a								
	b								
	c								
	d								
Information Submittals	e								
	f								
Occupancy 1	Small Industrial			on	L / m2 * yr.	Score	Values proposed by JMH	instead of	Source
Negative					1520	-1		1 520	
Acceptable practice					1425	0		1 425	
Good Practice	The predicted volume of liquid waste per m2 per year to be sent off the site for treatment				1140	3		1 140	
Best Practice					950	5		950	
Occupancy 2	Office			on	L / m2 * yr.	Score	Values proposed by JMH	instead of	Source
Negative					204	-1		204	
Acceptable practice					190	0		190	
Good Practice	The predicted volume of liquid waste per m2 per year to be sent off the site for treatment				147	3		147	
Best Practice					119	5		119	
C4.2 Retention of rainwater for later re-use.									
Intent	To encourage the retention of rainwater on the site for later re-use.			Applicable phases (Active if green)					
	Indicator	The percent of annual rainwater falling on the site that is planned to be retained on the site for future use on the site or in the building in holding ponds or tanks.		Dsn		Ops.			
Information sources	References x, y and z								
Applicable project type	Total project								
Assessment method	Review of contract documents and landscaping plans by a person with experience in this field.								
Applicable Standards	a								
	b								
	c								
	d								
Information Submittals	e								
	f								
Total project	Total Project			Percent	Score	Values proposed by JMH	instead of	Source	
Negative					0%	-1		0%	
Acceptable practice					0%	0		0%	
Good Practice	The percent of annual rainwater falling on the site that is predicted to be retained on the site for future use on the site or in the building in holding ponds or tanks.				45%	3		45%	
Best Practice					75%	5		75%	

Benchmarks C for designated occupancies in BigTown, Europe				Uses included	Small Industrial				
					Office				
					0				
New Construction	Design Phase			Generic		.			
C4.3 Untreated stormwater retained on the site.									
	Intent	To minimize the volume of stormwater sent off the site.			Applicable phases (Active if green)				
	Indicator	Percent of stormwater that is retained on the site.			Dsn	Ops.			
	Information sources	References x, y and z							
	Applicable project type	By separate occupancies.							
	Assessment method	Review of contract documents and landscaping plans by a person with experience in this field.							
	Applicable Standards	a							
		b							
		c							
		d							
	Information Submittals	e							
		f							
	Total project	Total Project			Percent	Score	Values proposed by JMH	instead of	Source
	Negative				10%	-1		10%	
	Acceptable practice				25%	0		25%	
	Good Practice	The percent of stormwater retained on the site, on an annualized basis:			70%	3		70%	
	Best Practice				100%	5		100%	
N.A.	N.A.								
N.A. N.A.									
					Applicable phases (Active if green)				
		N.A. N.A.			Dsn	C&C.	Ops.		
		N.A. N.A.							
		N.A. N.A.							
		N.A. N.A.							
		N.A. N.A.							
		N.A. N.A.							
		N.A. N.A.							
		N.A. N.A.							
		N.A. N.A.							
		N.A. N.A.							
		N.A. N.A.							
		N.A. N.A.							
		N.A. N.A.							
		N.A. N.A.							
		N.A. N.A.							
		N.A. N.A.							

Benchmarks C for designated occupancies in BigTown, Europe		Uses included	Small Industrial		
			Office		
			0		
New Construction	Design Phase		Generic		.
N.A. N.A.					
	N.A.	N.A.	Applicable phases (Active if green)		
	N.A.	N.A.	Dsn	C&C.	Ops.
	N.A.	N.A.			
	N.A.	N.A.			
	N.A.	N.A.			
	N.A.	N.A.			
	N.A.	N.A.			
	N.A.	N.A.			
	N.A.	N.A.			
	N.A.	N.A.			
	N.A.	N.A.			
	N.A.	N.A.			
	N.A.	N.A.	Score		
	N.A.	N.A.	-1		
	N.A.	N.A.	0		
	N.A.	N.A.	3		
N.A.	N.A.	5			
N.A. N.A.					
	N.A.	N.A.	Applicable phases (Active if green)		
	N.A.	N.A.	Dsn	C&C.	Ops.
	N.A.	N.A.			
	N.A.	N.A.			
	N.A.	N.A.			
	N.A.	N.A.			
	N.A.	N.A.			
	N.A.	N.A.			
	N.A.	N.A.			
	N.A.	N.A.			
	N.A.	N.A.			
	N.A.	N.A.			
	N.A.	N.A.	Score		
	N.A.	N.A.	-1		
	N.A.	N.A.	0		
	N.A.	N.A.	3		
N.A.	N.A.	5			

Benchmarks C for designated occupancies in BigTown, Europe			Uses included	Small Industrial		
				Office		
				0		
New Construction	Design Phase		Generic		.	
N.A. N.A.						
	N.A.	N.A.	Applicable phases (Active if green)			
	N.A.	N.A.	Dsn		Ops.	
	N.A.	N.A.	●			
	N.A.	N.A.				
	N.A.	N.A.				
	N.A.	N.A.				
	N.A.	N.A.				
	N.A.	N.A.				
	N.A.	N.A.				
	N.A.	N.A.				
	N.A.	N.A.				
	N.A.	N.A.	Score			
	N.A.	N.A.	-1			
	N.A.	N.A.	0			
	N.A.	N.A.	3			
N.A.	N.A.	5				
C6 Other Local and Regional Impacts			●	●	Not applicable (decided in Glasgow)	
C6.1 Cumulative thermal changes to lake water or sub-surface aquifers.						
	Intent	To ensure that building operations involving ground-source or ground-water heat pumps do not change the average annual temperature of sub-surface aquifers, nor affect the water quality of such aquifers.		Applicable phases (Active if green)		
	Indicator	Predictions of changes in the average annual temperature of sub-surface aquifers, determined by simulation studies.		Dsn	Ops.	
	Information sources	References x, y and z				
	Applicable project type	For Total Project if a water-source or ground-source heat pumps (GSHP) is being used.				
	#REF!	Review of mechanical drawings, specifications and equipment by geophysical engineer.				
	Applicable Standards	a				
		b				
		c				
		d				
	Information Submittals	e				
		f				
	Total project	Total Project			Deg. C	Score
	Negative				1.8	-1
	Acceptable practice	Studies predict that operations of ground-source or ground-water heat pumps may change the average annual temperature of sub-surface aquifers by :			1.5	0
	Good Practice				0.6	3
Best Practice				0.0	5	

Benchmarks C for designated occupancies in BigTown, Europe			Uses included	Small Industrial	
				Office	
				0	
New Construction	Design Phase		Generic		.
C6.2 Heat Island Effect - landscaping and paved areas.					Not applicable to Crealys context
Intent	To ensure that open areas of the site are either landscaped, or are paved with reflective materials, to minimize infrared re-radiation to the atmosphere that would increase the urban heat island effect.		Applicable phases (Active if green)		
Indicator	Reflectance and area of paved and landscaped areas, as indicated by drawings and specifications.		Dsn		Ops.
Information sources	References x, y and z				
Applicable project type	Total Project				
Assessment method	Review of landscaping plans and design team analysis.				
Applicable Standards	a				
	b				
	c				
	d				
Information Submittals	e				
	f				
Total project	Total Project		Percent	Score	
Negative			40%	-1	
Acceptable practice	Drawings and specifications indicate that the area of landscaped open area plus paved areas with a surface reflectance of 60% or greater, as a percentage of total open area (site area minus building footprint) is :		50%	0	
Good Practice			80%	3	
Best Practice			100%	5	
C6.3 Heat Island Effect - roofing.					Not applicable to Crealys context
Intent	To encourage the use of roofing systems with high reflectance or a landscaped or green roof, or a combination of these, so that reflected infrared radiation to the atmosphere is minimized.		Applicable phases (Active if green)		
Indicator	Reflectance and area of roofing material; or the use of a green roof, as indicated by drawings and specifications.		Dsn		Ops.
Information sources	References x, y and z				
Applicable project type	Total Project				
Assessment method	Review of roofing specifications.				
Applicable Standards	a				
	b				
	c				
	d				
Information Submittals	e				
	f				
Total project	Total Project		Percent	Score	
Negative			0%	-1	
Acceptable practice	According to drawings and specifications, the percentage of total roof area provided with a Green roof or a roofing system with a surface reflectance of 60%, or a combination of these, is :		0%	0	
Good Practice			60%	3	
Best Practice			100%	5	

Benchmarks C for designated occupancies in BigTown, Europe			Uses included	Small Industrial		
				Office		
				0		
New Construction	Design Phase		Generic	.		
C6.4 Atmospheric light pollution.					Not applicable to Crealys context	
	Intent	To minimize the spillage of light into the atmosphere from ground-level sources.		Applicable phases (Active if green)		
	Indicator	Percentage of total exterior light output that lies outside a vertical 120 degree cone, as indicated by drawings and specifications.		Dsn		Ops.
	Information sources	0				
	Applicable project type	Total Project				
	Assessment method	Review of building and site illumination plans and design team analysis.				
	Applicable Standards	a				
		b				
		c				
		d				
	Information Submittals	e				
		f				
	Total project	Total Project			Percent	Score
	Negative				90%	-1
	Acceptable practice	The percentage of total exterior light output that lies outside a vertical 120 degree cone, as indicated by drawings and specifications is :			75%	0
	Good Practice				30%	3
	Best Practice				0%	5

Benchmarks D for designated occupancies in BigTown, Europe		Uses included	Small Industrial
			Office
			0
New Construction	Design Phase	Generic	.

D Indoor Environmental Quality	●
D1 Indoor Air Quality	● ●

D1.1 Pollutant migration between occupancies.				
Intent	Ensure that areas that contain equipment or activities generating chemical pollutants, are separately ventilated and isolated from other occupied spaces. Examples include copier rooms, waste storage areas and janitorial rooms.		Applicable phases (active if green)	
Indicator	Measures taken to isolate areas or rooms where pollutants may be generated, as indicated by drawings and specifications.		Dsn	Ops.
Information sources	0		●	
Applicable project type	Separate by occupancy type.			
#REF	Review of contract documents and mechanical system by an outside mechanical engineer.			
Applicable Standards	a			
	b			
	c			
	d			
Information Submittals	e			
	f			
Occupancy 1	Small Industrial	on	Score	
Negative	Drawings and specifications indicate that some rooms and spaces in this occupancy that contain equipment or activities generating chemical pollutants are not separately ventilated.			-1
Acceptable practice	Drawings and specifications indicate that all rooms and spaces in this occupancy that contain equipment or activities generating chemical pollutants, are separately ventilated.			0
Good Practice	Drawings and specifications indicate that all rooms and spaces in this occupancy that contain equipment or activities generating chemical pollutants, are separately ventilated and there is little possibility of migration to or from other occupied spaces.			3
Best Practice	Drawings and specifications indicate that all rooms and spaces in this occupancy that contain equipment or activities generating chemical pollutants, are separately ventilated and there is NO possibility of migration to or from other occupied spaces.			5
Occupancy 2	Office	on	Score	
Negative	Drawings and specifications indicate that some rooms and spaces in this occupancy that contain equipment or activities generating chemical pollutants are not separately ventilated.			-1
Acceptable practice	Drawings and specifications indicate that all rooms and spaces in this occupancy that contain equipment or activities generating chemical pollutants, are separately ventilated.			0
Good Practice	Drawings and specifications indicate that all rooms and spaces in this occupancy that contain equipment or activities generating chemical pollutants, are separately ventilated and there is little possibility of migration to or from other occupied spaces.			3
Best Practice	Drawings and specifications indicate that all rooms and spaces in this occupancy that contain equipment or activities generating chemical pollutants, are separately ventilated and there is NO possibility of migration to or from other occupied spaces.			5

D1.2 CO2 concentrations in indoor air.				
Intent	To ensure that carbon dioxide concentrations stay below acceptable levels in typical primary occupancy areas.		Applicable phases (active if green)	
Indicator	Designs for HVAC systems that conform to ASHRAE, CIBSE or other acceptable protocol.		Dsn	Ops.
Information sources	Reference x, y and z			
Applicable project type	Non-residential Occupancies, except for Open Space.			
Assessment method	Review of contract documents and mechanical system by an outside mechanical engineer.			
Applicable Standards	a			
	b			
	c			
	d			
Information Submittals	e			
	f			
Occupancy 1	Small Industrial	on	ppm	Score
Negative			1160	-1
Acceptable practice	Designs for HVAC systems, carried out in accordance with ASHRAE, CIBSE or other acceptable standards, predict concentrations of CO2 during operating conditions equal to or less than :		1050	0
Good Practice			720	3
Best Practice			500	5
Occupancy 2	Office	on	ppm	Score
Negative			640	-1
Acceptable practice	Designs for HVAC systems, carried out in accordance with ASHRAE, CIBSE or other acceptable standards, predict concentrations of CO2 during operating conditions equal to or less than :		600	0
Good Practice			480	3
Best Practice			400	5

Values proposed by JMH	instead of	Source: EN 13 779
1 000	1 000	1 200
800	800	800
700	700	500
600	600	350
Values proposed by JMH	instead of	Source: EN 13 779
1 000	1 000	1 200
800	800	800
500	700	500
350	600	350

Benchmarks D for designated occupancies in BigTown, Europe			Uses included	Small Industrial	
				Office	
				0	
New Construction	Design Phase		Generic		
D1.3 IAQ monitoring during project operations.					
	Intent	To ensure long-term indoor air quality in non-residential occupancies by installing a permanent carbon dioxide monitoring system to provide objective data on indoor air quality, with monitoring points located in typical primary occupancy areas.		Applicable phases (active if green)	
	Indicator	Measures anticipated to ensure adequate monitoring of IAQ quality.		Dsn	Ops.
	Information sources	Reference A, B and C.			
	Applicable project type	By separate occupancies except outdoor space.			
	Assessment method	Review of contract documents and mechanical system by an outside mechanical engineer.			
	Applicable Standards	a			
		b			
		c			
		d			
	Information Submittals	e			
		f			
	Occupancy 1	Small Industrial		on	Score
	Negative	No specific measures are anticipated to ensure adequate and on-going monitoring of IAQ quality in public areas.			-1
	Acceptable practice	Annual monitoring is anticipated to assess IAQ quality in public areas.			0
	Good Practice	Quarterly monitoring is anticipated to assess IAQ quality in public areas.			3
	Best Practice	Daily monitoring is anticipated to assess IAQ quality in public areas.			5
	Occupancy 2	Office		on	Score
	Negative	No specific measures are anticipated to ensure adequate and on-going monitoring of IAQ quality in public areas.			-1
	Acceptable practice	Annual monitoring is anticipated to assess IAQ quality in public areas.			0
	Good Practice	Quarterly monitoring is anticipated to assess IAQ quality in public areas.			3
	Best Practice	Daily monitoring is anticipated to assess IAQ quality in public areas.			5
D2 Ventilation					
D2.1 Effectiveness of ventilation in naturally ventilated occupancies.					
	Intent	To ensure that the number, placement and type of windows or other openings in a naturally-ventilated building are capable of providing a high level of air quality and ventilation.		Applicable phases (active if green)	
	Indicator	Area and location of windows that provide natural ventilation.		Dsn	Ops.
	Information sources	Cross-ventilation is defined as spaces where openable windows are located on at least two separate walls.			
	Applicable project type	By separate occupancies for buildings under a defined height limit.		Height limit, floors	16
	Assessment method	Review of contract documents and mechanical system by an outside mechanical engineer with specific knowledge of natural ventilation issues.			
	Applicable Standards	a			
		b			
		c			
		d			
	Information Submittals	e			
		f			
	Occupancy 1	Small Industrial		M	Score
	Negative	The aggregate area of openings from primary occupancy areas to the exterior is less than 5% of the aggregate primary floor area, and less than 50% of all primary spaces have cross-ventilation.			-1
	Acceptable practice	The aggregate area of openings from primary occupancy areas to the exterior is at least 5% of the aggregate primary floor area, and more than 50% of all primary spaces have cross-ventilation.			0
	Good Practice	The aggregate area of openings from primary occupancy areas to the exterior is at least 5% of the aggregate primary floor area, and at more than 75% of all primary spaces have cross-ventilation.			3
	Best Practice	The aggregate area of openings from primary occupancy areas to the exterior is at least 10% of the aggregate primary floor area, and more than 90% of all primary spaces have cross-ventilation.			5
	Occupancy 2	Office		M	Score
	Negative	The aggregate area of openings from primary occupancy areas to the exterior is less than 5% of the aggregate primary floor area, and less than 50% of all primary spaces have cross-ventilation.			-1
	Acceptable practice	The aggregate area of openings from primary occupancy areas to the exterior is at least 5% of the aggregate primary floor area, and more than 50% of all primary spaces have cross-ventilation.			0
	Good Practice	The aggregate area of openings from primary occupancy areas to the exterior is at least 5% of the aggregate primary floor area, and at more than 75% of all primary spaces have cross-ventilation.			3
	Best Practice	The aggregate area of openings from primary occupancy areas to the exterior is at least 10% of the aggregate primary floor area, and more than 90% of all primary spaces have cross-ventilation.			5

Benchmarks D for designated occupancies in BigTown, Europe			Uses included
			Small Industrial
			Office
			0
New Construction	Design Phase	Generic	.

D2.2 Air quality and ventilation in mechanically ventilated occupancies.				
	Intent	To ensure that mechanical ventilation and cooling systems are designed in a manner that will ensure a satisfactory level of air quality and ventilation.		Applicable phases (active if green)
	Indicator	Conformance of the design to the requirements of a recognized relevant standard, such as ASHRAE or CIBSE.		Dsn Ops.
	Information sources	Reference x, y and z		
	Applicable project type	Any occupancy except Outdoor Area		
	Assessment method	Review of contract documents and mechanical system by an outside mechanical engineer.		
	Applicable Standards	a		
		b		
		c		
		d		
	Information Submittals	e		
		f		
	Occupancy 1	Small Industrial	M	Score
	Negative	Mechanical ventilation in some primary occupancy areas does not fully satisfy the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.		-1
	Acceptable practice	Mechanical ventilation in some primary occupancy areas meets the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.		0
	Good Practice	Mechanical ventilation in more than 50% of primary occupancy areas exceeds the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.		3
	Best Practice	Mechanical ventilation in 100% of primary occupancy areas exceeds the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.		5
	Occupancy 2	Office	M	Score
	Negative	Mechanical ventilation in some primary occupancy areas does not fully satisfy the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.		-1
	Acceptable practice	Mechanical ventilation in some primary occupancy areas meets the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.		0
	Good Practice	Mechanical ventilation in more than 50% of primary occupancy areas exceeds the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.		3
	Best Practice	Mechanical ventilation in 100% of primary occupancy areas exceeds the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.		5

D2.3 Air movement in mechanically ventilated occupancies.				
	Intent	To ensure that air movement in mechanically ventilated occupancies is sufficient to satisfy requirements for human comfort.		#REF!
	Indicator	Predicted air speed in m/s, as indicated by an analysis of proposed HVAC system characteristics or by post-occupancy monitoring.		Dsn Ops.
	Information sources	Reference x, y and z		
	Applicable project type	Total project		
	Assessment method	Review of contract documents and mechanical system by an outside mechanical engineer.		
	Applicable Standards	a		
		b		
		c		
		d		
	Information Submittals	e		
		f		
	Occupancy 1	Small Industrial	on	m/s Score
	Negative			0.0 -1
	Acceptable practice	An analysis of proposed HVAC system characteristics indicates that air speed at working level during typical operating conditions is likely to be :		0.0 0
	Good Practice			0.0 3
	Best Practice			0.0 5
	Occupancy 2	Office	on	m/s Score
	Negative			1.2 -1
	Acceptable practice	An analysis of proposed HVAC system characteristics indicates that air speed at working level during typical operating conditions is likely to be :		1.5 0
	Good Practice			2.4 3
	Best Practice			3.0 5

Values proposed by JMH	instead of	Source
	0.0	
	0.0	
	0.0	
	0.0	
	1.2	
	1.5	
	2.4	
	3.0	

Benchmarks D for designated occupancies in BigTown, Europe		Uses included	Small Industrial
			Office
			0
New Construction	Design Phase	Generic	.

Benchmarks D for designated occupancies in BigTown, Europe		Uses included	Small Industrial
			Office
			0
New Construction	Design Phase	Generic	

D2.3 Air movement in mechanically ventilated occupancies.				
	Intent	To ensure that mechanical ventilation and cooling systems are designed in a manner that will ensure a satisfactory level of air quality and ventilation.		Applicable phases (active if green)
	Indicator	Conformance of the design to the requirements of a recognized relevant standard, such as ASHRAE or CIBSE.		Dsn Ops.
	Information sources	Reference x, y and z		
	Applicable project type	Any occupancy except Outdoor Area		
	#REF!	Review of contract documents and mechanical system by an outside mechanical engineer.		
	Applicable Standards	a		
		b		
		c		
		d		
	Information Submittals	e		
		f		
	Occupancy 1	Small Industrial	M	Score
	Negative	Mechanical ventilation in some primary occupancy areas does not fully satisfy the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.		-1
	Acceptable practice	Mechanical ventilation in some primary occupancy areas meets the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.		0
	Good Practice	Mechanical ventilation in more than 50% of primary occupancy areas exceeds the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.		3
	Best Practice	Mechanical ventilation in 100% of primary occupancy areas exceeds the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.		5
	Occupancy 2	Office	M	Score
	Negative	Mechanical ventilation in some primary occupancy areas does not fully satisfy the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.		-1
	Acceptable practice	Mechanical ventilation in some primary occupancy areas meets the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.		0
	Good Practice	Mechanical ventilation in more than 50% of primary occupancy areas exceeds the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.		3
	Best Practice	Mechanical ventilation in 100% of primary occupancy areas exceeds the minimum requirements of ASHRAE 62-2001: Ventilation for Acceptable Indoor Air Quality or the equivalent CIBSE or other standard.		5

D2.4 Effectiveness of ventilation in mechanically ventilated occupancies.				
	Intent	Ensure, through the use of appropriate simulation programs, that the ventilation system in mechanically-ventilated non-residential occupancies will bring ventilation air to where it is needed, i.e. to seating areas or workers or visitors.		Applicable phases (active if green)
	Indicator	Percent of ventilation air reaching work surfaces, as indicated by an analysis of proposed HVAC system and room characteristics.		Dsn Ops.
	Information sources	Reference x, y and z		
	Applicable project type	Non-residential Occupancies.		
	Assessment method	Review of contract documents and mechanical system by an outside mechanical engineer.		
	Applicable Standards	a		
		b		
		c		
		d		
	Information Submittals	e		
		f		
	Occupancy 1	Small Industrial	on	Eac Score
	Negative	An analysis of proposed HVAC system and room characteristics in mechanically ventilated areas of the occupancy indicates that the air change effectiveness (Eac), as determined by ASHRAE 129 -1997 or equivalent CIBSE or other standard, of :		80% -1
	Acceptable practice	An analysis of proposed HVAC system and room characteristics in mechanically ventilated areas of the occupancy indicates that the air change effectiveness (Eac), as determined by ASHRAE 129 -1997 or equivalent CIBSE or other standard, of :		80% 0
	Good Practice	An analysis of proposed HVAC system and room characteristics in mechanically ventilated areas of the occupancy indicates that the air change effectiveness (Eac), as determined by ASHRAE 129 -1997 or equivalent CIBSE or other standard, of :		89% 3
	Best Practice	An analysis of proposed HVAC system and room characteristics in mechanically ventilated areas of the occupancy indicates that the air change effectiveness (Eac), as determined by ASHRAE 129 -1997 or equivalent CIBSE or other standard, of :		95% 5
	Occupancy 2	Office	on	Eac Score
	Negative	An analysis of proposed HVAC system and room characteristics in mechanically ventilated areas of the occupancy indicates that the air change effectiveness (Eac), as determined by ASHRAE 129 -1997 or equivalent CIBSE or other standard, of :		80% -1
	Acceptable practice	An analysis of proposed HVAC system and room characteristics in mechanically ventilated areas of the occupancy indicates that the air change effectiveness (Eac), as determined by ASHRAE 129 -1997 or equivalent CIBSE or other standard, of :		80% 0
	Good Practice	An analysis of proposed HVAC system and room characteristics in mechanically ventilated areas of the occupancy indicates that the air change effectiveness (Eac), as determined by ASHRAE 129 -1997 or equivalent CIBSE or other standard, of :		89% 3
	Best Practice	An analysis of proposed HVAC system and room characteristics in mechanically ventilated areas of the occupancy indicates that the air change effectiveness (Eac), as determined by ASHRAE 129 -1997 or equivalent CIBSE or other standard, of :		95% 5

Values proposed by JMH	instead of	Source
80%	80%	o.k. with proposal
80%	80%	o.k. with proposal
89%	89%	o.k. with proposal
95%	95%	o.k. with proposal
Values proposed by JMH	instead of	Source
80%	80%	o.k. with proposal
80%	80%	o.k. with proposal
89%	89%	o.k. with proposal
95%	95%	o.k. with proposal

Benchmarks D for designated occupancies in BigTown, Europe				Uses included	Small Industrial			
					Office			
					0			
New Construction		Design Phase		Generic				
D3 Air Temperature and Relative Humidity								
D3.1 Air temperature and relative humidity in mechanically heated occupancies.								
Intent	To ensure acceptable temperature and humidity control within established ranges per climate zone, and to provide on-going monitoring of thermal comfort performance and the effectiveness of humidification and/or dehumidification system.			Applicable phases (active if green)				
	Indicator	Compliance of mechanical ventilation systems with recognized design standards such as ASHRAE or CIBSE.			Dsn		Ops.	
		Information sources			Reference x, y and z			
	Applicable project type			All mechanically ventilated occupancies.				
	#REF!			Review of contract documents and mechanical system by an outside mechanical engineer.				
	Applicable Standards	a						
		b			text to be revised			
		c						
		d						
	Information Submittals	e						
		f						
Occupancy 1	Small Industrial			on	Score	Values proposed by JMH	instead of	Source
Negative	The mechanical system design does not comply with ASHRAE 55-1992, or other similar standard such as CIBSE, or the variation from setpoints exceeds 5 deg. C.			-1		≥ 19°C	< 5°C	
Acceptable practice	The mechanical system design complies with ASHRAE 55-1992, or complies with other similar standard such as CIBSE. Temperature variation from setpoints does not exceed 3 deg. C.			0		≥ 21°C	< 3°C	RGPT
Good Practice	The mechanical system design complies with ASHRAE 55-1992, or complies with other similar standard such as CIBSE. Temperature variation from setpoints does not exceed 2 deg. C.			3		≥ 23°C	< 2°C	intermediate value between neighbor ones
Best Practice	The mechanical system design complies with ASHRAE 55-1992, or complies with other similar standard such as CIBSE. A permanent monitoring system provides feedback on temperature and humidity conditions. Temperature variation from setpoints does not exceed 1 deg. C.			5		≤ 25°C	< 1°C	smallest PPD as possible
D3.2 Air temperature and relative humidity in mechanically cooled occupancies.								
Intent	To ensure acceptable temperature within established ranges per climate zone in naturally ventilated occupancies.			Applicable phases (active if green)				
	Indicator	Predicted ability of natural ventilation systems to maintain temperatures within an acceptable range, as indicated by drawings and specifications.			Dsn		Ops.	
		Information sources			ASHRAE 55-1992, Addenda 1995 or equivalent CIBSE or other recognized standard.			
	Applicable project type			Total project				
	Assessment method			Review of contract documents and mechanical system by an outside mechanical engineer with specific knowledge of natural ventilation issues.				
	Applicable Standards	a						
		b			text to be revised			
		c						
		d						
	Information Submittals	e						
		f						
Total project	Total Project			Score	Values proposed by JMH	instead of	Source	
Negative	According to recognized predictive techniques, the temperature in primary occupancy areas can NOT be kept, for more than 90% of occupied hours, within a swing range (+ or -) of 6 deg. C.			-1	≤ 28°C	90% in range of 6°C	ASHRAE	
Acceptable practice	According to recognized predictive techniques, the temperature in primary occupancy areas can be kept, for more than 90% of occupied hours, within a swing range (+ or -) of 4 deg. C.			0	≤ 24°C	90% in range of 4°C	RGPT	
Good Practice	According to recognized predictive techniques, the temperature in primary occupancy areas can be kept, for more than 90% of occupied hours, within a swing range (+ or -) of 3 deg. C.			3	≤ 22°C	90% in range of 3°C	intermediate value between neighbor ones	
Best Practice	According to recognized predictive techniques, the temperature in primary occupancy areas can be kept, for more than 90% of occupied hours, within a swing range (+ or -) of 2 deg. C.			5	≤ 20°C	90% in range of 2°C	smallest PPD as possible	

Benchmarks D for designated occupancies in BigTown, Europe				Uses included	Small Industrial			
					Office			
					0			
New Construction	Design Phase			Generic				
D3.3 Time lag and decrement factor								
	Intent	To ensure acceptable temperature within established ranges per climate zone in naturally ventilated occupancies.			Applicable phases (active if green)			
	Indicator	Predicted ability of natural ventilation systems to maintain temperatures within an acceptable range, as indicated by drawings and specifications.			Dsn	Ops.		
	Information sources	ASHRAE 55-1992, Addenda 1995 or equivalent CIBSE or other recognized standard.						
	Applicable project type	Total project						
	Assessment method	Review of contract documents and mechanical system by an outside mechanical engineer with specific knowledge of natural ventilation issues.						
	Applicable Standards	a						
		b	text to be revised					
		c						
		d						
	Information Submittals	e						
		f						
Total project	Total Project				Score	Values proposed by JMH	instead of	Source
Negative	According to recognized predictive techniques, the temperature in primary occupancy areas can NOT be kept, for more than 90% of occupied hours, within a swing range (+ or -) of 6 deg. C.				-1	6°C	90% in range of 6°C	o.k. with proposal and confirmed other values
Acceptable practice	According to recognized predictive techniques, the temperature in primary occupancy areas can be kept, for more than 90% of occupied hours, within a swing range (+ or -) of 4 deg. C.				0	4°C	90% in range of 4°C	RGPT : 20 to 24°C
Good Practice	According to recognized predictive techniques, the temperature in primary occupancy areas can be kept, for more than 90% of occupied hours, within a swing range (+ or -) of 3 deg. C.				3	3°C	90% in range of 3°C	intermediate value between neighbor ones
Best Practice	According to recognized predictive techniques, the temperature in primary occupancy areas can be kept, for more than 90% of occupied hours, within a swing range (+ or -) of 2 deg. C.				5	2°C	90% in range of 2°C	NEN 13 779
D3.4 Air temperature in naturally ventilated occupancies.								
	Intent	To ensure acceptable temperature within established ranges per climate zone in naturally ventilated occupancies.			Applicable phases (active if green)			
	Indicator	Predicted ability of natural ventilation systems to maintain temperatures within an acceptable range, as indicated by drawings and specifications.			Dsn	Ops.		
	Information sources	ASHRAE 55-1992, Addenda 1995 or equivalent CIBSE or other recognized standard.						
	Applicable project type	Total project						
	Assessment method	Review of contract documents and mechanical system by an outside mechanical engineer with specific knowledge of natural ventilation issues.						
	Applicable Standards	a						
		b						
		c						
		d						
	Information Submittals	e						
		f						
Total project	Total Project				Score	Values proposed by JMH	instead of	Source
Negative	According to recognized predictive techniques, the temperature in primary occupancy areas can NOT be kept, for more than 90% of occupied hours, within a swing range (+ or -) of 6 deg. C.				-1	6°C	90% in range of 6°C	o.k. with proposal and confirmed other values
Acceptable practice	According to recognized predictive techniques, the temperature in primary occupancy areas can be kept, for more than 90% of occupied hours, within a swing range (+ or -) of 4 deg. C.				0	4°C	90% in range of 4°C	RGPT : 20 to 24°C
Good Practice	According to recognized predictive techniques, the temperature in primary occupancy areas can be kept, for more than 90% of occupied hours, within a swing range (+ or -) of 3 deg. C.				3	3°C	90% in range of 3°C	intermediate value between neighbor ones
Best Practice	According to recognized predictive techniques, the temperature in primary occupancy areas can be kept, for more than 90% of occupied hours, within a swing range (+ or -) of 2 deg. C.				5	2°C	90% in range of 2°C	NEN 13 779

Benchmarks D for designated occupancies in BigTown, Europe				Uses Included	Small Industrial				
					Office				
					0				
New Construction	Design Phase			Generic					
D4 Daylighting and Illumination									
D4.1 Daylighting in primary occupancy areas.									
	Intent	To ensure an adequate level of daylighting in all primary occupied spaces.			Applicable phases (active if green)				
	Indicator	The predicted Daylight Factor in a typical occupancy area located on the ground floor of the building, as indicated by drawings and specifications.			Dsn	Ops.			
	Information sources	x							
	Applicable project type	By separate occupancies							
	Assessment method	Review of contract documents by an illumination specialist.							
	Applicable Standards	a							
		b							
		c							
		d							
	Information Submittals	e							
		f							
	Occupancy 1	Small Industrial	M	DF	Score	Values proposed by JMH	instead of	Source: littérature	
	Negative				1.8%	-1	1.0%	1.6%	circulation areas
	Acceptable practice	The predicted Daylight Factor in a typical workspace located on the ground floor of the occupancy, as indicated by drawings and specifications.			2.0%	0	2.0%	2.0%	standard workshop
	Good Practice				2.6%	3	3.0%	2.4%	(intermediate value)
	Best Practice				3.0%	5	5.0%	3.0%	for precise tasks
	Occupancy 2	Office	on	DF	Score	Values proposed by JMH	instead of		
	Negative				0.0%	-1	1.0%	0.0%	circulation areas
	Acceptable practice	The predicted Daylight Factor in a typical workspace located on the ground floor of the occupancy, as indicated by drawings and specifications.				0	2.0%		standard office
	Good Practice				0.0%	3	3.0%	0.0%	(intermediate value)
	Best Practice					5	5.0%		drawing office
D4.2 Glare in non-residential occupancies.									
	Intent	To ensure that glare conditions are minimized in main occupancy areas during periods of maximum exterior brightness, through the use of exterior or interior shading.			#REF!				
	Indicator	The predicted maximum ratio of contrast in illuminance between windows and adjacent wall areas in a typical occupancy area, as indicated by design characteristics.			Dsn	Ops.			
	Information sources	Glare shall be measured by the contrast between window areas and adjacent wall areas, as seen from the interior.							
	Applicable project type	Non-residential occupancies							
	Assessment method	Review of contract documents by an illumination specialist.							
	Applicable Standards	a							
		b							
		c							
		d							
	Information Submittals	e							
		f							
	Occupancy 1	Small Industrial	on	Ratio	Score	Values proposed by JMH	instead of	Source	
	Negative				59	-1	40	59	"Médecine et risque du travail" (Ed. Elsevier, 2003)
	Acceptable practice	The predicted maximum ratio of contrast in illuminance between windows and adjacent wall areas in a typical occupancy area, as indicated by design characteristics is :			50	0	20	50	
	Good Practice				23	3	10	23	
	Best Practice				5	5	3	5	
	Occupancy 2	Office	on	Ratio	Score	Values proposed by JMH	instead of	Source	
	Negative				59	-1	40	59	"Médecine et risque du travail" (Ed. Elsevier, 2003)
	Acceptable practice	The predicted maximum ratio of contrast in illuminance between windows and adjacent wall areas in a typical occupancy area, as indicated by design characteristics is :			50	0	20	50	
	Good Practice				23	3	10	23	
	Best Practice				5	5	3	5	

Benchmarks D for designated occupancies in BigTown, Europe				Uses included	Small Industrial	
					Office	
					0	
New Construction	Design Phase			Generic		
D4.3 Illumination levels and quality of lighting.						
	Intent	To ensure that lighting systems provide adequate illumination and quality levels in public and work areas; and that there is a capability to support the provision of suitable task lighting in work areas.			Applicable phases (active if green)	
	Indicator	Appropriateness of illumination levels and lighting quality to planned tasks, in Lux, as indicated by design characteristics.			Dsn	Ops.
	Information sources	Acceptable values range from 30 to 500 Lux for normal tasks, and up to 10,000 Lux for demanding tasks.				
	Applicable project type	Non-residential Occupancies, all sizes.				
	Assessment method	Review of contract documents, especially lighting plans and specs, by an illumination specialist.				
	Applicable Standards	a				
		b				
		c				
		d				
	Information Submittals	e				
		f				
	Occupancy 2	Office			on	Score
	Negative	The design indicates that illumination levels and quality of lighting will not be appropriate to planned tasks in the occupancy, and no provision is made for task lighting.			-1	
	Acceptable practice	The design indicates that ambient illumination systems will provide illumination levels appropriate to tasks in the occupancy, and provision is made for task lighting.			0	
	Good Practice	The design indicates that ambient illumination systems will provide illumination levels appropriate to tasks in the occupancy, dimmable ballasts are provided, and provision is made for task lighting in each 15 m2 work zone.			3	
	Best Practice	The design indicates that ambient illumination systems will provide illumination levels appropriate to tasks in the occupancy, dimmable ballasts are provided, and provision is made for task lighting in each 10 m2 work zone.			5	
D5 Noise and Acoustics						
D5.1 Noise attenuation through the exterior envelope.						
	Intent	Ensure that noise attenuation through the wall facing the noisiest site boundary is adequate to provide interior noise levels that will not interfere with normal tasks.			Applicable phases (active if green)	
	Indicator	The predicted noise attenuation performance of the exterior wall most exposed to potential sources of noise, as indicated by design characteristics.			Dsn	Ops.
	Information sources	http://greenbuildings.santa-monica.org/envelope/envventilation.html				
	Applicable project type	Total Project				
	Assessment method	Review of design team analysis by a noise specialist.				
	Applicable Standards	a				
		b				
		c				
		d				
	Information Submittals	e				
		f				
	Total project	Total Project			STC	Score
	Negative				29.7	-1
	Acceptable practice	Design documents indicate that windows in the exterior wall of the Design exposed to the most significant sources of external noise will have a Sound Transmission Class, or equivalent, of :			27.5	0
	Good Practice				34.1	3
	Best Practice				38.5	5
				Values proposed by JMH	instead of	Source
				26.0	29.7	
				29.0	27.5	standard value of STC
				34.0	34.1	acoustic glass
				41.0	38.5	2 glasses + 10 cm space between them





Benchmarks D for designated occupancies in BigTown, Europe				Uses included	Small Industrial			
					Office			
					0			
New Construction	Design Phase			Generic				
D5.2 Transmission of facility equipment noise to primary occupancies.								
Intent	To ensure that HVAC systems and equipment rooms are designed to minimize noise transmission to primary occupancies.			Applicable phases (Active if green)				
Indicator	Noise Reduction Criteria ratings of mechanical equipment and equipment rooms, as indicated by design characteristics.			Dsn		Ops.		
Information sources	Reference x, y and z."							
Applicable project type	Total project							
Assessment method	Review of contract documents and mechanical system by an outside mechanical engineer.							
Applicable Standards	a							
	b							
	c							
	d							
Information Submittals	e							
	f							
Total project	Total Project			NRC	Score	Values proposed by JMH		
Negative				37.0	-1	37.0	instead of	Source: Belgian acoustic standard
Acceptable practice	Design documents indicate that HVAC systems and equipment rooms are designed for a Noise Reduction Criteria (NRC) of :			35.0	0	29.0	35.0	normal acoustic comfort
Good Practice				29.0	3	34.0	29.0	intermediate value
Best Practice				25.0	5	41.0	25.0	superior acoustic comfort
D5.3 Noise attenuation between primary occupancy areas.								
Intent	To ensure that measures have been taken to reduce noise impacts between all tenancies and occupancy types.			Applicable phases (active if green)				
Indicator	Minimum Sound Transmission Class of partitions between primary occupancy areas, as indicated by design characteristics.			Dsn		Ops.		
Information sources	Reference x, y and z."							
Applicable project type	Total project							
Assessment method	Review of design team analysis.							
Applicable Standards	a							
	b							
	c							
	d							
Information Submittals	e							
	f							
Total project	Total Project			STC	Score	Values proposed by JMH	instead of	Source: Belgian acoustic standard
Negative				23.0	-1	50.0	23.0	
Acceptable practice	Design documents indicate that the Minimum Sound Transmission Class of partitions between			25.0	0	54.0	25.0	standard: normal comfort
Good Practice	primary occupancy areas will be :			31.0	3	59.0	31.0	
Best Practice				35.0	5	62.0	35.0	standard: superior comfort

Benchmarks D for designated occupancies in BigTown, Europe				Uses included	Small Industrial
					Office
					0
New Construction	Design Phase			Generic	.
D5.4 Acoustic performance within primary occupancy areas.					
Intent	To ensure that primary occupancies are designed to ensure a satisfactory level of acoustic performance.			Applicable phases (active if green)	
Indicator	Predicted reverberation time in seconds, as indicated by design characteristics.	Dsn		Ops.	
Information sources	Although acoustics is a complex science, only reverberation time is dealt with here.				
Applicable project type	Non-residential occupancies, all sizes				
Assessment method	Where needed, review of design team analysis by an acoustic specialist.				
Applicable Standards	a				
	b				
	c				
	d				
Information Submittals	e				
	f				
Occupancy 1	Small Industrial	on		Score	
Negative	Design documents indicate that reverberation time in primary occupancy areas will be more than 3.5 seconds or less than 0.5 second.			-1	
Acceptable practice	Design documents indicate that reverberation time in primary occupancy areas will be between 3.5 seconds and 0.5 second.			0	
Good Practice	Design documents indicate that reverberation time in primary occupancy areas will be between 3 seconds and 1 second.			3	
Best Practice	Design documents indicate that reverberation time in primary occupancy areas will be between 2.5 seconds and 1.5 second.			5	
Occupancy 2	Office	on		Score	
Negative	Design documents indicate that reverberation time in primary occupancy areas will be more than 3.5 seconds or less than 0.5 second.			-1	
Acceptable practice	Design documents indicate that reverberation time in primary occupancy areas will be between 3.5 seconds and 0.5 second.			0	
Good Practice	Design documents indicate that reverberation time in primary occupancy areas will be between 3 seconds and 1 second.			3	
Best Practice	Design documents indicate that reverberation time in primary occupancy areas will be between 2.5 seconds and 1.5 second.			5	
D6 Control of electromagnetic emissions					
Intent	To ensure that electro-magnetic emissions are kept to a level that does not harm human health.			Applicable phases (Active if green)	
Indicator		Dsn		Ops.	
Information sources	The report shown below states that there is no certain standard for EMF.				
Applicable project type	Environmental Health Perspectives				
Applicable project type	Total Building, all sizes.				
Assessment method	0				
Applicable Standards	a				
	b				
	c				
	d				
Information Submittals	e				
	f				
Total project	Total Project			Score	
Negative	XXXa.			-1	
Acceptable practice	XXXs			0	
Good Practice	XXXd.			3	
Best Practice	XXXg.			5	

text to be revised

"magnetic" instead of "electromagnetic"

Benchmarks E for designated occupancies in BigTown, Europe		Uses included	Small Industrial
			Office
			0
New Construction	Design Phase	Generic	.
E Service Quality			

Benchmarks E for designated occupancies in BigTown, Europe			Uses included	Small Industrial	
				Office	
				0	
New Construction	Design Phase		Generic		.
E1	Automation of building systems to maximize operational efficiency				
	#REF!	To encourage the commissioning of building systems with critical functions.	Applicable phases (Active if green)		
		The development of a commissioning plan and the range of systems to be commissioned.	Dsn	C&C.	Ops.
		It is strongly recommended that the architects and engineers should be involved in the commissioning process, to ensure that the design intent is respected. Costs are estimated as ranging from 0.5% to 1.5%, with specialized facilities much higher.			
	Applicable project type	Total building where total net area is more than threshold area.	Threshold area, m2	10 000	Not applicable to Crealys context
	#REF!	Review of commissioning management plan.			
	Applicable Standards	a	<div>Revise text</div>		
		b			
		c			
		d			
	Information Submittals	e			
		f			
	#REF!	Total project			Score
	Negative	No commissioning plan has been developed and no commissioning activities are planned.			-1
	Acceptable practice	A commissioning plan has been developed and some building systems with critical functions are to be commissioned, including life safety systems, central HVAC systems and electrical systems.			0
	Good Practice	A commissioning plan has been developed and all building systems with critical functions are to be fully commissioned, including life safety systems, central HVAC systems, lighting, building control and electrical systems.			3
Best Practice	A commissioning plan has been developed and all building systems with critical functions are to be fully commissioned, including life safety systems, central HVAC systems, lighting, building control, electrical systems and the building envelope.			5	

Benchmarks E for designated occupancies in BigTown, Europe				Uses included	Small Industrial		
					Office		
					0		
New Construction	Design Phase			Generic	.		
E2 Ability to modify facility technical systems.					<div></div>	<div></div>	
	#REF!	To encourage the commissioning of building systems with critical functions.			Applicable phases (Active if green)		
	#REF!	The development of a commissioning plan and the range of systems to be commissioned.			Dsn	C&C. Ops.	
	#REF!	It is strongly recommended that the architects and engineers should be involved in the commissioning process, to ensure that the design intent is respected. Costs are estimated as ranging from 0.5% to 1.5%, with specialized facilities much higher.			<div></div>	<div></div>	
	Applicable project type	Total building where total net area is more than threshold area.			Threshold area, m2	0	
	#REF!	Review of commissioning management plan.					
	Applicable Standards	a	<div>Revise text</div>				
		b					
		c					
		d					
	Information Submittals	e					
		f					
	#REF!	Total project				Score	
	Negative	No commissioning plan has been developed and no commissioning activities are planned.				-1	
	Acceptable practice	A commissioning plan has been developed and some building systems with critical functions are to be commissioned, including life safety systems, central HVAC systems and electrical systems.				0	
	Good Practice	A commissioning plan has been developed and all building systems with critical functions are to be fully commissioned, including life safety systems, central HVAC systems, lighting, building control and electrical systems.				3	
	Best Practice	A commissioning plan has been developed and all building systems with critical functions are to be fully commissioned, including life safety systems, central HVAC systems, lighting, building control, electrical systems and the building envelope.				5	

Benchmarks E for designated occupancies in BigTown, Europe			Uses included	Small Industrial	
				Office	
				0	
New Construction	Design Phase		Generic		.
E3 Commissioning of facility systems					
Intent	To encourage the commissioning of building systems with critical functions.		Applicable phases (Active if green)		
	Indicator	The development of a commissioning plan and the range of systems to be commissioned.	Dsn	C&C.	Ops.
Information sources		It is strongly recommended that the architects and engineers should be involved in the commissioning process, to ensure that the design intent is respected. Costs are estimated as ranging from 0.5% to 1.5%, with specialized facilities much higher.			
	Applicable project type	Total building where total net area is more than threshold area.	Threshold area, m2		10 000
#REF!		Review of commissioning management plan.			
	Applicable Standards	a			
b					
c					
d					
Information Submittals	e				
	f				
#REF!	Total project			Score	
	Negative	No commissioning plan has been developed and no commissioning activities are planned.			-1
Acceptable practice		A commissioning plan has been developed and some building systems with critical functions are to be commissioned, including life safety systems, central HVAC systems and electrical systems.			0
	Good Practice	A commissioning plan has been developed and all building systems with critical functions are to be fully commissioned, including life safety systems, central HVAC systems, lighting, building control and electrical systems.			3
Best Practice		A commissioning plan has been developed and all building systems with critical functions are to be fully commissioned, including life safety systems, central HVAC systems, lighting, building control, electrical systems and the building envelope.			5
	Not applicable to Crealys context				

Not applicable to Crealys context

Benchmarks E for designated occupancies in BigTown, Europe		Uses included	Small Industrial	
			Office	
			0	
New Construction	Design Phase	Generic	.	
E4 Maintenance of Operating Performance				
E4.1 Maintenance of building envelope performance.				
Intent	To ensure that detailed design minimizes the risk of moisture accumulating in the building envelope, where it is likely to shortn the lifespan of building elements, especially if constructed of wood in areas where temperatures can fall to below 0 deg.C.	Applicable phases (Active if green)		
Indicator	In areas where applicable, the existence of a report that describes and details the measures taken to ensure long-term integrity of the building envelope.	Dsn		Ops.
Information sources	0			
Applicable project type	Any occupancy type where winter design temperatures fall below 0 deg. C.			
Assessment method	Review of contract documents and engineering analysis of performance during winter conditions.			
Applicable Standards	a			
	b			
	c			
	d			
Information Submittals	e			
	f			
#REF!	Total Project			Score
Negative	Envelope detailing and construction does not follow industry good practice.			-1
Acceptable practice	Envelope detailing and construction follows industry good practice.			0
Good Practice	Envelope detailing and construction follows best practices, and at least one air-depressurization test is carried out.			3
Best Practice	Envelope detailing and construction follows best practices, and air-depressurization tests are carried out before and after interior finishes are applied.			5




Benchmarks E for designated occupancies in BigTown, Europe			Uses included	Small Industrial		
				Office		
				0		
New Construction	Design Phase		Generic		.	
E4.2 Development and implementation of a maintenance management plan.						
	Intent	To ensure the availability and implementation of a plan for the long-term maintenance and efficient operation of the facility.	Applicable phases (Active if green)			
	Indicator	The availability of a comprehensive and long-term plan at the end of Design phase, and evidence of its implementation during Operations phase.	Dsn		Ops.	
	Information sources	0				
	Applicable project type	Total project, where gross area exceeds threshold area.	Threshold area, m2	10 000	Not applicable to Crealys context	
	#REF!	Review of operations and maintenance management plan.				
	Applicable Standards	a				
		b				
		c				
		d				
	Information Submittals	e				
		f				
	#REF!	Total Project				Score
	Negative	No explicit plan exists for future maintenance and efficient operation of the facility.				-1
	Acceptable practice	An explicit plan exists for future maintenance and efficient operation of the facility, but it is not comprehensive and is not long term.			0	
	Good Practice	An explicit plan exists for future maintenance and efficient operation of the facility, covering main technical systems, and providing performance targets, system maintenance and replacement guidance over at least a 10-year period.			3	
	Best Practice	An explicit plan exists for future maintenance and efficient operation of the facility, covering all technical systems, and providing performance targets, system maintenance and replacement guidance over a 25-year period.			5	

Benchmarks E for designated occupancies in BigTown, Europe		Uses included	Small Industrial		
			Office		
			0		
New Construction	Design Phase	Generic			
E4.3 On-going monitoring and verification of performance.					
Intent	To ensure the ongoing optimization of building energy and water consumption performance over time.	Applicable phases (Active if green)			
Indicator	The provision of energy sub-metering systems and water consumption monitoring systems, according to design documentation.	Dsn			Ops.
Information sources	0				
Applicable project type	0				
Assessment method	Review of contract documentation, with special emphasis on the capability of the computerized building management system to manage the gathering and analysis of data from many dispersed locations.				
Applicable Standards	a				
	b				
	c				
	d				
Information Submittals	e				
	f				
#REF!	Total Project				Score
Negative	According to design documentation, no sub-metering of energy use will be provided for major occupancies.				-1
Acceptable practice	According to design documentation, an energy submetering system is provided for a few major occupancies.				0
Good Practice	According to design documentation, an energy and water submetering system will be provided for the occupancy, occasional air quality tests will be carried out, and a reporting system will be provided.				3
Best Practice	According to design documentation an energy and water submetering system linked to a building management system will be provided for the occupancy, regular air quality tests will be carried out, and a reporting system will be provided.				5

Benchmarks E for designated occupancies in BigTown, Europe		Uses included	Small Industrial	
			Office	
			0	
New Construction	Design Phase	Generic		.
E4.4 Retention of as-built drawings and documentation.				
Intent	Ensure that as-built architectural, mechanical and electrical drawings, and equipment manuals are available to operating staff and owners, so that they will be able to operate the building efficiently.	Applicable phases (Active if green)		
Indicator	The scope and quality of design documentation retained for use by building operators, according to design documentation.	Dsn		Ops.
Information sources	0			
Applicable project type	0			
Applicable Standards	a			
	b			
	c			
	d			
Information Submittals	e			
	f			
#REF!	Total Project	Score		
Negative	Operations and maintenance manuals have not been provided, or are deficient. Plans for operation do not provide for recording, reporting and documentation protocol for maintenance, or it will be inconsistent with the size and complexity of the building.	-1		
Acceptable practice	A full set of systems manuals and complete as-built drawings will be provided. There will be a partial recording, reporting and documentation protocol for maintenance, but somewhat inconsistent with the size and complexity of the building.	0		
Good Practice	A full set of operations and maintenance documentation, including a full set of systems manuals, complete as-built drawings and an operations and maintenance guide will be provided.	3		
Best Practice	A full set of operations and maintenance documentation, including a full set of systems manuals, complete as-built drawings and an operations and maintenance guide will be provided in both hard-copy and electronic forms.	5		

Benchmarks E for designated occupancies in BigTown, Europe		Uses included	Small Industrial		
			Office		
			0		
New Construction	Design Phase	Generic		.	
E4.5 Provision and maintenance of a building log.					
Intent	Assess whether operating events, such as significant events, occupancy density, operating schedule, energy and water consumption, renovations and equipment changes, etc., are all recorded in a building log for future analysis and reference.		Applicable phases (Active if green)		
	Indicator	The maintenance of a building log, of varying degrees of comprehensiveness.	Dsn		Ops.
Information sources	0				
Applicable project type	0				
Applicable Standards	a				
	b				
	c				
	d				
Information Submittals	e				
	f				
#REF!	Total Project			Score	
Negative	A building log is not maintained, or it is only sporadically maintained.			-1	
Acceptable practice	A building log is continuously maintained, but only a few key parameters are covered, such as energy and water consumption.			0	
Good Practice	A building log is continuously maintained, and contents include all key operating parameters, as well as most relevant supporting data.			3	
Best Practice	A building log is continuously maintained, and contents include all key operating parameters, as well as most relevant supporting data. The log is maintained in a software form that collects operating data from the BMS system.			5	

Benchmarks E for designated occupancies in BigTown, Europe		Uses included	Small Industrial	
			Office	
			0	
New Construction	Design Phase	Generic		
E4.6 Skills and knowledge of operating staff.				
Intent	To increase the probability that tenants and occupants will operate building systems under their control in an efficient manner. This probability will be increased if incentives are built into sales or lease agreements.	Applicable phases (Active if green)		
Indicator	The presence of sales agreements or leases that will incent owners or tenants to operate the facilities efficiently.	Dsn		Ops.
Information sources	0			
Applicable project type	All occupancies			
Assessment method	Review of proposed lease agreements to ascertain incentives and disincentives for efficient day-to-day management.			
Applicable Standards	a			
	b			
	c			
	d			
Information Submittals	e			
	f			
#REF!	Total Project			Score
Negative	Sales agreements or leases will contain no information relating to efficient building operations and heating, cooling and power costs are paid by the building owner.			-1
Acceptable practice	Planned leases will require tenants to pay directly for heating, cooling and electric power usage.			0
Good Practice	Planned leases will require tenants to pay directly for heating, cooling and electric power usage and information is provided about performance requirements and recommended practices.			3
Best Practice	Planned leases will require tenants to pay directly for heating, cooling and electric power usage, information is provided about performance requirements and recommended practices and performance incentives are provided.			5

Benchmarks F for designated occupancies in BigTown, Europe			Uses included	Small Industrial	
				Office	
				0	
New Construction	Design Phase		Generic		.
F Social and Economic aspects					
F1 Social Aspects					rejected in Glasgow, because considered as mandatory
F1.1 Minimization of construction accidents.					
	Intent	To minimize accidents causing injury or death to construction workers.		Applicable phases (Active if green)	
	Indicator	Target rate for accidents on the jobsite requiring hospitalization per 100,000 hours worked.		Dsn	Ops.
	Information sources	0			
	Applicable project type	0			
	Assessment method	Review of construction management plans by specialist in construction safety.			
	Applicable Standards	a			
		b			
		c			
		d			
	Information Submittals	e			
		f			
	Total project	Total Project		Rate	Score
	Negative			0.60	-1
	Acceptable practice			0.50	0
	Good Practice	Target rate for accidents on the jobsite requiring hospitalization per 100,000 hours worked is :		0.20	3
	Best Practice			0.00	5

Benchmarks F for designated occupancies in BigTown, Europe			Uses included	Small Industrial	
				Office	
				0	
New Construction	Design Phase		Generic		.
F1.2 Access for physically handicapped persons.					
	Intent	To assess the relative ease of access and use of facilities for persons with physical handicaps.		Applicable phases (Active if green)	
	Indicator	The scope and quality of design measures planned to facilitate access and use of building facilities by handicapped persons.		Dsn	Ops.
	Information sources	0			
	Applicable project type	By separate occupancies			
	Assessment method	Review of construction documents by a specialist in universal access design.			
	Applicable Standards	a			
		b			
		c			
		d			
	Information Submittals	e			
		f			
	Occupancy 1	Small Industrial			On
Negative	Design documentation indicates that not all key facilities in the occupancy, including entry points, washrooms and vertical circulation systems, are accessible to wheelchair users and visually impaired persons.				-1
Acceptable practice	Design documentation indicates that all key facilities in the occupancy, including entry points, washrooms and vertical circulation systems, are accessible to wheelchair users and visually impaired persons.				0
Good Practice	Design documentation indicates that all key facilities in the occupancy, including entry points, washrooms, vertical circulation systems and support facilities, are accessible to wheelchair users and visually impaired persons.				3
Best Practice	Same as Good Practice.				5
Occupancy 2	Office			on	Score
Negative	Design documentation indicates that not all key facilities in the occupancy, including entry points, washrooms and vertical circulation systems, are accessible to wheelchair users and visually impaired persons.				-1
Acceptable practice	Design documentation indicates that all key facilities in the occupancy, including entry points, washrooms and vertical circulation systems, are accessible to wheelchair users and visually impaired persons.				0
Good Practice	Design documentation indicates that all key facilities in the occupancy, including entry points, washrooms, vertical circulation systems and support facilities, are accessible to wheelchair users and visually impaired persons.				3
Best Practice	Same as Good Practice.				5

Benchmarks F for designated occupancies in BigTown, Europe					Uses included	Small Industrial					
						Office					
						0					
New Construction		Design Phase			Generic		.				
F1.3 Access to views from work areas.											
	Intent	To assess the extent to which the distance from a workstation to the exterior and the interior organization of the space does not limit visual access to exterior views.				Applicable phases (Active if green)					
	Indicator	Distance of the most remote workstation in a typical primary occupancy from exterior windows; and the extent to which interior organization provides exterior views.				Dsn		Ops.			
	Information sources	0									
	Applicable project type	For non-residential occupancies, all sizes.									
	#REF!	Review of analysis prepared by the design team.									
	Applicable Standards	a									
		b									
		c									
		d									
	Information Submittals	e									
		f									
	Occupancy 1	Small Industrial				on	m.	Score	Values proposed by JMH	instead of	Source
	Negative	The maximum distance from the most remote work location in a typical primary occupancy to exterior windows is :					11	-1		11	
	Acceptable practice						10	0		10	
	Good Practice						6	3		6	
	Best Practice						4	5		4	
	Occupancy 2	Office				On	m.	Score	Values proposed by JMH	instead of	Source
	Negative	The maximum distance from the most remote work location in a typical primary occupancy to exterior windows is :					11	-1		11	
	Acceptable practice						10	0		10	
	Good Practice						6	3		6	
	Best Practice						4	5		4	
F1.4 Social utility of primary building function								rejected in Glasgow			
	Intent	To assess the extent to which the primary occupancy function of the project satisfies basic societal needs.				Applicable phases (Active if green)					
	Indicator	The degree of social relevance of the primary occupancy.				Dsn		Ops.			
	Information sources	0									
	Applicable project type	All occupancies									
	Assessment method	Review of planned primary occupancy type by expert panel that includes a sociologist and an economist.									
	Applicable Standards	a									
		b									
		c									
		d									
	Information Submittals	e									
		f									
	Total project	Total Project						Score			
	Negative	The planned primary occupancy serves a function that will work against regional social values or stability.						-1			
	Acceptable practice	The planned primary occupancy serves a function that is not likely to have either a negative or positive impact on regional social values or stability.						0			
	Good Practice	The planned primary occupancy serves a function that is likely to have a positive impact on regional social values or stability.						3			
	Best Practice	The planned primary occupancy serves a function that is likely to have a very positive impact on regional social values or stability.						5			

Benchmarks F for designated occupancies in BigTown, Europe				Uses included	Small Industrial				
					Office				
					0				
New Construction	Design Phase			Generic	.				
F2 Cost and Economics				●	●				
F2.1 Minimization of life-cycle cost.									
	Intent	To assess the level of total Life Cycle Cost of the project			Applicable phases (Active if green)				
	Indicator	Predicted Life Cycle Cost over a 25-year period, with calculations carried out in accordance with recognized procedures.			Dsn	Ops.			
	Information sources	0							
	Applicable project type	0							
	Assessment method	Review of LCC analysis by a qualified cost consultant.							
	Applicable Standards	a							
		b							
		c							
		d							
	Information Submittals	e							
		f							
	Occupancy 1	Small Industrial	on	EUR per m2	Score	Values proposed by JMH	instead of	Source	
	Negative				9 880	-1		9 880	
	Acceptable practice				9 500	0		9 500	
	Good Practice	The maximum distance from the most remote work location in a typical primary occupancy to exterior windows is :			8 360	3		8 360	
	Best Practice				7 600	5		7 600	
	Occupancy 2	Office	on	EUR per m2	Score	Values proposed by JMH	instead of	Source	
	Negative				12 840	-1		12 840	
	Acceptable practice				12 000	0		12 000	
	Good Practice	The maximum distance from the most remote work location in a typical primary occupancy to exterior windows is :			9 480	3		9 480	
	Best Practice				7 800	5		7 800	
F2.2 Minimization of construction cost.									
	Intent	To assess the difference between the capital cost of the Design with that of a reference building designed according to standards of Acceptable Practice.			Applicable phases (Active if green)				
	Indicator	Predicted construction cost per unit area, according to design documentation.			Dsn	Ops.			
	Information sources	0							
	Applicable project type	For individual occupancies, all sizes							
	Assessment method	Review of cost analysis by a qualified cost consultant.							
	Applicable Standards	a							
		b							
		c							
		d							
	Information Submittals	e							
		f							
	Occupancy 1	Small Industrial	on	EUR/m2	Score	Values proposed by JMH	instead of	Source	
	Negative				2 100	-1		2 100	BEP : ?
	Acceptable practice				2 000	0		2 000	BEP : ?
	Good Practice	The maximum distance from the most remote work location in a typical primary occupancy to exterior windows is :			1 700	3		1 700	BEP : ?
	Best Practice				1 500	5		1 500	BEP : ?
	Occupancy 2	Office	on	EUR per m2	Score	Values proposed by JMH	instead of	Source	
	Negative				1 120	-1		1 120	BEP : ?
	Acceptable practice				1 100	0		1 100	BEP : ?
	Good Practice	The maximum distance from the most remote work location in a typical primary occupancy to exterior windows is :			1 040	3		1 040	BEP : ?
	Best Practice				1 000	5		1 000	BEP : ?

Benchmarks F for designated occupancies in BigTown, Europe		Uses included	Small Industrial
			Office
			0
New Construction	Design Phase	Generic	.

Benchmarks F for designated occupancies in BigTown, Europe				Uses included	Small Industrial			
					Office			
					0			
New Construction	Design Phase			Generic	.			
F2.3 Minimization of operating and maintenance cost.								
	Intent	To assess the difference between the operating cost of the Design with that of a reference building designed according to standards of Acceptable Practice.			Applicable phases (Active if green)			
	Indicator	Operating cost per unit area for energy, water & maintenance, according to design documentation.			Dsn	Ops.		
	Information sources	The operating cost of a high-performance building should be substantially less than Acceptable Practice, primarily because of reduced energy, water and equipment maintenance costs.						
	Applicable project type	For individual occupancies, all sizes						
	Assessment method	Review of operating cost projections by a cost consultant and a person knowledgeable in building operations.						
	Applicable Standards	a						
		b						
		c						
		d						
	Information Submittals	e						
		f						
	Occupancy 1	Small Industrial	on	EUR per m2	Score	Values proposed by JMH	instead of Source	
	Negative				17	-1	17	BEP : ?
	Acceptable practice	The maximum distance from the most remote work location in a typical primary occupancy to exterior windows is :			15	0	15	BEP : ?
	Good Practice				11	3	11	BEP : ?
	Best Practice				8	5	8	BEP : ?
	Occupancy 2	Office	on	EUR per m2	Score	Values proposed by JMH	instead of Source	
	Negative				6	-1	6	BEP : ?
	Acceptable practice	The maximum distance from the most remote work location in a typical primary occupancy to exterior windows is :			5	0	5	BEP : ?
	Good Practice				3	3	3	BEP : ?
	Best Practice				2	5	2	BEP : ?
F2.5 Support of Local Economy.								
	Intent	To encourage the purchase of a significant level of construction goods and services within the economic region.			Applicable phases (Active if green)			
	Indicator	Prediction of the percentage of construction expenditures for goods and services going to firms with permanent offices in the urban region.			Dsn	Ops.		
	Information sources	0						
	Applicable project type	For Total Project, all sizes.						
	#REF!	Review of expenditure program and sample analysis of material billing to verify costs.						
	Applicable Standards	a						
		b						
		c						
		d						
	Information Submittals	e						
		f						
	Total project	Total Project		Percent	Score	Values proposed by JMH	instead of Source	
	Negative				44%	-1	44%	BEP : ?
	Acceptable practice	The maximum distance from the most remote work location in a typical primary occupancy to exterior windows is :			50%	0	50%	BEP : ?
	Good Practice				68%	3	68%	BEP : ?
	Best Practice				80%	5	80%	BEP : ?