

NOMENCLATURE

1. PERFORMANCES

\dot{M}_a	Air mass flow rate	kg/s
\dot{M}_{CO_2}	CO ₂ mass flow rate	kg/s
MM	Molar mass	kg/kmol
X_{CO_2}	Air CO ₂ concentration	-
$dM/d\tau_{CO_2,in}$	Variation of room indoor CO ₂ mass	kg/s
V_{in}	Room indoor volume	m ³
v_a	Moist air specific volume	m ³ /kg _{dryair}
\dot{L}	Thermal imbalance of the human body	W
\dot{Q}_m	Metabolism not converted in work and dissipated as heat	W
\dot{Q}_a	Heat flow dissipated to ambience through breathing and skin	W
\dot{E}_m	Metabolism	W
η	Mechanical efficiency	-
\dot{H}_R	Enthalpy taken away by the breathing air	W
\dot{H}_{persp}	Perspiration i.e. steam diffusion through skin	W
\dot{H}_{sweat}	Sweating steam diffusion	W
\dot{Q}_{cl}	Heat flow through clothing	W
\dot{Q}_{rad}	Radiation heat exchange with ambience	W
\dot{Q}_{conv}	Convection heat exchange with ambience	W
A_{sk}	Human body skin area	m ²
C	Occupant <i>susceptibility</i>	-
PMV	Predicted Mean Vote	-
PPD	Predicted Percentage of Dissatisfied	%
$f_{comfort,profile}$	Factor equal to 1 when comfort is required, 0 when it isn't	-
$t_{set,occ}$	Temperature set point during occupancy period	°C
t_{in}	Indoor temperature	°C
τ	Time	s
dd	Degree-days	K.day
t_a	Moist air dry temperature	°C
W	Moist air humidity ratio	kg _{water} /kg _{dryair}
\dot{M}_w	Water mass flow rate	kg/s
$F_{w,in}$	Fictitious surcharge of indoor moisture capacity	-
p_w	Water vapor partial pressure of moist air total pressure	Pa
$p_{w,s}$	Water vapor partial pressure of saturated moist air	Pa
RH	Relative humidity of moist air	-
η	System efficiency	-
COP	System coefficient of performance	-

2. SOLAR HEAT GAINS AND SKY RADIATION

$q_{b,w}$	Heat gains from direct solar intensity through windows	W
SF	Window solar factor	-
g	Glazing solar factor	-
f_{fr}	Ratio of frame area in the whole window area	-
I_b	Direct solar intensity on a plane of a given slope and azimuth	W/m^2
A_w	Window area including glazing and frame	m^2
I_{bh}	Direct solar intensity measured on a horizontal plane	W/m^2
θ	Angle between sun beams and normal direction to a given wall	rad
θ_z	Angle between sun beams and vertical direction	rad
$A_{eq,w}$	Window equivalent solar area including glazing and frame	m^2
p	Wall slope (0 for horizontal position; $\pi/2$ for vertical)	rad
γ	Sun azimuth (0 for sun on south, >0 for sun on west)	rad
γ_p	Wall azimuth (0 for south facing wall, >0 for west facing wall)	rad
δ	Sun declination	rad
φ	Latitude	rad
λ	Longitude	rad
ω	True solar time	rad
λ_h	Longitude expressed in h	h
ω_h	True solar time expressed in h	h
UTC	Coordinated Universal Time in h	h
ET	Equation of Time in h	h
h_{cw}	Clock time in winter	h
h_{cs}	Clock time in summer	h
h_{solar}	Solar time of the place under consideration	h
$q_{dr,w}$	Heat gains from diffuse and reflected solar intensities through windows	W
I_{dr}	Diffuse and reflected solar intensities on a plane of a given slope	W/m^2
I_{dh}	Diffuse solar intensity measured on a horizontal plane	W/m^2
I_{bh}	Direct solar intensity measured on a horizontal plane	W/m^2
I_{th}	Total solar intensity measured on a horizontal plane	W/m^2
ρ	Surrounding ground albedo	-
I_{ir}	Infrared radiation emitted by an area of a given slope	W/m^2
$I_{ir,h}$	Infrared radiation emitted by an horizontal plane	W/m^2
$I_{ir,h,cs}$	Infrared radiation of a horizontal plane for clear sky conditions	W/m^2
$I_{ir,h,cc}$	Infrared radiation of a horizontal plane for covered sky conditions	W/m^2
J	Relative solar intensity at a given time	-
J_{cc}	Relative solar intensity for covered sky conditions $J_{cc} = 0,354$	-
J_{cs}	Relative solar intensity for clear sky conditions $J_{cs} = 1$	-
$I_{t,h}$	Total solar intensity on a horizontal plane at a given time	W/m^2
$I_{t,h,cs}$	Total solar intensity on a horizontal plane for clear sky conditions	W/m^2

3. WALL MODEL DEFINITION

\tilde{t}_1, \tilde{t}_2	Temperature variations expressed as complex quantities	$^{\circ}\text{C}$
\tilde{q}_1, \tilde{q}_2	Heat flow variations expressed as complex quantities	W/m^2
ω	Pulsation	rad/s
d	Thickness	m
α	Thermal diffusivity	m^2/s
λ	Thermal conductivity	$\text{W}/\text{m}\cdot\text{K}$
ρ	Mass density	kg/m^3
c	Specific heat	$\text{J}/\text{kg}\cdot\text{K}$
\tilde{K}_v	Wall transmittance	$\text{W}/\text{m}^2\cdot\text{K}$
\tilde{A}_v	Wall admittance	$\text{W}/\text{m}^2\cdot\text{K}$
ν	Frequency of a sinusoidal signal	s^{-1}
f_d	Dampening factor of a sinusoidal signal	-
R	Wall heat transfer resistance	$\text{m}^2\cdot\text{K}/\text{W}$
C	Wall heat capacity	$\text{J}/\text{m}^2\cdot\text{K}$
ϕ	Useful proportion of wall overall heat capacity	-
θ	Accessibility of wall overall heat capacity	-
U	Wall overall heat transfer coefficient	$\text{W}/\text{m}^2\cdot\text{K}$

4. BUILDING SIMPLIFIED MODEL DEFINITION

R_1	Heat transfer resistance of a zone light external walls	K/W
R_{21}, R_{22}	Heat transfer resistances of a zone massive external walls	K/W
C_2	Heat capacity of a zone massive external walls	J/K
R_3	Heat transfer resistance of a zone massive internal walls	K/W
C_3	Heat capacity of a zone massive internal walls	J/K
C_4	Heat capacity associated to a zone indoor node	J/K
R_v	Heat transfer resistance modeling zone ventilation heat losses	K/W
R_4	Heat transfer resistance of light walls separating zones	K/W
$R_{5,z1}, R_{5,z2}$	Heat transfer resistances of massive walls separating zones	K/W
C_5	Heat capacity of massive walls separating zones	J/K
t_1	Outdoor node temperature	$^{\circ}\text{C}$
t_2	Node temperature associated to C_2 capacity	$^{\circ}\text{C}$
t_3	Node temperature associated to C_3 capacity	$^{\circ}\text{C}$
t_4	Indoor node temperature	$^{\circ}\text{C}$
\dot{Q}_{vent}	Ventilation heat exchange between zone and outdoor	W
\dot{Q}_{transm}	Transmission heat exchange between zone and outdoor	W
$\dot{Q}_{heating}$	Emission from zone heating system	W
\dot{Q}_{sol}	Heat gains from direct solar intensity through windows	W
\dot{Q}_{occ}	Heat gains from occupants, lighting and appliances	W
U_{C4}	Energy stored in C_4 capacity	J

5. BUILDING SIMPLIFIED MODEL VALIDATION

Y	Outdoor heat flow response factor for indoor temperature impulse	W/m^2
Z	Indoor heat flow response factor for indoor temperature impulse	W/m^2
Δt	Time step for the computation of walls response factors	s
N	Finite elements temperature interpolation matrix	-
B	Finite elements temperature-gradient interpolation matrix	m^{-1}
N_S	Finite elements surface temperature interpolation matrix	-
C	Finite elements capacity matrix	J/K
L	Finite elements conductivity matrix	W/K
H	Finite elements convection and radiation matrix	W/K
h	Heat transfer coefficient, including convection and radiation	$W/m^2.K$
θ	Finite elements nodal temperatures vector	$^{\circ}C$
θ_e	Finite elements surface nodes temperatures vector	$^{\circ}C$
\dot{Q}_{convol}	Indoor heat flow from convection on zone response factors	W
$\dot{Q}_{out,isothermal}$	Indoor heat flow response to outdoor temperature	W
$\dot{Q}_{in,isothermal}$	Indoor heat flow response to indoor temperature for isothermal boundary conditions walls	W
$\dot{Q}_{in,adiabatic}$	Indoor heat flow response to indoor temperature for adiabatic boundary conditions walls	W
$\lambda_{out,isothermal}$	Convolution correction factor for $\dot{Q}_{out,isothermal}$	-
$\lambda_{in,isothermal}$	Convolution correction factor for $\dot{Q}_{in,isothermal}$	-
$\lambda_{in,adiabatic}$	Convolution correction factor for $\dot{Q}_{in,adiabatic}$	-
$\dot{Q}_{heating}$	Emission from zone heating system	W
$\dot{Q}_{heating,max}$	Maximum emission from zone heating system	W
X	Control factor	-
t_{in}	Indoor temperature	$^{\circ}C$
t_{set}	Temperature set point	$^{\circ}C$
X	Control factor	-
C	Invert of the differential of zone indoor temperature controller	K^{-1}
$t_{in,ref}$	Reference indoor temperature	$^{\circ}C$
\bar{t}_{in}	Daily mean indoor temperature	$^{\circ}C$
Δt_{in}	Daily indoor temperature amplitude	$^{\circ}C$
RMS	Root mean square of the error on indoor temperature	$^{\circ}C$
dmp	Indoor temperature dampening ratio	-
$\bar{t}_{in,st}$	Daily mean indoor temperature for a static computation	$^{\circ}C$
$\Delta t_{in,st}$	Daily indoor temperature amplitude for a static computation	$^{\circ}C$
$t_{eq,out}$	Equivalent outdoor temperature	$^{\circ}C$
$t_{a,out}$	Outdoor air temperature	$^{\circ}C$
α	Shortwave absorption factor	-
ε	Emissivity	-
h_{out}	Outdoor heat transfer coefficient (convection and radiation)	$W/m^2.K$
\dot{Q}_{sol}	Solar radiation reaching outdoor wall surface	W/m^2
$\dot{Q}_{sky,ir}$	Sky radiation related to outdoor wall surface	W/m^2

6. VENTILATION MODELS

Δp	Pressure drop through ventilation aperture	Pa
\dot{M}	Air mass flow rate through ventilation aperture	kg/s
n	Air mass flow rate exponent (0 for laminar, 1 for turbulent flow)	-
K	Constant of ventilation aperture resistance	Pa.(s/kg) ¹⁺ⁿ
Δp_{wind}	Wind pressure	Pa
p_c	Wind pressure factor	-
u_{wind}	Wind speed	m/s
v_{out}	Outdoor air specific volume	m ³ /kg
$\Delta p_{buoyancy}$	Buoyancy pressure	Pa
g	Acceleration of gravity	m/s ²
z	Level	m
v	Air specific volume	m ³ /kg
CSO	Controlled Supply Orifice	
CEO	Controlled Exhaust Orifice	
TO	Transfer Orifice	
\dot{M}_{ms}	Mechanical supply air mass flow rate	kg/s
\dot{M}_{me}	Mechanical exhaust air mass flow rate	kg/s
Δp_{duct}	Duct pressure drop	Pa
Δp_{unit}	Supply unit pressure drop including pressure balance device	Pa
Δp_{AHU}	Pressure drop through Air Handling Unit	Pa

7. AIR QUALITY ANALYSIS

X_{CO_2}	Air CO ₂ concentration	ppm
$X_{CO_2,set}$	Air CO ₂ concentration set point	ppm
C	Invert of the differential of indoor CO ₂ concentration controller	ppm ⁻¹
rpm_{fan}	Fan rotation speed	rev/min
$rpm_{fan,nom}$	Nominal fan rotation speed	rev/min
$COP_{chiller}$	Chiller coefficient of performance	-
$t_{a,su,cd}$	Chiller condenser air supply temperature	°C

8. SUMMER COMFORT ANALYSIS

t_{out}	Outdoor temperature	°C
t_{in}	Indoor temperature	°C
PPD	Predicted Percentage of Dissatisfied	%

9. CONNECTION WITH HEATING OR HVAC SYSTEM

$t_{s, floor}$	Heating floor surface temperature	$^{\circ}C$
t_{in}	Indoor temperature	$^{\circ}C$
t_w	Water temperature	$^{\circ}C$
$t_{room, under}$	Temperature of the room under heating floor	$^{\circ}C$
$R_{floor, in}$	Heat transfer resistance between floor surface and indoor node	K/W
$R_{w, floor}$	Heat transfer resistance between water pipes and floor surface	K/W
$R_{floor losses}$	Heat transfer resistance between water pipes and room under	K/W
C_{floor}	Floor heat capacity	J/K
$\dot{Q}_{ex, floor}$	Heat flow supplied by the heating floor to the zone	W
$\dot{Q}_{su, floor}$	Heat flow supplied by the water to the heating floor	W
$\dot{Q}_{floor, storage}$	Heat flow stored in the floor heat capacity	W
ε_{floor}	Heating floor heat exchange efficiency	-
$\dot{C}_{w, floor}$	Heating floor water heat capacity rate	W/K
$t_{w, su, floor}$	Heating floor water supply temperature	$^{\circ}C$
$t_{w, ex, floor}$	Heating floor water exhaust temperature	$^{\circ}C$
$t_{w, su, floor, set}$	Heating floor water supply set point temperature	$^{\circ}C$
$t_{w, su, floor, nom}$	Heating floor water supply temperature for nominal conditions	$^{\circ}C$
t_{out}	Outdoor temperature	$^{\circ}C$
$t_{out, nom}$	Outdoor nominal temperature	$^{\circ}C$
t_{set}	Indoor set point temperature	$^{\circ}C$
C_{ff}	Feed-forward proportional action factor	-
C_{fb}	Feed-back proportional action factor	-
C_w	Invert of the differential of water supply temperature controller	K^{-1}
C_{in}	Invert of the differential of zone indoor temperature controller	K^{-1}
$t_{c, ground}$	Ground capacity node temperature	$^{\circ}C$
t_{ground}	Ground temperature	$^{\circ}C$
$t_{glw, su, ev}$	Brine-water heat pump evaporator brine supply temperature	$^{\circ}C$
$R_{ground, fluid}$	Heat transfer resistance between ground capacity node and brine	K/W
R_{ground}	Ground heat transfer resistance	K/W
C_{ground}	Ground heat capacity	J/K
\dot{Q}_{ev}	Heat flow supplied to the brine-water heat pump evaporator	W
$\dot{Q}_{su, ground}$	Heat flow supplied by the ground heat exchanger	W
$\dot{Q}_{ground, storage}$	Heat flow stored in the ground heat capacity	W
NTU	Heat exchanger number of transfer units	-
AU	Heat exchanger overall heat transfer coefficient	W/K
\dot{C}_a	Heat exchanger air heat capacity rate	W/K
\dot{C}_w	Heat exchanger water heat capacity rate	W/K
ε	Heat exchanger efficiency	-

w_a	Moist air humidity ratio /kg _{dryair}	kg _{water}
\dot{M}_a	Air mass flow rate	kg _{dryair} /s
\dot{M}_{steam}	Steam mass flow rate	kg _{water} /s
h_a	Moist air enthalpy	J/kg _{dryair}
h_{steam}	Steam enthalpy	J/kg _{water}
h_{fg0}	Latent heat of vaporization	J/kg _{water}
c_{pg}	Vapor specific heat at constant pressure	J/kg.K
c_{pa}	Air specific heat at constant pressure	J/kg.K
h_c	Convection heat transfer coefficient	W/m ² .K
h_m	Mass transfer conductance	kg/m ² .s
w_{sat}	Moist air humidity ratio for saturated air /kg _{dryair}	kg _{water}
$h_{sat,tw}$	Enthalpy of saturated air at temperature t_w	J/kg _{dryair}
t_{wb}	Moist air wet bulb temperature	°C
R_w	Water side cooling coil thermal resistance	m ² .K/W
R_m	Metal cooling coil thermal resistance	m ² .K/W
R_a	Air side dry air cooling coil thermal resistance	m ² .K/W
R_{sat}	Air side saturated air cooling coil thermal resistance	m ² .K/W
AU_c	Wet cooling coil contact heat transfer coefficient	W/K
ε_c	Wet cooling coil contact effectiveness	-
t_c	Wet cooling coil contact temperature	°C

REFERENCES

- [1] IEA ECBCS Annex 3: “Energy Conservation in Residential Buildings”
Anon;
“Calculation Methods to Predict Energy savings in Residential Buildings” (1983)
- [2] IEA ECBCS Annex 10:
J. Lebrun, G. Liebecq;
“System Simulation Synthesis Report” (1988)
- [3] IEA ECBCS Annex 21:
L. G. Mansson;
“Calculation of Energy & Environmental Performance of Buildings: Technical Synthesis Report” (1998)
- [4] IEA ECBCS Annex 23:
P. Warren;
“Multizone Air Flow Modelling (COMIS): Technical Synthesis Report” (2000)
- [5] IEA ECBCS Annex 24:
H. Hens;
“Heat, Air and Moisture Transfer in Highly Insulated Building Envelopes: Technical Synthesis Report” (2002)
- [6] IEA ECBCS Annex 40: “Commissioning of HVAC systems” (2000-2005)
Website : www.commissioning-hvac.org
- [7] IEA ECBCS Annex 43: “Validation of simulation models” (2003-2007)
P. André, J. Lhoest;
“Testing and Validation of Building Energy Simulation tools: Digest du rapport final de la sous-tâche C” (June 2007)
- [8] IEA ECBCS Annex 43: “Validation of simulation models” (2003-2007)
C. Adam, P. André, B. Georges, J. Lebrun, V. Lemort, J. Lhoest, G. Masy;
“Testing and Validation of Building Energy Simulation tools: Rapport de la première étude de cas (simulation intégrée) : maison résidentielle de Gesves” (June 2007)
- [9] G. Masy ;
« Dynamic Simulation on Simplified Building Models and Interaction with Heating Systems », *7th International Conference on System Simulation in Buildings, Liège, December, 2006.*
- [10] Ph. André, C. Aparecida Silva, J. Hannay, J. Lebrun, V. Lemort and V. Teodorese
“Simulation of HVAC systems: development and validation of simulation models and examples of practical applications.”
Keynote presented at Mercofrio 2006, Porto Alegre, Brazil, October 17-20 2006

- [11] Ph. André, J. Lebrun, V. Lemort, G. Masy, V. Teodorese
 “Développement de modèles pour la simulation des systèmes de chauffage, ventilation et conditionnement d’air.”
Communication presented at the CFQ conference, Montréal May 2007
- [12] Ph. André, B. Georges, V. Lemort, J. Lebrun, G. Masy
 “A friendly tool for comparative energy evaluation of different space heating systems in residential buildings.”
Communication presented at the Passive House Symposium, Zolder 6 October 2006
- [13] X. Xu and S. Wang
 “Optimal simplified thermal models of building envelope based on frequency domain regression using genetic algorithm.”
 Department of Building Services Engineering, The Hong Kong Polytechnic University, Kowloon, Hong Kong, China.
Energy and Building Conference, 2007
- [14] G. Fraisse, C. Viardot, J. Hannay, G. Achard
 “Development of building Models based on Electrical Analogy.”
 Laboratoire Optimisation de la Conception et Ingénierie de l’Environnement
 Université de Savoie, France.
Communication presented at the System Simulation in Buildings Conference, 2002
- [15] C. Felsmann, G. Knobe, H. Werdin
 “Simulation of Domestic Heating Systems by integration of TRNSYS in a MATLAB/SIMULINK Model.”
Communication presented at the System Simulation in Buildings Conference, 2002
- [16] D. Herron, G. Walton, L. Lawrie;
 “Building Loads Analysis and System Thermodynamics (BLAST) program users manual”
Army Construction Engineering Research Lab., Champaign, IL, 1981.
- [17] R. Sonderegger;
 “Dynamic Models of House Heating based on Equivalent Thermal Parameters”
Princeton University Press, 1977.
- [18] M. Kummert
 “Contribution to the application of modern control techniques to solar buildings: simulation based approach and experimental validation”
 PHD Thesis, Fondation Universitaire Luxembourgeoise, 2001.
- [19] L. Laret
 « Contribution au développement de modèles mathématiques du comportement thermique transitoire de structures d’habitation. »
 Thèse de doctorat, Université de Liège, 1981.
- [20] F. Lorenz ; G. Masy
 « Méthode d’évaluation de l’économie d’énergie apportée par l’intermittence de chauffage dans les bâtiments. Traitement par différences finies d’un modèle à deux constantes de temps. »

- [21] G. Masy
« Building dynamic simplified model. »
Working document IEA 43, February 2006.
HEPL Rennequin Sualem ; GM060228-01
- [22] G. Masy
« Modelling of wall equivalent solar area. »
Working document IEA 43, February 2006.
HEPL Rennequin Sualem; GM060228-01
- [23] P. Ngendakumana, J. Lebrun
« Simulation thermique des bâtiments par des modèles simplifiés du second ordre : mode d'emploi et applications. »
Université de Liège, décembre 1983 ; PNG831209-01
- [24] P. Ngendakumana
« Etude de l'introduction des phénomènes solaires dans les modèles simplifiés de bâtiments. »
Université de Liège, octobre 1984 ; PNG841026-01
- [25] P. Ngendakumana, G. Liebecq
« Les facteurs de réponse simplifiés de paroi. »
Université de Liège, février 1986 ; PNG860215-01
- [26] P. Ngendakumana
« Les facteurs de réponse simplifiés de paroi. »
Université de Liège, février 1986 ; PNG860215-01
- [27] « Comparison of Load Determination Methodologies for Building Energy Analysis Programs. »
US Department of Energy, Washington
Prepared for international Energy Agency
Energy Conservation in Buildings & Community Systems Program, January 1981.
- [28] M. Sherman, D. Grimsrud
« Measurement of Infiltration using Fan Pressurization and Weather Data. »
Energy and Environment Division
Lawrence Berkeley Laboratory
University of California, 1980.
- [29] A. Blomsterberg, M. Modera, D. Grimsrud
« Mobile infiltration test unit: Its design and capabilities, preliminary experimental results. »
Energy and Environment Division
Lawrence Berkeley Laboratory
University of California, 1981.
- [30] M. Liddament
« A Guide to Energy Efficient Ventilation.»

Air Infiltration and Ventilation Centre
University of Warwick Science Park, March 1996.

- [31] K. Bathe
“Finite Element Procedures”
Prentice Hall International Editions, 1996.
- [32] Recknagel, Sprenger, Hönnmann
“Manuel pratique du genie climatique”
PYC Editions, 1986.
- [33] Ngendakumana P.
"Modélisation simplifiée du comportement thermique d'un bâtiment et vérification expérimentale".
Ph. D. Thesis in Applied Sciences. Université de Liège, Laboratoire de Physique du bâtiment, 1988
- [34] S. Filfli
“Optimisation bâtiment/système pour minimiser les consommations dues à la climatisation”
Ecole des mines de Paris, 2006.
- [35] M. Dupont
“Potentiel d'économies d'énergie par les services énergétiques – application au cycle de vie des équipements de conversion d'énergie ”
Ecole des mines de Paris, 2006.
- [36] Davies, M. G.
“Building Heat Transfer ”
John Wiley & Sons, Chichester, England, 2004
- [37] N. Heijmans, P. Wouters, Ch. Delmotte, D. Van Orshoven
“La ventilation des immeubles de bureau: vers une meilleure expression des exigences ”
Centre Scientifique et Technique du Bâtiment, 2005
- [38] J.H. Klote
“A General Routine For Analysis of Stack Effect »”
U.S. Department of Commerce, National Institute of Standards and Technology, 1991
- [39] CD-ROM Energie +
UCL, Service Architecture et Climat
- [40] S. Bertagnolio, G. Masy, J. Lebrun and P. André
“Building and HVAC system simulation with the help of an engineering equation solver”
SimBuild 2008 Conference, Berkeley, USA.
- [41] J. Lebrun
“Climatisation: le confort thermique”
Notes de cours 2003-2004, Université de Liège.
- [42] Klein, S.A., Alvarado, F.L. 2002.

EES : Engineering Equation Solver. F-chart software.

- [43] 11 Mars 2005- Arrêté du Gouvernement flamand établissant des exigences en matière de performance énergétique et de climat intérieur des bâtiments, Moniteur belge, vendredi 17 juin 2005.
- [44] « Prix d'achat de l'énergie par les ménages », APERE – Revue « Renouvelle », 1^{er} trimestre 2007.
- [45] Logiciel « EPB software », Calcul du niveau E en Flandres Logiciel développé par DECYSIS.
- [46] Y.A. Cengel
“Heat and mass transfer : a practical approach”
Mc Graw Hill, 2006.
- [47] J. Lebrun
“How to Effectively Use Advanced Research Energy Saving Technologies in HVAC Systems”
Notes de cours donné à Gliwice, May 2004, Université de Liège.
- [48] D. Marchio, P. Stabat
“Echangeur arrosé à plaques ou à tubes”
Ecole des mines de Paris, Centre d'Energétique, août 2000.
- [49] G. Masy
“ Modèle dynamique simplifié de bâtiment : définition et méthode de validation”
Projet Sisal Minergibat, Rapport Semestriel avril 2007, Annexe 2.
- [50] G. Masy, V. Nicolai
“ Validation d'un modèle dynamique simplifié pour le secteur résidentiel ”
Projet Sisal Minergibat, Rapport Semestriel avril 2007, Annexe 4.
- [51] G. Masy
“ Building Tightness and Air Renewal ”
IEA Annex 40, Final Subtask B2, Development of Functional Performance Testing procedures, January 2005.
- [52] O. Morisot, D. Marchio
“ HEATEX échangeur de chaleur: modèle NUT-ε en enthalpie ou en température de l'HVAC2 Toolkit”
Ecole des mines de Paris, Centre d'énergétique, mars 1999.